

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

MARSHA L. BROWN
PRESIDENT

PEDRO BIRBA
VICE-PRESIDENT

VAN AMBATIELOS
HELENA JUBANY
ELENORE A. WILLIAMS

CITY OF LOS ANGELES
CALIFORNIA



ANTONIO R. VILLARAIGOSA
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

ANDREW A. ADELMAN, P.E.
GENERAL MANAGER

RAYMOND CHAN
EXECUTIVE OFFICER

ITW Ramset
700 High Grove Boulevard
Glendale Heights, IL 60139

RESEARCH REPORT: RR 25264
(CSI # 03150)

Expires: July 1, 2009

Attn: Dave Jablonski
(800) 726-7386

GENERAL APPROVAL - Renewal - ITW Ramset Trakfast Fasteners.

DETAILS

ITW Ramset Trakfast Fasteners are used for the attachment of drywall track to concrete, lightweight concrete, metal deck with lightweight concrete fill, concrete masonry units and steel. The fasteners are manufactured from steel conforming to AISI 1060 to 1065, and are austempered. The concrete and masonry fasteners have a 0.109" shank diameter, and are either black oxide finished or zinc plated. The steel fasteners have a 0.109" shank diameter, and are zinc plated. All fasteners are collated into plastic strips of 10 fasteners each.

The fasteners in collated strips are designed to be installed with an ITW Ramset Trakfast tool in accordance with an ITW Ramset recommendations.

The allowable shear and tension values for Trakfast Fasteners installed in concrete, lightweight concrete, metal deck with lightweight concrete fill, concrete masonry units and steel are set forth in the attached tables in this report.

The approval is subject to the following conditions:

1. The allowable values listed in the tables are for the fasteners only. The connected drywall tracks shall be checked for their capacity.
2. No increase is permitted in the tabulated allowable loads for short duration loading.
3. The Trakfast Fasteners are identified by a "R" stamped into the head of the fasteners.

RR 25264
Page 1 of 4

ITW Ramset

RE: ITW Ramset Trakfast Fasteners.

4. Fasteners shall not be installed until the concrete has reached the designated compressive strength.
5. The fasteners shall be installed per the manufacturer's instructions, a copy of which shall be available at each job site.
6. Minimum concrete thickness shall be three times the fastener penetration into the concrete.

DISCUSSION

The clerical modification is to change the company name, the address and the telephone number.

The approval is based on load test.

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this approval have been met in the project in which it is to be used.

YEUAN CHOU, Chief
Engineering Research Section
2319 Dorris Place
Los Angeles, CA 90031
Phone (213) 485-2376
Fax (213) 847-0985

RB:elcm
RR25264/wp8.0
R08/08/07
5A1/5C2/1925

ITW Ramset

RE: ITW Ramset Trakfast Fasteners.

Table A
Allowable Working Values for Trakfast Fasteners Installed in Normal Weight Concrete^{1,2}

Shank Diameter (in.)	Minimum Embedment (in.)	Concrete Compressive Strength					
		2500 PSI		3500 PSI		4500 PSI	
		Tension (lb.)	Shear (lb.)	Tension (lb.)	Shear (lb.)	Tension (lb.)	Shear (lb.)
.109	5/8	50	65	50	75	55	85
.109	3/4	70	80	70	85	70	90

¹Allowable values are for Trakfast Fasteners with black oxide or zinc plated finish .

²Fasteners shall have a minimum edge distance of 3 inches.

Table B
Allowable Working Values for Trakfast Fasteners Installed in Concrete Masonry Units^{1,2}

Shank Diameter (in.)	Minimum Embedment (in.)	Hollow CMU (any location)	
		Tension (lb.)	Shear (lb.)
.109	5/8	40	50

¹Allowable values are for Trakfast Fasteners with zinc plated finish only.

²Fasteners shall have minimum edge distance of 3 inches.

Table C
Allowable Working Values for Trakfast Fasteners in Minimum 3500 PSI Structural Lightweight Concrete¹

Shank Diameter (in.)	Minimum Embedment (in.)	Installed in Concrete ²		Installed Through Metal Deck ³	
		Tension (lb.)	Shear (lb.)	Tension (lb.)	Shear (lb.)
.109	5/8	30	50	30	125
.109	3/4	75	90	40	155

¹Zinc plated or black oxide finished fasteners may be used.

²Fasteners shall have minimum edge distance of 3 inches.

³Fasteners shall have minimum 1 1/8" setback from edge of lower flute.

ITW Ramset

RE: ITW Ramset Trakfast Fasteners.

Table D
Allowable Working Values for Trakfast
Fasteners Installed in ASTM A36 Steel^{1,2,3}

Fastener Type	Steel Thickness					
	3/16"		1/4"		3/8"	
	Tension (lb.)	Shear (lb.)	Tension (lb.)	Shear (lb.)	Tension (lb.)	Shear (lb.)
0.109" shank	200	315	230	305	210	215

¹Fasteners shall have a minimum edge distance of ½ inch.

²Fasteners installed in 3/16 & 1/4 inch thick steel shall penetrate the steel and protrude a minimum of .16 & .10 inches respectively.

³Fasteners shall have a .32 inch minimum penetration when installed into 3/8" thick steel