



Technical Questions and Answers
RectorSeal® Firestopping Sealants
LEED (Leadership in Energy and Environmental Design)
Green Building Rating System®

The following information is provided to assist architects and persons responsible for obtaining a U.S. Green Building Council (USGBC) Certification.

- **Do RectorSeal® Firestopping products meet USGBC requirements?**

RectorSeal® firestopping sealants meet the 1-point credit requirements of Section 4.1 of the LEED™ Rating System Version 2.2 (Low-Emitting Materials: Adhesives & Sealant. As currently manufactured, RectorSeal® firestopping sealants contain less than 10 g/L volatile organic compounds (VOC) and comply with limits established by the South Coast Air Quality Management District (SCAQMD) Rule #1168, and the Bay Area Air Quality Management District Regulation 8, Rule 51.

- **Why is there no LEED Certification on the product label?**

According to USGBC: *“USGBC certifies buildings, not the materials that are used to construct the building. Only USGBC can use the LEED logo. All others violate USGBC’s registered trademark rights.”*