


Description: 3MTM Brand Fire Barrier Products

- FireDamTM Spray
- FireDamTM 150 Caulk
- Fire Barrier CP 25WB+ Caulk
- Fire Barrier 2000 Silicone Sealant
- Fire Barrier 2000+ Silicone Sealant
- Fire Barrier 2001 Silicone RTV Foam
- Fire Barrier 2003 Silicone Sealant SL
- Graphite Intumescent Seal (GIS)
- Fire Barrier CS-195+ Composite Sheet
- Fire Barrier FS-195+ Sheet
- Fire Barrier FS-195+ Wrap/Strip
- Fire Barrier Moldable Putty+
- Fire Barrier Plastic Pipe Device (PPD)
- InteramTM Ultra GS Wrap
- InteramTM G Mat
- ExpantrolTM Flexible Intumescent Seal (EFIS)

These Products are Tested According to ASTM Standards:


- ASTM E 119 Fire Tests of Building Construction and Materials Time-Temperature Curve
- ASTM E 814 Fire Tests of Through-Penetration Fire Stops (Under positive furnace pressure of minimum .01 inches of water column.)
- ASTM E 84 Surface Burning Characteristics of Building Materials
- UL 2079 Test for Fire Resistance of Building Joint Systems
- NFPA 252 Standard Methods of Fire Test and Door Assemblies
- UBC Standard 7-2(97)
- No asbestos or PCBs are used or contained in these products.



Quality Manager or Designee

04-06-00

Date



Fire Protection Laboratory Manager or Designee

04-06-00

Date