

SPECIFICATION CLAUSE

POWERDRAIN S100K - LOAD CLASS B

GENERAL

THE SURFACE DRAINAGE SYSTEM SHALL BE POLYMER CONCRETE S100K CHANNEL SYSTEM WITH DUCTILE IRON RAILS AS MANUFACTURED BY ACO POLYMER PRODUCTS, INC.

MATERIALS

CHANNELS SHALL BE MANUFACTURED	D FROM		
POLYESTER RESIN POLYMER CONCRETE WITH AN			
INTEGRALLY CAST-IN DUCTILE IRON RAIL.			
MINIMUM PROPERTIES OF POLYMER CONCRETE WILL			
AS FOLLOWS:			
COMPRESSIVE STRENGTH:	14,000 PSI		
FLEXURAL STRENGTH:	4,000 PSI		
TENSILE STRENGTH:	1,500 PSI		
WATER ABSORPTION:	0.07%		
FROST PROOF	YES		
DILUTE ACID AND ALKALI RESISTANT	YES		
B117 SALT SPRAY TEST COMPLIANT	YES		

THE SYSTEM SHALL BE 4" (100mm) NOMINAL INTERNAL WIDTH WITH A 6.29" (160mm) OVERALL WIDTH AND A BUILT-IN SLOPE OF 0.5%. CHANNEL INVERT SHALL HAVE DEVELOPED "V" SHAPE. ALL CHANNELS SHALL BE INTERLOCKING WITH A MALE/FEMALE JOINT.

THE COMPLETE DRAINAGE SYSTEM SHALL BE BY ACO POLYMER PRODUCTS, INC. ANY DEVIATION OR PARTIAL SYSTEM DESIGN AND/OR IMPROPER INSTALLATION WILL VOID ANY AND ALL WARRANTIES PROVIDED BY ACO POLYMER PRODUCTS. INC.

CHANNEL SHALL WITHSTAND LOADING TO PROPER LOAD CLASS AS OUTLINED BY EN 1433. GRATE TYPE SHALL BE APPROPRIATE TO MEET THE SYSTEM LOAD CLASS SPECIFIED AND INTENDED APPLICATION. GRATES SHALL BE SECURED USING EITHER THE 'POWERLOK' BOLTLESS LOCKING SYSTEM OR THE 4 BOLT LOCKING OPTION. CHANNEL AND GRATE SHALL BE CERTIFIED TO MEET THE SPECIFIED EN 1433 LOAD CLASS. THE SYSTEM SHALL BE INSTALLED IN ACCORDANCE WITH THE MANUFACTURER'S INSTRUCTIONS AND RECOMMENDATIONS.

ACO Polymer Products, Inc. 9470 Pinecone Dr.

	Fax: 520-421-9899	Fax: 440-639-7235	Fax: 803-802-1063
O DRAIN	Tel: 520-421-9988	Tel: 440-639-7230	Tel: 440-639-7230
	Casa Granue, AZ 05122		FULLIVIIII, SC 29700
	Casa Grande. AZ 85122	Mentor, OH 44060	Fort Mill. SC 29708

Arizona Tel: 888-490-9552

e-mail: sales@acousa.com

Ohio Tel: 800-543-4764

www.acousa.com

South Carolina Tel: 800-543-4764

4211 Pleasant Rd.