

## SPECIFICATION CLAUSE

### **POWERDRAIN S200K - LOAD CLASS C**

#### GENERAL

THE SURFACE DRAINAGE SYSTEM SHALL BE POLYMER CONCRETE S200K CHANNEL SYSTEM WITH DUCTILE IRON EDGE RAILS AS MANUFACTURED BY ACO POLYMER PRODUCTS, INC.

#### MATERIALS

| CHANNELS SHALL BE MANUFACTURED              | FROM       |  |  |
|---|------------|--|--|
| POLYESTER RESIN POLYMER CONCRETE WITH AN    |            |  |  |
| INTEGRALLY CAST-IN DUCTILE IRON EDGE RAIL.  |            |  |  |
| MINIMUM PROPERTIES OF POLYMER CONCRETE WILL |            |  |  |
| BE AS FOLLOWS:                              |            |  |  |
| COMPRESSIVE STRENGTH:                       | 14,000 PSI |  |  |
| FLEXURAL STRENGTH:                          | 4,000 PSI  |  |  |
| TENSILE STRENGTH:                           | 1,500 PSI  |  |  |
| WATER ABSORPTION:                           | 0.07%      |  |  |
| FROST PROOF                                 | YES        |  |  |
| DILUTE ACID AND ALKALI RESISTANT            | YES        |  |  |
| B117 SALT SPRAY TEST COMPLIANT              | YES        |  |  |

THE SYSTEM SHALL BE 8" (200mm) NOMINAL INTERNAL WIDTH WITH A 10.2" (260mm) OVERALL WIDTH AND A BUILT-IN SLOPE OF 0.5%. CHANNEL INVERT SHALL HAVE DEVELOPED "V" SHAPE. ALL CHANNELS SHALL BE INTERLOCKING WITH A MALE/FEMALE JOINT.

THE COMPLETE DRAINAGE SYSTEM SHALL BE BY ACO POLYMER PRODUCTS, INC. ANY DEVIATION OR PARTIAL SYSTEM DESIGN AND/OR IMPROPER INSTALLATION WILL VOID ANY AND ALL WARRANTIES PROVIDED BY ACO POLYMER PRODUCTS, INC.

CHANNEL SHALL WITHSTAND LOADING TO PROPER LOAD CLASS AS OUTLINED BY EN 1433. GRATE TYPE SHALL BE APPROPRIATE TO MEET THE SYSTEM LOAD CLASS SPECIFIED AND INTENDED APPLICATION. GRATES SHALL BE SECURED USING EITHER THE 'POWERLOK' BOLTLESS LOCKING SYSTEM OR THE 4 BOLT LOCKING OPTION. CHANNEL AND GRATE SHALL BE CERTIFIED TO MEET THE SPECIFIED EN 1433 LOAD CLASS. THE SYSTEM SHALL BE INSTALLED IN ACCORDANCE WITH THE MANUFACTURER'S INSTRUCTIONS AND RECOMMENDATIONS.

# **ACO Polymer Products, Inc.**

| aunched Asphalt Pavement | 825 W. Beechcraft St  | 9470 Pinecone Dr. | 4211 Pleasant Rd.   |
|--------------------------|-----------------------|-------------------|---------------------|
|                          | Casa Grande, AZ 85122 | Mentor, OH 44060  | Fort Mill, SC 29708 |
| TION DRAWING - ACO DRAIN | Tel: 520-421-9988     | Tel: 440-639-7230 | Tel: 440-639-7230   |
|                          | Fax: 520-421-9899     | Fax: 440-639-7235 | Fax: 803-802-1063   |

Arizona Tel: 888-490-9552

e-mail: sales@acousa.com

Ohio Tel: 800-543-4764

www.acousa.com

South Carolina Tel: 800-543-4764