

Use of
Synko-Flex Preformed Adhesive Waterstop in
Potable Water Applications

Thank you for your interest in Synko-Flex Waterstop.

Synko-Flex, used in accordance with manufacturer's suggested installation guidelines, is safe for use in potable water applications. Synko-Flex, being bituminous based and hydrophobic in nature, will not leach into or mix with potable water. Additionally, Synko-Flex is installed, confined within concrete construction joints and has very little, if any, direct contact with the potable water itself.

Synko-Flex has been certified by NSF International to conform to the requirements of NSF 61 – Drinking Water System Components – Health Effects. A copy of this listing is attached. This certification can be verified on NSF's web site at www.nsf.org.

If you have any further questions or concerns, please contact our technical services department at 1-800-231-4551.



Certified to
ANSI/NSF 61

NSF International NSF)
OFFICIAL LISTING

This is a Certification by NSF that these products conform to the requirements of NSF Standard 61 - Drinking Water System Components - Health Effects

This is your Official Listing as we have it on record at this time.

October 18, 1999

CC: 04

HENRY COMPANY - SEALANTS DIVISION
1277 BOYLES STREET
HOUSTON, TEXAS 77020

Plant At: Houston, Texas

JOINING & SEALING MATERIALS

Trade Designation		Size	Water Contact Temp	Water Contact Material
Sealants				
Synko-Flex®#	*		CLD 30	ASPH

*This product is Certified for a 100,000-gallon tank and greater.

#Certified for use only in conjunction with Synko-Flex® PRIMER or Synko-Flex® EMULSION PRIMER.

Plant At: GARLAND, TX

JOINING & SEALING MATERIALS

Trade Designation		Size	Water Contact Temp	Water Contact Material
Sealants				
Synko-Flex® EMULSION PRIMER#	*		CLD 30	ASPH
Synko-Flex® PRIMER#	*		CLD 30	ASPH

* This product is Certified for a 100,000-gallon tank and greater.

Certified for use only in conjunction with Synko-Flex® strips.

Additions Cannot Be Made To
This Listing Without Prior
Evaluation And Acceptance By NSF
Issued by Certification Records