



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786)315-2590 F (786) 31525-99

www.miamidade.gov/economy

CertainTeed Corporation
1400 Union Meeting Road, P.O. Box 1100
Blue Bell, PA 19422-0761

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: CertainTeed Modified Bitumen Roof System over Concrete Decks.

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews and revises NOA #13-0204.04 and consists of pages 1 through 48.
The submitted documentation was reviewed by Alex Tigera.

Alex Tigera 4/23/14



NOA No.: 14-0224.04
Expiration Date: 05/19/18
Approval Date: 04/10/14
Page 1 of 48

ROOFING SYSTEM APPROVAL

Category:	Roofing
Sub-Category:	Modified Bitumen
Material:	APP/SBS
Deck Type:	Concrete
Maximum Design Pressure:	-630 psf

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
All Weather/Empire Base Sheet	36" x 65' 10"; Roll weight: 86 lbs. (2 squares)	ASTM D 4601 Type II UL Type 15	Asphalt coated, fiberglass reinforced base sheet
Flex-I-Glas™ Base Sheet	36" x 98' 9"; Roll weight: 90 lbs. (3 squares)	ASTM D 4601, Type II UL Type G2	Modified Bitumen coated fiberglass base sheet.
Flex-I-Glas™ FR Base Sheet	39 3/8" x 50'; Roll weight: 90 lbs. (1.5 squares)	ASTM D 6163, Grade S, Type I	Modified Bitumen coated fiberglass base sheet.
Flintglas® Ply Sheet Type IV or VI	36" x 164' 7"; Roll weight: 40/55 lbs. (5 squares)	ASTM D 2178 Type IV or VI UL Type G1	Fiberglass, asphalt impregnated ply sheet.
Flintlastic STA	39 3/8" x 33'; Roll weight: 90 lbs. (1 square)	ASTM D 6222, Grade S, Type II	Smooth surfaced APP Modified Bitumen membrane with non-woven polyester mat reinforcement for torch application.
Flintlastic GTA, GTA-FR	39 3/8" x 33' 3"; Roll weight: 105 lbs. (1 square)	ASTM D 6222, Grade G, Type II	Granule surfaced APP Modified Bitumen membrane with non-woven polyester mat reinforcement for torch application.
Flintlastic GMS, GMS Premium	39 3/8" x 34' 2"; Roll weight: 100/105 lbs. (1 square)	ASTM D 6164, Grade G, Type II	Granule surfaced SBS Modified Bitumen membrane with non-woven polyester mat reinforcement for mop application.
Flintlastic FR, FR-P Premium	39 3/8" x 34' 2"; Roll weight: 105 lbs. (1 square)	ASTM D 6164, Grade G, Type I	Fire resistant, granule surfaced SBS Modified Bitumen Membrane with non-woven polyester mat reinforcement for mop application.
Flintlastic FR Cap Sheet	39 3/8" x 34' 2"; Roll weight: 90 lbs. (1 square)	ASTM D 6163, Grade G, Type I	Fire resistant, granule surfaced SBS Modified Bitumen membrane with fiberglass mat reinforcement for mop applications.



TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Flintlastic FR Cap T	39-3/8" x 34'2"; Roll weight: 81lbs. (1 square)	ASTM D6163	Granule surfaced SBS Modified Bitumen membrane with fiberglass mat reinforcement for torch application.
Flintlastic FR Base T	39-3/8" x 33'; Roll Weight: 81lbs. (1.0 squares)	ASTM D6163	Modified Bitumen, coated fiberglass base sheet for torch application.
Flintlastic FR Cap CoolStar	39 3/8" x 34' 2"; Roll weight: 90 lbs. (1 square)	ASTM D 6163	Fire resistant, granule surfaced SBS Modified Bitumen membrane with fiberglass mat reinforcement for mop applications. Covered with reflective CoolStar Coating.
Flintlastic FR Cap T CoolStar	39 3/8" x 34' 2"; Roll weight: 90 lbs. (1 square)	ASTM D 6163	Fire resistant, granule surfaced SBS Modified Bitumen membrane with fiberglass mat reinforcement for mop applications. Covered with reflective CoolStar Coating.
Flintlastic GTA, GTA-FR CoolStar	39 3/8" x 33' 3"; Roll weight: 105 lbs. (1 square)	ASTM D 6222	Granule surfaced APP Modified Bitumen membrane with non-woven polyester mat reinforcement for torch application. Covered with reflective CoolStar Coating.
Flintlastic GMS/GMS Premium CoolStar	39 3/8" x 34' 2"; Roll weight: 100/105 lbs. (1 square)	ASTM D 6164	Granule surfaced SBS Modified Bitumen membrane with non-woven polyester mat reinforcement for mop application. Covered with reflective CoolStar Coating.
Flintlastic FR-P/FR-P Premium CoolStar	39 3/8" x 34' 2"; Roll weight: 105 lbs. (1 square)	ASTM D 6164	Fire resistant, granule surfaced SBS Modified Bitumen Membrane with non-woven polyester mat reinforcement for mop application. Covered with reflective CoolStar Coating. Covered with reflective CoolStar Coating.
Ultra Poly SMS	36" x 64'4" (2 squares)	ASTM D 6164, Grade S, Type I	Smooth surfaced SBS Modified Bitumen Membrane with non-woven polyester mat reinforcement for mop applications.



GlasBase™ Base Sheet	36" x 98'9"; Roll weight: 69 lbs. (3 squares)	ASTM D 4601 UL Type G2	Asphalt coated, fiberglass base sheet.
PolySMS Base Sheet	39 3/8" x 64' 4"; Roll weight: 90 lbs. (2 squares)	ASTM D 4601, Grade S, Type II UL Type G2	Modified Bitumen coated polyester base sheet.
Yosemite® Buffer Base Sheet	36" x 32'10"; Roll weight: 90 lbs. (1 square)	ASTM D 3909 ASTM D 4897 UL Type 30	Mineral Surfaced fiberglass reinforced buffer sheet.
Black Diamond™ Base Sheet	36" x 68'7"; Roll weight: 78 lbs. (2 squares)	ASTM D 1970	Self-adhering fiberglass reinforced modified bitumen base sheet

APPROVED INSULATIONS:

TABLE 2

<u>Product Name</u>	<u>Product Description</u>	<u>Manufacturer (With Current NOA)</u>
FlintBoard ISO	Polyisocyanurate foam insulation	CertainTeed Corp.
ACFoam-II	Polyisocyanurate foam insulation	Atlas Roofing Corporation
High Density Wood Fiberboard	Wood fiber insulation board	Generic
Perlite Insulation	Perlite insulation board	Generic
H-Shield	Polyisocyanurate foam insulation	Hunter Panels LLC
DensDeck, DensDeck Prime	Water resistant gypsum board	Georgia Pacific Gypsum LLC
DensDeck DuraGuard Overlayment Board	Water resistant gypsum board	Georgia Pacific Gypsum LLC
ENRGY 3, ENRGY 3 25 PSI	Polyisocyanurate foam insulation	Johns Manville Corp.
FescoBoard	Expanded mineral fiber insulation	Johns Manville Corp.
SECUROCK Gypsum-Fiber Roof Board	Gypsum insulation	USG Corp.



APPROVED FASTENERS:

TABLE 3

<u>Fastener Number</u>	<u>Product Name</u>	<u>Product Description</u>	<u>Dimensions</u>	<u>Manufacturer (With Current NOA)</u>
1.	Dekfast 14 & Dekfast 15 HS	Insulation fastener for wood, steel and concrete decks		SFS Intec, Inc.
2.	Dekfast DekSpike	Insulation fastener for concrete decks		SFS Intec, Inc.
3.	Dekfast Galvalume Steel Hex Plate	Galvalume hex stress plate.	2 7/8" x 3 1/4"	SFS Intec, Inc.
4.	Dekfast Dekflat Round Lock Plate	Polypropylene locking plate.	3" x 3 1/4"	SFS Intec, Inc.
5.	UltraFast #14	Insulation fastener for concrete deck.		Johns Manville Corp.
6.	UltraFast ASAP	Pre-assembled Insulation fastener and plate		Johns Manville Corp.
7.	UltraFast Metal Plate	Galvalume AZ55 steel plate	3" round 3" square	Johns Manville Corp.
8.	OMG #14 Roofgrip	Insulation fastener		OMG, Inc.
9.	ASAP RoofGrip Pre-Assembled System	Pre-assembled Insulation fastener and plate		OMG, Inc.
10.	OMG 3 in. Round Metal Plates	Galvalume AZ50 steel plate	3" round	OMG, Inc.
11.	Dekfast System ES #14 Plastic	Pre-assembled Insulation fastener and plate		SFS Intec, Inc.
12.	Trufast #14 HD Fastener	Insulation fastener for wood and steel decks		Altenloh, Brinck & Co. U.S., Inc.
13.	Trufast 3" Metal Insulation Plate	Galvalume AZ50 steel plate	3" round	Altenloh, Brinck & Co. U.S., Inc.
14.	Trufast 2.4" Barbed Metal Seam Plates	Galvalume AZ50 steel plate	2.4" round	Altenloh, Brinck & Co. U.S., Inc.
15.	FlintFast #14	Insulation and membrane fastener	Various	CertainTeed Corp.
16.	FlintFast 3"	Galvalume AZ50 steel plate	3" round	CertainTeed Corp.
17.	Trufast #15 EHD Fastener	Coated carbon steel screw	Various	Altenloh, Brinck & Co. U.S., Inc.
18.	Trufast 2" Metal Seam Plate	Galvalume steel stress plate	2" round	Altenloh, Brinck & Co. U.S., Inc.



EVIDENCE SUBMITTED:

<u>Test Agency/Identifier</u>	<u>Name</u>	<u>Report</u>	<u>Date</u>	
Factory Mutual Research Corp.	FMRC 4470	J.I. 3Y8A1.AM	03/23/96	
	FMRC 4470	J.I. 0D3A3.AM	04/04/97	
	FMRC 4470	J.I. 2D0A0.AM	12/23/98	
	FMRC 4470	J.I. 1D7A4.AM	11/09/98	
Underwriters Laboratories, Inc.	UL 790	R11656	01/11/13	
United States Testing Company	ASTM D 5147	97457-4	06/03/88	
	ASTM D 5147	97-457-2R	12/02/87	
Momentum Technologies, Inc.	ASTM D 4601	AX31G8D	09/05/08	
	ASTM D6164	AX31G8F	06/05/09	
	ASTM D6222	AX31G8G	06/05/09	
	ASTM D 3909/ D 4897	AX31G8C	09/05/08	
Trinity ERD	TAS 114(J)	#3504.06.01-1	06/05/01	
	TAS 117 (B)	3503.10.06	10/10/06	
	TAS 117 (B)	O6490.04.07-R1	06/27/07	
	TAS 114 (H)	Letter	04/05/06	
	TAS 114	3533.01.06	01/06/06	
	TAS 114	3521.07.04	07/29/04	
	TAS 117 (B)/ ASTM D 6862	C8500SC.11.07	11/30/07	
	TAS 114	C8370.08.08	08/19/08	
	ASTM Physical Properties	C10080.09.08-R4	03/25/10	
	ASTM D6164/D4798	C31410.01.11-2	01/10/11	
	ASTM D4601	C40050.09.12-1	09/28/12	
	ASTM D1970	C40050.09.12-2	09/28/12	
	ASTM D5147/D4798	C31410.10.10-R1	11/01/12	
	ASTM D5147/D4798	C31410.01.11-1-R1	11/01/12	
	ASTM D4798	C31410.01.11-2A-R1	02/21/13	
	ASTM D4798	C31410.12.13	12/05/13	
	ASTM D6222	C40050.12.13	12/05/13	
	PRI Construction Materials Technologies LLC	ASTM D6163	CTC-032-02-01	01/22/08
		ASTM D6163	CTC-066-02-01	08/09/11
		ASTM D6164	CTC-068-02-01	08/09/11
ASTM D6222		CTC-070-02-01	08/09/11	
ASTM D6164/D4798		CTC-093-02-01	08/09/11	
ASTM D2178		CTC-122-02-01	03/13/12	
ASTM D2178		CTC-123-02-01	03/13/12	
ASTM D4601		CTC-127-02-01	03/13/12	
ASTM D6163		CTC-128-02-01	06/11/12	
ASTM D6163		CTC-129-02-01	06/11/12	
ASTM D6164		CTC-132-02-01	06/11/12	
ASTM D6164		CTC-162-02-01	05/09/13	
ASTM D6164		CTC-161-02-01	05/09/13	
ASTM D6162		CTC-183-02-01	10/02/13	
ASTM D6164	CTC-190-02-01	12/02/13		



APPROVED ASSEMBLIES

- Membrane Type:** APP Modified
- Deck Type 3I:** Concrete Decks, Insulated
- Deck Description:** 2500 psi structural concrete or concrete plank
- System Type A(1):** Anchor sheet (optional), insulation adhered with approved asphalt.

All General and System Limitations apply.

Anchor Sheet: (Optional) One ply of All Weather/Empire Base Sheet, Glas-Base, Flexiglas Base, Flexiglas FR Base, PolySMS, Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the primed concrete deck with approved mopping asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

One or more layers of any of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u> <u>Table 3</u>	<u>Fastener</u> <u>Density/ft²</u>
ACFoam-II, ENRGY 3, ENRGY 3 25 PSI, FlintBoard ISO, H-Shield Minimum 1.5” thick	N/A	N/A
Approved High Density Wood Fiberboard Minimum ½” thick	N/A	N/A
Approved Perlite Minimum ¾” thick	N/A	N/A
DensDeck, DensDeck Prime Minimum ¼” thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners</u> <u>Table 3</u>	<u>Fastener</u> <u>Density/ft²</u>
Approved High Density Wood Fiberboard Minimum ½” thick	N/A	N/A
Approved Perlite Minimum ¾” thick	N/A	N/A
DensDeck, DensDeck Prime Minimum ¼” thick	N/A	N/A

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of base sheet. All insulation shall be adhered to the anchor sheet in full mopping of approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.



- Base Sheet:** One ply of All Weather/Empire Base Sheet, Glas-Base, Flexiglas Base, Flexiglas FR Base, Poly SMS, Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the insulated substrate with approved mopping asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
- Ply Sheet:** (Optional) One ply of Ultra Poly SMS, Glas-Base, Flexiglas Base, Flexiglas FR Base, PolySMS or one or more plies of Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the base sheet in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or one ply of Black Diamond Base Sheet self adhered or Flintlastic STA torch adhered.
- Membrane:** Flintlastic GTA, Flintlastic GTA CoolStar, Flintlastic GTA-FR or GTA-FR CoolStar torch adhered to base/ply sheet.
- Surfacing:** (Optional) Any coating, listed below, used as a surfacing, must be listed within a current NOA. Install one of the following:
1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lb./sq..
 2. Karnak (#97 AF) Fibrated Aluminum Roof Coating, FlintCoat A-150, APOC #212 Fibrated Aluminum Roof Coating at an application rate of 1½ gal./sq., or APOC #400 Sunbrite at an application rate of 3 gal./sq..
- Maximum Design Pressure:**
- 87.5 psf (for top layer minimum $\frac{15}{16}$ " thick fiberglass applied in hot asphalt.) (See General Limitations #9)
 - 107.5 psf (for top layer minimum $\frac{3}{4}$ " thick Perlite applied in hot asphalt.) (See General Limitations #9)
 - 227 psf (for top layer minimum $\frac{1}{2}$ " thick High Density Wood Fiberboard applied in hot asphalt.) (See General Limitations #9)
 - 240 psf (for top layer minimum $\frac{1}{4}$ " thick Dens Deck applied in hot asphalt.) (See General Limitations #9)



Membrane Type: SBS Modified
Deck Type 3I: Concrete Decks, Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type A(2): Anchor sheet (optional), insulation adhered with approved asphalt.

All General and System Limitations apply.

Anchor Sheet: (Optional) One ply of All Weather/Empire Base Sheet, Glas-Base, Flexiglas Base, Flexiglas FR Base or PolySMS Base adhered to the primed concrete deck with approved mopping asphalt applied within the EVT range and at a rate of 20-40 lbs./sq..

One or more layers of any of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u> <u>Table 3</u>	<u>Fastener</u> <u>Density/ft²</u>
ACFoam-II, ENRGY 3, ENRGY 3 25 PSI, FlintBoard ISO, H-Shield Minimum 1.5” thick	N/A	N/A
Approved High Density Wood Fiberboard Minimum ½” thick	N/A	N/A
Approved Perlite Minimum ¾” thick	N/A	N/A
DensDeck, DensDeck Prime Minimum ¼” thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners</u> <u>Table 3</u>	<u>Fastener</u> <u>Density/ft²</u>
Approved High Density Wood Fiberboard Minimum ½” thick	N/A	N/A
Approved Perlite Minimum ¾” thick	N/A	N/A
DensDeck, DensDeck Prime Minimum ¼” thick	N/A	N/A

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of base sheet. All insulation shall be adhered to the anchor sheet in full mopping of approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.



- Base Sheet:** One ply of All Weather/Empire Base Sheet, Glas-Base, Flexiglas Base, Flexiglas FR Base, Poly SMS, Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the insulated substrate with approved mopping asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
- Ply Sheet:** (Optional) One ply of Ultra Poly SMS, Glas-Base, Flexiglas Base, Flexiglas FR Base, PolySMS or one or more plies of Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the base sheet in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or one ply of Black Diamond Base Sheet self adhered or Flintlastic STA torch adhered.
- Membrane:** One ply of Flintlastic GMS, Flintlastic GMS CoolStar, Flintlastic Premium GMS, Flintlastic Premium GMS CoolStar, Flintlastic FR-P, Flintlastic FR-P CoolStar, Flintlastic Premium FR-P, Flintlastic Premium FR-P CoolStar, Flintlastic FR Cap Sheet, Flintlastic FR Cap Sheet CoolStar adhered to ply sheet with approved mopping asphalt applied within the EVT range and at a rate of 20 to 40 lbs./sq. or Flintlastic FR Cap T or Flintlastic FR Cap T CoolStar torch adhered to ply sheet.
- Surfacing:** (Optional) Any coating, listed below, used as a surfacing, must be listed within a current NOA. Install one of the following:
1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lb./sq..
 2. Karnak (#97 AF) Fibrated Aluminum Roof Coating, FlintCoat A-150, APOC #212 Fibrated Aluminum Roof Coating at an application rate of 1½ gal./sq., or APOC #400 Sunbrite at an application rate of 3 gal./sq..
- Maximum Design Pressure:**
- 87.5 psf (for top layer minimum $\frac{15}{16}$ " thick fiberglass applied in hot asphalt.) (See General Limitations #9)
 - 107.5 psf (for top layer minimum $\frac{3}{4}$ " thick Perlite applied in hot asphalt.) (See General Limitations #9)
 - 227 psf (for top layer minimum $\frac{1}{2}$ " thick High Density Wood Fiberboard applied in hot asphalt.) (See General Limitations #9)
 - 240 psf (for top layer minimum $\frac{1}{4}$ " thick Dens Deck applied in hot asphalt.) (See General Limitations #9)



Membrane Type: APP Modified
Deck Type 3I: Concrete Decks, Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type A(3): Base sheet and insulation adhered with approved asphalt.

All General and System Limitations apply.

One or more layers of any of the following insulations:

<u>Insulation Layer</u>	<u>Insulation Fasteners</u> <u>Table 3</u>	<u>Fastener</u> <u>Density/ft²</u>
ENRGY 3, H-Shield Minimum 1.5" thick	N/A	N/A

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of base sheet. All insulation shall be adhered to the anchor sheet in full mopping of approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.

Base Sheet: One ply of All Weather/Empire Base Sheet, Glas-Base, Flexiglas Base, Flexiglas FR Base, Poly SMS, Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the composite insulation with approved mopping asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Ply Sheet: (Optional) One ply of Ultra Poly SMS, Glas-Base, Flexiglas Base, Flexiglas FR Base, PolySMS or one or more plies of Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the base sheet in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or one ply of Black Diamond Base Sheet self adhered or Flintlastic STA torch adhered.

Membrane: Flintlastic GTA, Flintlastic GTA CoolStar, Flintlastic GTA-FR or GTA-FR CoolStar torch adhered to base/ply sheet.

Surfacing: (Optional) Any coating, listed below, used as a surfacing, must be listed within a current NOA. Install one of the following:

1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lb./sq..
2. Karnak (#97 AF) Fibrated Aluminum Roof Coating, FlintCoat A-150, APOC #212 Fibrated Aluminum Roof Coating at an application rate of 1½ gal./sq., or APOC #400 Sunbrite at an application rate of 3 gal./sq..

Maximum Design Pressure: -355 psf (See General Limitations # 9)



Membrane Type: SBS Modified
Deck Type 3I: Concrete Decks, Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type A(4): Base sheet and insulation adhered with approved asphalt.

All General and System Limitations apply.

One or more layers of any of the following insulations:

<u>Insulation Layer</u>	<u>Insulation Fasteners Table 3</u>	<u>Fastener Density/ft²</u>
ENRGY 3, H-Shield Minimum 1.5" thick	N/A	N/A

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of base sheet. All insulation shall be adhered to the anchor sheet in full mopping of approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.

Base Sheet: One ply of All Weather/Empire Base Sheet, Glas-Base, Flexiglas Base, Flexiglas FR Base, Poly SMS, Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the composite insulation with approved mopping asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Ply Sheet: (Optional) One ply of Ultra Poly SMS, Glas-Base, Flexiglas Base, Flexiglas FR Base, PolySMS or one or more plies of Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the base sheet in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or one ply of Black Diamond Base Sheet (for use with a torched cap sheet only) self adhered.

Membrane: One ply of Flintlastic GMS, Flintlastic GMS CoolStar, Flintlastic Premium GMS, Flintlastic Premium GMS CoolStar, Flintlastic FR-P, Flintlastic FR-P CoolStar, Flintlastic Premium FR-P, Flintlastic Premium FR-P CoolStar, Flintlastic FR Cap Sheet, Flintlastic FR Cap Sheet CoolStar adhered to ply sheet with approved mopping asphalt applied within the EVT range and at a rate of 20 to 40 lbs./sq. or Flintlastic FR Cap T or Flintlastic FR Cap T CoolStar torch adhered to ply sheet.



Surfacing:

(Optional) Any coating, listed below, used as a surfacing, must be listed within a current NOA. Install one of the following:

1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lb./sq..
2. Karnak (#97 AF) Fibrated Aluminum Roof Coating, FlintCoat A-150, APOC #212 Fibrated Aluminum Roof Coating at an application rate of 1½ gal./sq., or APOC #400 Sunbrite at an application rate of 3 gal./sq..

Maximum Design

Pressure:

-355 psf (See General Limitations # 9)



Membrane Type: APP Modified
Deck Type 3I: Concrete Decks, Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type A(5): Base sheet and insulation adhered with approved asphalt.

All General and System limitations apply.

One or more layers of any of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u>	<u>Fastener Density/ft²</u>
ACFoam-II, H-Shield or FlintBoard ISO Minimum 1.5” thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners</u>	<u>Fastener Density/ft²</u>
DuraBoard Minimum 0.5” thick	N/A	N/A

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of base sheet. All insulation shall be adhered to the anchor sheet in full mopping of approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.

Base Sheet: One ply of All Weather/Empire Base Sheet, Glas-Base, Flexiglas Base, Flexiglas FR Base, Poly SMS, Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the insulated substrate with approved mopping asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Ply Sheet: (Optional) One ply of All Weather/Empire Base Sheet, Glas-Base, Flexiglas Base, Flexiglas FR Base, Poly SMS or one or more plies of Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the base sheet in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or one ply of Black Diamond Base Sheet self adhered or Flintlastic STA torch adhered.

Membrane: Flintlastic GTA, Flintlastic GTA CoolStar, Flintlastic GTA-FR or GTA-FR CoolStar torch adhered to base/ply sheet.

Maximum Design Pressure: -430 psf. (See General Limitation #9.)



Membrane Type: SBS Modified
Deck Type 3I: Concrete Decks, Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type A(6): Base sheet and insulation adhered with approved asphalt.

All General and System Limitations apply.

One or more layers of any of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u>	<u>Fastener Density/ft²</u>
ACFoam-II, H-Shield or FlintBoard ISO Minimum 1.5” thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners</u>	<u>Fastener Density/ft²</u>
DuraBoard Minimum 0.5” thick	N/A	N/A

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of base sheet. All insulation shall be adhered to the anchor sheet in full mopping of approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.

Base Sheet: One ply of All Weather/Empire Base Sheet, Glas-Base, Flexiglas Base, Flexiglas FR Base, Poly SMS, Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the insulated substrate with approved mopping asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Ply Sheet: (Optional) One ply of All Weather/Empire Base Sheet, Glas-Base, Flexiglas Base, Flexiglas FR Base, Poly SMS or one or more plies of Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the base sheet in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or one ply of Black Diamond Base Sheet (for use with a torched cap sheet only) self adhered.

Membrane: One ply of Flintlastic GMS, Flintlastic GMS CoolStar, Flintlastic Premium GMS, Flintlastic Premium GMS CoolStar, Flintlastic FR-P, Flintlastic FR-P CoolStar, Flintlastic Premium FR-P, Flintlastic Premium FR-P CoolStar, Flintlastic FR Cap Sheet, Flintlastic FR Cap Sheet CoolStar adhered to ply sheet with approved mopping asphalt applied within the EVT range and at a rate of 20 to 40 lbs./sq. or Flintlastic FR Cap T or Flintlastic FR Cap T CoolStar torch adhered to ply sheet.

Maximum Design Pressure: -430 psf. (See General Limitation #9)



Membrane Type: APP Modified
Deck Type 3I: Concrete Decks, Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type A(7): Base sheet and insulation adhered with approved asphalt.

All General and System limitations apply.

One or more layers of any of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u>	<u>Fastener Density/ft²</u>
ACFoam-II, H-Shield or FlintBoard ISO Minimum 1.5” thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners	Fastener Density/ft²
FescoBoard Minimum 0.75” thick	N/A	N/A

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of base sheet. All insulation shall be adhered to the anchor sheet in full mopping of approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.

Base Sheet: One ply of All Weather/Empire Base Sheet, Glas-Base, Flexiglas Base, Flexiglas FR Base, Poly SMS, Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the insulated substrate with approved mopping asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Ply Sheet: (Optional) One ply of All Weather/Empire Base Sheet, Glas-Base, Flexiglas Base, Flexiglas FR Base, Poly SMS or one or more plies of Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the base sheet in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or one ply of Black Diamond Base Sheet self adhered or Flintlastic STA torch adhered.

Membrane: Flintlastic GTA, Flintlastic GTA CoolStar, Flintlastic GTA-FR or GTA-FR CoolStar torch adhered to base/ply sheet.

Maximum Design Pressure: -412 psf. (See General Limitation #9.)



Membrane Type: SBS Modified
Deck Type 3I: Concrete Decks, Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type A(8): Base sheet and insulation adhered with approved asphalt.

All General and System Limitations apply.

One or more layers of any of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u>	<u>Fastener Density/ft²</u>
ACFoam-II, H-Shield or FlintBoard ISO Minimum 1.5” thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners</u>	<u>Fastener Density/ft²</u>
FescoBoard Minimum 0.75” thick	N/A	N/A

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of base sheet. All insulation shall be adhered to the anchor sheet in full mopping of approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.

Base Sheet: One ply of All Weather/Empire Base Sheet, Glas-Base, Flexiglas Base, Flexiglas FR Base, Poly SMS, Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the insulated substrate with approved mopping asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Ply Sheet: (Optional) One ply of All Weather/Empire Base Sheet, Glas-Base, Flexiglas Base, Flexiglas FR Base, Poly SMS or one or more plies of Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the base sheet in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or one ply of Black Diamond Base Sheet (for use with a torched cap sheet only) self adhered.

Membrane: One ply of Flintlastic GMS, Flintlastic GMS CoolStar, Flintlastic Premium GMS, Flintlastic Premium GMS CoolStar, Flintlastic FR-P, Flintlastic FR-P CoolStar, Flintlastic Premium FR-P, Flintlastic Premium FR-P CoolStar, Flintlastic FR Cap Sheet, Flintlastic FR Cap Sheet CoolStar adhered to ply sheet with approved mopping asphalt applied within the EVT range and at a rate of 20 to 40 lbs./sq. or Flintlastic FR Cap T or Flintlastic FR Cap T CoolStar torch adhered to ply sheet.

Maximum Design Pressure: -412 psf. (See General Limitation #9)



Membrane Type: SBS Modified
Deck Type 3I: Concrete, Insulated
Deck Description: Min. 2,500 psi structural concrete or concrete plank.
System Type A(9): One or more layers of insulation adhered with approved asphalt.

All General and System Limitations apply.

One or more layers of any of the following insulations.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ACFoam-II, FlintBoard ISO, H-Shield Minimum 1.5” thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
DensDeck, DensDeck Prime, DensDeck DuraGuard Overlayment Board, SECUROCK Gypsum-Fiber Roof Board Minimum ¼” thick	N/A	N/A

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of insulation. All insulation shall be adhered to the deck in full mopping of approved hot asphalt within the EVT range and at a rate of 25 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Base Sheet: One or more layers of Flintlastic FR Base T, torch applied
Ply Sheet: (Optional) Flintlastic FR Base T, torch applied.
Membrane: Flintlastic FR Cap T, Flintlastic FR Cap T CoolStar, torch applied.
Maximum Design Pressure: -180 psf (See General Limitation # 9)



Membrane Type: SBS Modified
Deck Type 3I: Concrete, Insulated
Deck Description: Min. 2,500 psi structural concrete or concrete plank.
System Type A(10): One or more layers of insulation adhered with approved asphalt.

All General and System Limitations apply.

One or more layers of any of the following insulations.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ACFoam-II, FlintBoard ISO, H-Shield Minimum 1.5” thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
DensDeck Minimum ¼” thick	N/A	N/A

Note: All insulation shall be adhered to the deck in 3/4” – 1” wide beads of Insta-Stik or Millennium One Step Foamable Insulation Adhesive, spaced 12” o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Base Sheet: One or more layers of Flintlastic FR Base T, torch applied
Ply Sheet: (Optional) Flintlastic FR Base T, torch applied.
Membrane: Flintlastic FR Cap T, Flintlastic FR Cap T CoolStar, torch applied.
Maximum Design Pressure: -112.5 psf (with Insta-Stik) (See General Limitation # 9)
-180 psf (with Millennium One Step Foamable Insulation Adhesive) (See General Limitation # 9)



Membrane Type: SBS Modified
Deck Type 3I: Concrete, Insulated
Deck Description: Min. 2,500 psi structural concrete or concrete plank.
System Type A(11): One or more layers of insulation adhered with approved asphalt.

All General and System Limitations apply.

One or more layers of any of the following insulations.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ACFoam-II, FlintBoard ISO, H-Shield Minimum 1.5” thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
SECUROCK Gypsum-Fiber Roof Board Minimum ¼” thick	N/A	N/A

Note: All insulation shall be adhered to the deck in 3/4” – 1” wide beads of Insta-Stik or Millenium Pourable Foam Insulation Adhesive or 1” wide ribbons of OlyBond 500 or SpotShot, spaced 12” o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Base Sheet: One or more layers of Flintlastic FR Base T, torch applied.
Ply Sheet: (Optional) Flintlastic FR Base T, torch applied.
Membrane: Flintlastic FR Cap T, Flintlastic FR Cap T CoolStar, torch applied.
Maximum Design Pressure: -180 psf (See General Limitation # 9)



Membrane Type: SBS Modified
Deck Type 3I: Concrete, Insulated
Deck Description: Min. 2,500 psi structural concrete or concrete plank.
System Type A(12): One or more layers of insulation adhered with approved asphalt.

All General and System Limitations apply.

One or more layers of any of the following insulations.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ACFoam-II, FlintBoard ISO, H-Shield Minimum 1.5" thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
SECUROCK Gypsum-Fiber Roof Board, DensDeck Minimum ¼" thick	N/A	N/A

Note: All insulation shall be adhered to the deck in ½" – ¾" wide beads of Millenium One Step Foamable Adhesive or in full coverage of OlyBond Adhesive Fastener applied at a rate of 1 gal/sq. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Base Sheet: One or more layers of Flintlastic FR Base T, torch applied
Ply Sheet: (Optional) Flintlastic FR Base T, torch applied.
Membrane: Flintlastic FR Cap T, Flintlastic FR Cap T CoolStar, torch applied.
Maximum Design Pressure: -180 psf (See General Limitation # 9)



Membrane Type: SBS Modified
Deck Type 3I: Concrete, Insulated
Deck Description: Min. 2,500 psi structural concrete or concrete plank.
System Type A(13): One or more layers of insulation adhered with approved asphalt.

All General and System Limitations apply.

One or more layers of any of the following insulations.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ACFoam-II, FlintBoard ISO, H-Shield Minimum 1.5" thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
DensDeck, DensDeck Prime Minimum ¼" thick	N/A	N/A

Note: All insulation shall be adhered to the deck in 1" wide ribbons of OlyBond 500 or SpotShot, spaced 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Base Sheet: One or more layers of Flintlastic FR Base T, torch applied
Ply Sheet: (Optional) Flintlastic FR Base T, torch applied.
Membrane: Flintlastic FR Cap T, Flintlastic FR Cap T CoolStar, torch applied.
Maximum Design Pressure: -150 psf (See General Limitation # 9)



Membrane Type: SBS Modified
Deck Type 3I: Concrete, Insulated
Deck Description: Min. 2,500 psi structural concrete or concrete plank.
System Type A(14): One or more layers of insulation adhered with approved asphalt.

All General and System Limitations apply.

One or more layers of any of the following insulations.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ACFoam-II, FlintBoard ISO, H-Shield Minimum 1.5" thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
DensDeck, DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board Minimum ¼" thick	N/A	N/A

Note: All insulation shall be adhered to the deck in 3" – 3.5" wide ribbons of Tite-Set Roofing Adhesive or 3M Polyurethane Foam Insulation Adhesive CR-20, spaced 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Base Sheet: One or more layers of Flintlastic FR Base T, torch applied.
Ply Sheet: (Optional) Flintlastic FR Base T, torch applied.
Membrane: Flintlastic FR Cap T, Flintlastic FR Cap T CoolStar, torch applied.
Maximum Design Pressure: -180 psf (See General Limitation # 9)



Membrane Type: APP Modified
Deck Type 3I: Concrete Decks, Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type B(1): Base layer of insulation mechanically fastened, optional top layer adhered with approved asphalt.

All General and System Limitations apply.

One or more layers of any of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u> <u>Table 3</u>	<u>Fastener</u> <u>Density/ft²</u>
ENRGY 3, ENRGY 3 25 PSI		
Minimum 1.4" thick	1, 8 or 12	1:2 ft ²
Minimum 2" thick	1, 8, or 12	1:3.2 ft ²
ACFoam-II, FlintBoard ISO, H-Shield		
Minimum 1.5" thick	1, 8 or 12	1:2 ft ²
Minimum 2" thick	1, 8, or 12	1:3.2 ft ²
Approved Perlite		
Minimum ¾" thick	1, 8, or 12	1:2 ft ²
Approved High Density Wood Fiberboard		
Minimum ½" thick	1, 8, or 12	1:2 ft ²
DensDeck, DensDeck Prime		
Minimum ½" thick	1, 8 or 12	1:2 ft ²

Note: Base layer shall be mechanically attached with fasteners and density described above. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

<u>Top Insulation Layer (Optional)</u>	<u>Insulation Fasteners</u> <u>Table 3</u>	<u>Fastener</u> <u>Density/ft²</u>
--	---	--

Any of the insulations listed for Base Layer, above.

Note: Optional top layer of insulation shall be adhered with approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Composite insulation boards used as a top layer shall be installed with the polyisocyanurate face down.

Base Sheet: One ply of All Weather/Empire Base Sheet, Glas-Base, Flexiglas Base, Flexiglas FR Base, Poly SMS, Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the composite insulation with approved mopping asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.



Ply Sheet: (Optional) One ply of All Weather/Empire Base Sheet, Ultra Poly SMS, Glas-Base, Flexiglas Base, Flexiglas FR Base, PolySMS or one or more plies of Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the base sheet in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or one ply of Black Diamond Base Sheet self adhered or Flintlastic STA torch adhered.

Membrane: Flintlastic GTA, Flintlastic GTA CoolStar, Flintlastic GTA-FR or GTA-FR CoolStar torch adhered to base/ply sheet.

Surfacing: (Optional) Any coating, listed below, used as a surfacing, must be listed within a current NOA. Install one of the following:

1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lb./sq..
2. Karnak (#97 AF) Fibrated Aluminum Roof Coating, FlintCoat A-150, APOC #212 Fibrated Aluminum Roof Coating at an application rate of 1½ gal./sq., or APOC #400 Sunbrite at an application rate of 3 gal./sq..

Maximum Design Pressure: -52.5 psf (See General Limitations # 9)



Membrane Type: SBS Modified
Deck Type 3I: Concrete, Insulated
Deck Description: Min. 2,500 psi structural concrete or concrete plank.
System Type B(2): Base layer of insulation mechanically fastened, optional top layer adhered with approved asphalt.

All General and System Limitations apply.

One or more layers of any of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u> <u>Table 3</u>	<u>Fastener</u> <u>Density/ft²</u>
ENRGY 3, ENRGY 3 25 PSI		
Minimum 1.4" thick	1, 8 or 12	1:2 ft²
Minimum 2" thick	1, 8, or 12	1:3.2 ft²
ACFoam-II, FlintBoard ISO, H-Shield		
Minimum 1.5" thick	1, 8 or 12	1:2 ft²
Minimum 2" thick	1, 8, or 12	1:3.2 ft²
Approved Perlite		
Minimum ¾" thick	1, 8, or 12	1:2 ft²
Approved High Density Wood Fiberboard		
Minimum ½" thick	1, 8, or 12	1:2 ft²
DensDeck, DensDeck Prime		
Minimum ½" thick	1, 8, or 12	1:2 ft²

Note: Base layer shall be mechanically attached with fasteners and density described above. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

<u>Top Insulation Layer (Optional)</u>	<u>Insulation Fasteners</u> <u>Table 3</u>	<u>Fastener</u> <u>Density/ft²</u>
--	---	--

Any of the insulations listed for Base Layer, above.

Note: Optional top layer of insulation shall be adhered with approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Composite insulation boards used as a top layer shall be installed with the polyisocyanurate face down.

Base Sheet: One ply of All Weather/Empire Base Sheet, Glas-Base, Flexiglas Base, Flexiglas FR Base, Poly SMS, Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the insulated substrate with approved mopping asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.



Ply Sheet: (Optional) One ply of All Weather/Empire Base Sheet, Ultra Poly SMS, Glas-Base, Flexiglas Base, Flexiglas FR Base, PolySMS or one or more plies of Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the base sheet in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or one ply of Black Diamond Base Sheet (for use with a torched cap sheet only) self adhered.

Membrane: One ply of Flintlastic GMS, Flintlastic GMS CoolStar, Flintlastic Premium GMS, Flintlastic Premium GMS CoolStar, Flintlastic FR-P, Flintlastic FR-P CoolStar, Flintlastic Premium FR-P, Flintlastic Premium FR-P CoolStar, Flintlastic FR Cap Sheet, Flintlastic FR Cap Sheet CoolStar adhered to ply sheet with approved mopping asphalt applied within the EVT range and at a rate of 20 to 40 lbs./sq. or Flintlastic FR Cap T or Flintlastic FR Cap T CoolStar torch adhered to ply sheet.

Surfacing: (Optional) Any coating, listed below, used as a surfacing, must be listed within a current NOA. Install one of the following:

1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lb./sq..
2. Karnak (#97 AF) Fibrated Aluminum Roof Coating, FlintCoat A-150, APOC #212 Fibrated Aluminum Roof Coating at an application rate of 1½ gal./sq., or APOC #400 Sunbrite at an application rate of 3 gal./sq..

Maximum Design Pressure: -52.5 psf (See General Limitations #9)



Membrane Type: APP Modified
Deck Type 3I: Concrete Decks, Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type B(3): Base layer of insulation mechanically fastened, optional top layer adhered with approved asphalt.

All General and System Limitations apply.

One or more layers of any of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ACFoam-II, ENRGY 3, Multi-Max FA-3, FlintBoard ISO, H-Shield Minimum 1.5" thick	1, 5, 8 or 12	1:1.33

Note: Base layer shall be mechanically attached with fasteners and density described. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
FescoBoard Minimum 3/4" thick	N/A	N/A
Approved High Density Wood Fiberboard Minimum 1/2" thick	N/A	N/A

Note: Top layer of insulation shall be adhered with approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Composite insulation boards used as a top layer shall be installed with the polyisocyanurate face down.

Base Sheet: One ply of All Weather/Empire Base Sheet, Glas-Base, Flexiglas Base, Flexiglas FR Base, Poly SMS, Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the composite insulation with approved mopping asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Ply Sheet: (Optional) One ply of All Weather/Empire Base Sheet, Ultra Poly SMS, Glas-Base, Flexiglas Base, Flexiglas FR Base, PolySMS or one or more plies of Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the base sheet in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or one ply of Black Diamond Base Sheet self adhered or Flintlastic STA torch adhered.

Membrane: Flintlastic GTA, Flintlastic GTA CoolStar, Flintlastic GTA-FR or GTA-FR CoolStar torch adhered to base/ply sheet.



Surfacing:

(Optional) Any coating, listed below, used as a surfacing, must be listed within a current NOA. Install one of the following:

1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lb./sq..
2. Karnak (#97 AF) Fibrated Aluminum Roof Coating, FlintCoat A-150, APOC #212 Fibrated Aluminum Roof Coating at an application rate of 1½ gal./sq., or APOC #400 Sunbrite at an application rate of 3 gal./sq..

Maximum Design Pressure:

-52.5 psf (For FescoBoard) (See General Limitation #7)

-67.5 psf (For High Density Wood Fiberboard) (See General Limitation #7)



Membrane Type: SBS Modified
Deck Type 3I: Concrete, Insulated
Deck Description: Min. 2,500 psi structural concrete or concrete plank.
System Type B(4): Base layer of insulation mechanically fastened, top layer adhered with approved asphalt.

All General and System Limitations apply.

One or more layers of any of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ACFoam-II, ENRGY 3, Multi-Max FA-3, FlintBoard ISO, H-Shield Minimum 1.5" thick	1, 5, 8 or 12	1:1.33

Note: Base layer shall be mechanically attached with fasteners and density described. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
FescoBoard Minimum 3/4" thick	N/A	N/A
Approved High Density Wood Fiberboard Minimum 1/2" thick	N/A	N/A

Note: Top layer of insulation shall be adhered with approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Composite insulation boards used as a top layer shall be installed with the polyisocyanurate face down.

Base Sheet: One ply of All Weather/Empire Base Sheet, Glas-Base, Flexiglas Base, Flexiglas FR Base, Poly SMS, Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the insulated substrate with approved mopping asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Ply Sheet: (Optional) One ply of All Weather/Empire Base Sheet, Ultra Poly SMS, Glas-Base, Flexiglas Base, Flexiglas FR Base, PolySMS or one or more plies of Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the base sheet in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or one ply of Black Diamond Base Sheet (for use with a torched cap sheet only) self adhered.



Membrane: One ply of Flintlastic GMS, Flintlastic GMS CoolStar, Flintlastic Premium GMS, Flintlastic Premium GMS CoolStar, Flintlastic FR-P, Flintlastic FR-P CoolStar, Flintlastic Premium FR-P, Flintlastic Premium FR-P CoolStar, Flintlastic FR Cap Sheet, Flintlastic FR Cap Sheet CoolStar adhered to ply sheet with approved mopping asphalt applied within the EVT range and at a rate of 20 to 40 lbs./sq. or Flintlastic FR Cap T or Flintlastic FR Cap T CoolStar torch adhered to ply sheet.

Surfacing: (Optional) Any coating, listed below, used as a surfacing, must be listed within a current NOA. Install one of the following:

1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lb./sq..
2. Karnak (#97 AF) Fibrated Aluminum Roof Coating, FlintCoat A-150, APOC #212 Fibrated Aluminum Roof Coating at an application rate of 1½ gal./sq., or APOC #400 Sunbrite at an application rate of 3 gal./sq..

Maximum Design Pressure: -52.5 psf (For FescoBoard) (See General Limitation #7)
-67.5 psf (For High Density Wood Fiberboard) (See General Limitation #7)



Membrane Type: APP Modified
Deck Type 3I: Concrete Decks, Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type C(1): All layers of insulation simultaneously fastened.

All General and System Limitations apply.

One or more layers of any of the following insulations:

<u>Base Insulation Layer (Optional)</u>	<u>Insulation Fasteners</u> <u>Table 3</u>	<u>Fastener</u> <u>Density/ft²</u>
ENRGY 3, ENRGY 3 25 PSI, ACFoam-II, FlintBoard ISO, H-Shield Minimum 1.5” thick	N/A	N/A
Approved Perlite Minimum ¾” thick	N/A	N/A
Approved High Density Wood Fiberboard Minimum ½” thick	N/A	N/A
DensDeck, DensDeck Prime Minimum ¼” thick	N/A	N/A

Note: All layers shall be simultaneously fastened; see top layer below for fasteners and density.

<u>Top Insulation Layer</u>	<u>Insulation Fasteners</u> <u>Table 3</u>	<u>Fastener</u> <u>Density/ft²</u>
Approved Perlite Minimum ¾” thick	1, 8, 12 or 15	1:2 ft ²
Approved High Density Wood Fiberboard Minimum ½” thick	1, 8, 12 or 15	1:2 ft ²
DensDeck, DensDeck Prime Minimum ½” thick	1, 8, 12 or 15	1:2 ft ²

Note: All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density.

Base Sheet: One ply of All Weather/Empire Base Sheet, Glas-Base, Flexiglas Base, Flexiglas FR Base, Poly SMS, Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the composite insulation with approved mopping asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.



Ply Sheet: (Optional) One ply of All Weather/Empire Base Sheet, Ultra Poly SMS, Glas-Base, Flexiglas Base, Flexiglas FR Base, PolySMS or one or more plies of Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the base sheet in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or one ply of Black Diamond Base Sheet self adhered or Flintlastic STA torch adhered.

Membrane: Flintlastic GTA, Flintlastic GTA CoolStar, Flintlastic GTA-FR or GTA-FR CoolStar torch adhered to base/ply sheet.

Surfacing: (Optional) Any coating, listed below, used as a surfacing, must be listed within a current NOA. Install one of the following:

1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lb./sq..
2. Karnak (#97 AF) Fibrated Aluminum Roof Coating, FlintCoat A-150, APOC #212 Fibrated Aluminum Roof Coating at an application rate of 1½ gal./sq., or APOC #400 Sunbrite at an application rate of 3 gal./sq..

Maximum Design Pressure: -52.5 psf (See General Limitations #9)



Membrane Type: SBS Modified
Deck Type 3I: Concrete Decks, Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type C(2): All layers of insulation simultaneously fastened.

All General and System Limitations apply.

One or more layers of any of the following insulations:

<u>Base Insulation Layer (Optional)</u>	<u>Insulation Fasteners Table 3</u>	<u>Fastener Density/ft²</u>
ENRGY 3, ENRGY 3 25 PSI, ACFoam-II, FlintBoard ISO, H-Shield Minimum 1.5” thick	N/A	N/A
Approved Perlite Minimum ¾” thick	N/A	N/A
Approved High Density Wood Fiberboard Minimum ½” thick	N/A	N/A
DensDeck, DensDeck Prime Minimum ¼” thick	N/A	N/A

Note: All layers shall be simultaneously fastened; see top layer below for fasteners and density.

<u>Top Insulation Layer</u>	<u>Insulation Fasteners Table 3</u>	<u>Fastener Density/ft²</u>
Approved Perlite Minimum ¾” thick	1, 8, 12 or 15	1:2 ft ²
Approved High Density Wood Fiberboard Minimum ½” thick	1, 8, 12 or 15	1:2 ft ²
DensDeck, DensDeck Prime Minimum ½” thick	1, 8, 12 or 15	1:2 ft ²

Note: All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density.

Base Sheet: One ply of All Weather/Empire Base Sheet, Glas-Base, Flexiglas Base, Flexiglas FR Base, Poly SMS, Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the insulated substrate with approved mopping asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.



Ply Sheet: (Optional) One ply of All Weather/Empire Base Sheet, Ultra Poly SMS, Glas-Base, Flexiglas Base, Flexiglas FR Base, PolySMS or one or more plies of Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the base sheet in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or one ply of Black Diamond Base Sheet (for use with a torched cap sheet only) self adhered.

Membrane: One ply of Flintlastic GMS, Flintlastic GMS CoolStar, Flintlastic Premium GMS, Flintlastic Premium GMS CoolStar, Flintlastic FR-P, Flintlastic FR-P CoolStar, Flintlastic Premium FR-P, Flintlastic Premium FR-P CoolStar, Flintlastic FR Cap Sheet, Flintlastic FR Cap Sheet CoolStar adhered to ply sheet with approved mopping asphalt applied within the EVT range and at a rate of 20 to 40 lbs./sq. or Flintlastic FR Cap T or Flintlastic FR Cap T CoolStar torch adhered to ply sheet.

Surfacing: (Optional) Any coating, listed below, used as a surfacing, must be listed within a current NOA. Install one of the following:

1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lb./sq..
2. Karnak (#97 AF) Fibrated Aluminum Roof Coating, FlintCoat A-150, APOC #212 Fibrated Aluminum Roof Coating at an application rate of 1½ gal./sq., or APOC #400 Sunbrite at an application rate of 3 gal./sq..

Maximum Design Pressure: -52.5 psf (See General Limitations #9)



Membrane Type: APP Modified
Deck Type 3I: Concrete Decks, Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type C(3): All layers of insulation simultaneously fastened.

All General and System Limitations apply.

One or more layers of any of the following insulations:

<u>Insulation Layer</u>	<u>Insulation Fasteners</u> <u>Table 3</u>	<u>Fastener</u> <u>Density/ft²</u>
ENRGY 3, ENRGY 3 25 PSI, ACfoam-II, Multi-Max FA-3, FlintBoard ISO, H-Shield Minimum 1.5" thick	1, 8 or 12	1:1.33 ft ²

Note: All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: One ply of Black Diamond Base Sheet self-adhered.

Ply Sheet: ((Optional) One ply of All Weather/Empire Base Sheet, Ultra Poly SMS, Glas-Base, Flexiglas Base, Flexiglas FR Base, PolySMS or one or more plies of Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the base sheet in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or one ply of Black Diamond Base Sheet self adhered or Flintlastic STA torch adhered.

Membrane: Flintlastic GTA, Flintlastic GTA CoolStar, Flintlastic GTA-FR or GTA-FR CoolStar torch adhered to base/ply sheet.

Surfacing: (Optional) Any coating, listed below, used as a surfacing, must be listed within a current NOA. Install one of the following:
 1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lb./sq..
 2. Karnak (#97 AF) Fibrated Aluminum Roof Coating, FlintCoat A-150, APOC #212 Fibrated Aluminum Roof Coating at an application rate of 1½ gal./sq., or APOC #400 Sunbrite at an application rate of 3 gal./sq..

Maximum Design Pressure: -82.5 psf (See General Limitations #7)



Membrane Type: SBS Modified
Deck Type 3I: Concrete Decks, Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type C(4): All layers of insulation simultaneously fastened.

All General and System Limitations apply.

One or more layers of any of the following insulations:

<u>Insulation Layer</u>	<u>Insulation Fasteners</u> <u>Table 3</u>	<u>Fastener</u> <u>Density/ft²</u>
ENRGY 3, ENRGY 3 25 PSI, ACFoam-II, Multi-Max FA-3, FlintBoard ISO, H-Shield Minimum 1.5" thick	1, 8 or 12	1:1.33 ft ²

Note: All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: One ply of Black Diamond Base Sheet self-adhered.

Ply Sheet: (Optional) One ply of All Weather/Empire Base Sheet, Ultra Poly SMS, Glas-Base, Flexiglas Base, Flexiglas FR Base, PolySMS or one or more plies of Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the base sheet in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or one ply of Black Diamond Base Sheet (for use with a torched cap sheet only) self adhered.

Membrane: One ply of Flintlastic GMS, Flintlastic GMS CoolStar, Flintlastic Premium GMS, Flintlastic Premium GMS CoolStar, Flintlastic FR-P, Flintlastic FR-P CoolStar, Flintlastic Premium FR-P, Flintlastic Premium FR-P CoolStar, Flintlastic FR Cap Sheet, Flintlastic FR Cap Sheet CoolStar adhered to ply sheet with approved mopping asphalt applied within the EVT range and at a rate of 20 to 40 lbs./sq. or Flintlastic FR Cap T or Flintlastic FR Cap T CoolStar torch adhered to ply sheet.

Surfacing: (Optional) Any coating, listed below, used as a surfacing, must be listed within a current NOA. Install one of the following:

1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lb./sq..
2. Karnak (#97 AF) Fibrated Aluminum Roof Coating, FlintCoat A-150, APOC #212 Fibrated Aluminum Roof Coating at an application rate of 1½ gal./sq., or APOC #400 Sunbrite at an application rate of 3 gal./sq..

Maximum Design Pressure: -52.5 psf (See General Limitations #7)



Membrane Type: APP Modified
Deck Type 3I: Concrete Decks, Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type D(1): All layers of insulation and base sheet simultaneously attached.

All General and System Limitations apply.

One or more layers of any of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners Table 3</u>	<u>Fastener Density/ft²</u>
ACFoam-II, ENRGY 3, ENRGY 3 25 PSI, FlintBoard ISO, H-Shield Minimum 1.5" thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners Table 3</u>	<u>Fastener Density/ft²</u>
Approved Perlite Minimum ¾" thick	N/A	N/A
Approved High Density Wood Fiberboard Minimum ½" thick	N/A	N/A
DensDeck, DensDeck Prime Minimum ¼" thick	N/A	N/A

Note: Top layer shall have preliminary attachment, prior to the installation of the base/anchor sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.

Base Sheet: One ply of All Weather/Empire Base Sheet, Flexiglas Base, Flexiglas FR Base, SBS FR, Poly SMS or Ultra Poly SMS Base Sheet mechanically attached as detailed in Fastening #1 below or one ply of Poly SMS or Ultra Poly SMS Base Sheet mechanically attached as detailed in Fastening #2 below.

Fastening #1: OMG #14 Roofgrip and OMG 3 in. Round Metal Plates, Dekfast #14 and Dekfast Galvalume Steel Hex Plates, Trufast #14 HD Fastener and Trufast 3" Metal Insulation Plates or FlintFast #14 screws and FlintFast 3" plates at a 4" side lap 6" o.c. and two rows staggered in the center of the sheet, 6" o.c.
(Maximum Design Pressure -67.5 psf; See General Limitation #7)

Fastening #2: OMG #14 Roofgrip and OMG 3 in. Round Metal Plates, Dekfast #14 and Dekfast Galvalume Steel Hex Plates, Trufast #14 HD Fastener and Trufast 3" Metal Insulation Plates or FlintFast#14 screws and FlintFast 3" plates at a 4" side lap 12" o.c. and two rows staggered in the center of the sheet, 12" o.c.
(Maximum Design Pressure -120 psf; See General Limitation #7)



Ply Sheet: (Optional) One ply of All Weather/Empire Base Sheet, Ultra Poly SMS, Glas-Base, Flexiglas Base, Flexiglas FR Base, PolySMS or one or more plies of Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the base sheet in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or one ply of Black Diamond Base Sheet self adhered or Flintlastic STA torch adhered.

Membrane: Flintlastic GTA, Flintlastic GTA CoolStar, Flintlastic GTA-FR or GTA-FR CoolStar torch adhered to base/ply sheet.

Surfacing: (Optional) Any coating, listed below, used as a surfacing, must be listed within a current NOA. Install one of the following:

1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lb./sq..
2. Karnak (#97 AF) Fibrated Aluminum Roof Coating, FlintCoat A-150, APOC #212 Fibrated Aluminum Roof Coating at an application rate of 1½ gal./sq., or APOC #400 Sunbrite at an application rate of 3 gal./sq..

Maximum Design Pressure: See Fastening Options Above



Membrane Type: SBS Modified
Deck Type 3I: Concrete Decks, Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type D(2): All layers of insulation and base sheet simultaneously attached.

All General and System Limitations apply.

One or more layers of any of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners Table 3</u>	<u>Fastener Density/ft²</u>
ACFoam-II, ENRGY 3, ENRGY 3 25 PSI, FlintBoard ISO, H-Shield Minimum 1.5" thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners Table 3</u>	<u>Fastener Density/ft²</u>
Approved Perlite Minimum 3/4" thick	N/A	N/A
Approved High Density Wood Fiberboard Minimum 1/2" thick	N/A	N/A
DensDeck, DensDeck Prime Minimum 1/4" thick	N/A	N/A

Note: Top layer shall have preliminary attachment, prior to the installation of the base/anchor sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.

Base Sheet: One ply of All Weather/Empire Base Sheet, Flexiglas Base, Flexiglas FR Base, SBS FR, Poly SMS or Ultra Poly SMS Base Sheet mechanically attached as detailed in Fastening #1 below or one ply of Poly SMS or Ultra Poly SMS Base Sheet mechanically attached as detailed in Fastening #2 below.

Fastening #1: OMG #14 Roofgrip and OMG 3 in. Round Metal Plates, Dekfast #14 and Dekfast Galvalume Steel Hex Plates, Trufast #14 HD Fastener and Trufast 3" Metal Insulation Plates or FlintFast #14 screws and FlintFast 3" plates at a 4" side lap 6" o.c. and two rows staggered in the center of the sheet, 6" o.c.
(Maximum Design Pressure -67.5 psf; See General Limitation #7)

Fastening #2: OMG #14 Roofgrip and OMG 3 in. Round Metal Plates, Dekfast #14 and Dekfast Galvalume Steel Hex Plates, Trufast #14 HD Fastener and Trufast 3" Metal Insulation Plates or FlintFast#14 screws and FlintFast 3" plates at a 4" side lap 12" o.c. and two rows staggered in the center of the sheet, 12" o.c.
(Maximum Design Pressure -120 psf; See General Limitation #7)



Ply Sheet: (Optional) One ply of All Weather/Empire Base Sheet, Ultra Poly SMS, Glas-Base, Flexiglas Base, Flexiglas FR Base, PolySMS or one or more plies of Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the base sheet in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or one ply of Black Diamond Base Sheet (for use with a torched cap sheet only) self adhered.

Membrane: One ply of Flintlastic GMS, Flintlastic GMS CoolStar, Flintlastic Premium GMS, Flintlastic Premium GMS CoolStar, Flintlastic FR-P, Flintlastic FR-P CoolStar, Flintlastic Premium FR-P, Flintlastic Premium FR-P CoolStar, Flintlastic FR Cap Sheet, Flintlastic FR Cap Sheet CoolStar adhered to ply sheet with approved mopping asphalt applied within the EVT range and at a rate of 20 to 40 lbs./sq. or Flintlastic FR Cap T or Flintlastic FR Cap T CoolStar torch adhered to ply sheet.

Surfacing: (Optional) Any coating, listed below, used as a surfacing, must be listed within a current NOA. Install one of the following:

1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lb./sq..
2. Karnak (#97 AF) Fibrated Aluminum Roof Coating, FlintCoat A-150, APOC #212 Fibrated Aluminum Roof Coating at an application rate of 1½ gal./sq., or APOC #400 Sunbrite at an application rate of 3 gal./sq..

Maximum Design Pressure: See Fastening Options Above



Membrane Type: APP/SBS Modified
Deck Type 3I: Concrete Decks, Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type D(3): All layers of insulation and base sheet simultaneously attached.

All General and System Limitations apply.

One or more layers of any of the following insulations:

<u>Insulation Layer</u>	<u>Insulation Fasteners Table 3</u>	<u>Fastener Density/ft²</u>
ACFoam-II, ENRGY 3, ENRGY 3 25 PSI, FlintBoard ISO, H-Shield Minimum 1.5” thick	N/A	N/A

Note: Insulation layer shall have preliminary attachment, prior to the installation of the base/anchor sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.

Base Sheet: One ply of Ultra Poly SMS Base Sheet mechanically attached as detailed in below:

Fastening: Trufast #15 EHD Fastener and Trufast 2.4” Barbed Metal Seam Plates space 12” o.c. in a 4” side lap. The lap is heat welded closed encapsulating the fastener row.

Ply Sheet: None.

Membrane: Flintlastic GTA, Flintlastic GTA CoolStar, Flintlastic GTA-FR or GTA-FR CoolStar torch adhered to base/ply sheet.

Surfacing: (Optional) Any coating, listed below, used as a surfacing, must be listed within a current NOA. Install one of the following:

1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lb./sq..
2. Karnak (#97 AF) Fibrated Aluminum Roof Coating, FlintCoat A-150, APOC #212 Fibrated Aluminum Roof Coating at an application rate of 1½ gal./sq., or APOC #400 Sunbrite at an application rate of 3 gal./sq..

Maximum Design Pressure: -60 psf (See General Limitation #7)



Membrane Type: APP/SBS Modified
Deck Type 3I: Concrete Decks, Insulated
Deck Description: Min. 2500 psi structural concrete or concrete plank
System Type D(4): All layers of insulation and base sheet simultaneously attached.

All General and System Limitations apply.

One or more layers of any of the following insulations.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
(Optional) ACFoam-II, ENRGY 3, FlintBoard ISO, H-Shield, Multi-Max FA-3, H-Shield Minimum 1.0" thick	N/A	N/A
(Optional) Expanded Polystyrene (min 1.25 pcf) Minimum 1" thick	N/A	N/A
(Optional) Approved Perlite Minimum ¾" thick	N/A	N/A
(Optional) Approved High Density Wood Fiberboard Minimum ½" thick	N/A	N/A
(Optional) DensDeck, DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board Minimum ¼" thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ACFoam-II, ENRGY 3, FlintBoard ISO, H-Shield, Multi-Max FA-3, H-Shield Minimum 1.0" thick	N/A	N/A
Approved Expanded Polystyrene (min 1.25 pcf) Minimum 1" thick	N/A	N/A
Approved High Density Wood Fiberboard Minimum ½" thick	N/A	N/A
Approved Perlite Minimum ¾" thick	N/A	N/A
DensDeck, DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board Minimum ¼" thick	N/A	N/A

Note: Top layer shall have preliminary attachment, prior to the installation of the base/anchor sheet, at an application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.



Base Sheet: One ply of Poly SMS or Ultra Poly SMS, mechanically attached as detailed below:

Fastening: OMG #14 Roofgrip and OMG 3 in. Round Metal Plates, Dekfast #14 and Dekfast Galvalume Steel Hex Plates, Trufast #14 HD Fastener and Trufast 3” Metal Insulation Plates or FlintFast #14 screws and FlintFast 3” plates at 12” o.c. in the 4” wide lap and 12” o.c. in two equally spaced staggered rows in the field.

Ply Sheet: (Optional) Flintlastic FR Base T, torch applied.

Membrane: Flintlastic FR Cap T, Flintlastic FR Cap T CoolStar, torch applied.

Maximum Design Pressure: -112.5psf (See General Limitation #7)



Membrane Type: APP Modified
Deck Type 3I: Concrete Decks, Non-Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type F(1): Base sheet adhered with approved asphalt.

All General and System Limitations apply.

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of base sheet.

Base Sheet: One ply of All Weather/Empire Base Sheet, Glas-Base, Flexiglas Base, Flexiglas FR Base, Poly SMS, Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the substrate with approved mopping asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or one ply of Black Diamond Base self-adhered to the substrate.

Ply Sheet: (Optional) One ply of All Weather/Empire Base Sheet, Ultra Poly SMS, Glas-Base, Flexiglas Base, Flexiglas FR Base, PolySMS or one or more plies of Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the base sheet in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or one ply of Black Diamond Base Sheet self adhered or Flintlastic STA torch adhered.

Membrane: Flintlastic GTA, Flintlastic GTA CoolStar, Flintlastic GTA-FR or GTA-FR CoolStar torch adhered to base/ply sheet.

Surfacing: (Optional) Any coating, listed below, used as a surfacing, must be listed within a current NOA. Install one of the following:

1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lb./sq..
2. Karnak (#97 AF) Fibrated Aluminum Roof Coating, FlintCoat A-150, APOC #212 Fibrated Aluminum Roof Coating at an application rate of 1½ gal./sq., or APOC #400 Sunbrite at an application rate of 3 gal./sq..

Maximum Design Pressure: -240 psf (See General Limitation #9)



Membrane Type: SBS Modified
Deck Type 3I: Concrete Decks, Non-Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type F(2): Base sheet adhered with approved asphalt.

All General and System Limitations apply.

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of base sheet.

Base Sheet: One ply of All Weather/Empire Base Sheet, Glas-Base, Flexiglas Base, Flexiglas FR Base, Poly SMS, Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the substrate with approved mopping asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or one ply of Black Diamond Base self-adhered to the substrate.

Ply Sheet: (Optional) One ply of All Weather/Empire Base Sheet, Ultra Poly SMS, Glas-Base, Flexiglas Base, Flexiglas FR Base, PolySMS or one or more plies of Flintglas Ply Sheet (Type IV) or Flintglas Premium Ply Sheet (Type VI) adhered to the base sheet in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or one ply of Black Diamond Base Sheet (for use with a torched cap sheet only) self adhered.

Membrane: One ply of Flintlastic GMS, Flintlastic GMS CoolStar, Flintlastic Premium GMS, Flintlastic Premium GMS CoolStar, Flintlastic FR-P, Flintlastic FR-P CoolStar, Flintlastic Premium FR-P, Flintlastic Premium FR-P CoolStar, Flintlastic FR Cap Sheet, Flintlastic FR Cap Sheet CoolStar adhered to ply sheet with approved mopping asphalt applied within the EVT range and at a rate of 20 to 40 lbs./sq. or Flintlastic FR Cap T or Flintlastic FR Cap T CoolStar torch adhered to ply sheet.

Surfacing: (Optional) Any coating, listed below, used as a surfacing, must be listed within a current NOA. Install one of the following:

1. 400 lb./sq. gravel or 300 lb./sq. slag in a flood coat of approved mopping asphalt at an application rate of 60 lb./sq..
2. Karnak (#97 AF) Fibrated Aluminum Roof Coating, FlintCoat A-150, APOC #212 Fibrated Aluminum Roof Coating at an application rate of 1½ gal./sq., or APOC #400 Sunbrite at an application rate of 3 gal./sq..

Maximum Design Pressure: -240 psf (See General Limitation #9)



Membrane Type: SBS Modified
Deck Type 3I: Concrete Decks, Non-Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type F(3): Base sheet heat welded to primed substrate.

All General and System Limitations apply.

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of base sheet.

Base Sheet: One or more layers of Flintlastic FR Base T, torch applied.
Ply Sheet: (Optional) Flintlastic FR Base T, torch applied.
Membrane: Flintlastic FR Cap T, Flintlastic FR Cap T CoolStar, torch applied.
Maximum Design Pressure: -542.5 psf (See General Limitation # 9)



CONCRETE DECK SYSTEM LIMITATIONS:

1. If mechanical attachment to the structural deck through the lightweight insulating concrete is proposed, a field withdrawal resistance testing shall be performed to determine equivalent or enhanced fastener patterns and density. All testing and fastening design shall be in compliance with Testing Application Standard TAS 105 and Roofing Application Standard RAS 117, calculations shall be signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant.

GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq.
Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE