

# CITY OF LOS ANGELES

CALIFORNIA



ERIC GARCETTI  
MAYOR

BOARD OF  
**BUILDING AND SAFETY**  
COMMISSIONERS

—  
VAN AMBATIELOS  
PRESIDENT

E. FELICIA BRANNON  
VICE-PRESIDENT

JOSELYN GEAGA-ROSENTHAL  
GEORGE HOVAGUIMIAN  
JAVIER NUNEZ

DEPARTMENT OF  
**BUILDING AND SAFETY**

201 NORTH FIGUEROA STREET  
LOS ANGELES, CA 90012

—  
OSAMA YOUNAN, P.E.  
GENERAL MANAGER  
SUPERINTENDENT OF BUILDING

CETCO  
2870 Forbs Ave  
Hoffman Estates, IL 60192

Attn: Building Materials  
(847) 851-1800

RESEARCH REPORT: RR 25669  
(CSI 07110)

Expires: June 1, 2022  
Issued Date: June 1, 2020  
Code: 2020 LABC

**GENERAL APPROVAL**– Renewal and Clerical Modification - Strataseal HR Hot Applied Rubberized Asphalt Waterproofing System for Wall and Slab Waterproofing.

## DETAILS

1. The above product is approved for below-grade waterproofing as required by Chapter 18 of the Los Angeles Building Code. The product may be used in conjunction with Los Angeles City approved caulking materials at penetrations of the waterproofing membrane.
2. The application of the material shall be in accordance with the manufacturer's instructions. A copy of the instruction shall be available at each job site.
3. The product shall be in full contact with the wall and soil at all times.
4. The maximum allowable hydrostatic pressure of the Straaseal HR is 64.5 psi.

RR 25669  
Page 1 of 3

CETCO

Re: Strataseal HR Hot Applied Rubberized Asphalt Waterproofing System

## **DISCUSSION**

The report is in compliance with the 2020 Los Angeles City Building Code.

The clerical modification is to update this report to 2020 LABC.

The approval is based on tests.

Strataseal HR was tested with 129 psi Hydrostatic Resistance.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this Approval have been met in the project in which it is to be used.

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

---

DAVID CHANG, Chief  
Engineering Research Section  
201 N. Figueroa St., Room 880  
Los Angeles, CA 90012  
Phone- 213-202-9812  
Fax- 213-202-9943

DC  
RR25669  
TLB2000096  
R06/01/2020  
1805.3

CETCO

Re: Strataseal HR Hot Applied Rubberized Asphalt Waterproofing System