

# **Product Submittal Sheet**

Tech Support: 888-437-3244 Engineering Services: 877-832-3206

0.629 lb/ft

0.750 in 4.000 in

0.0330 in

Sales: 800-543-7140 clarkdietrich.com

#### Product category: Product name:

## (TLF) TRAKLOC Fixed Length Stud **250TLF125-33 33ksi G40 - Punched** 2-1/2" TRAKLOC Stud 33 mils (20ga) Coating: G40 Color coding: White

**Geometric Properties** 

Web depth	2.500 in	Weight
Flange width	1.250 in	Punchout width
Stiffening lip	0.288 in	Punchout length
Design thickness	0.0347 in	Minimum thickness
Yield stress, Fy	33 ksi	

## **Gross Section Properties of Full Section, Strong Axis**

Cross sectional area (A)	0.185 in <sup>2</sup>
Moment of inertia (Ix)	0.188 in <sup>4</sup>
Radius of gyration (Rx)	1.010 in
Gross moment of inertia (ly)	0.039 in <sup>4</sup>
Gross radius of gyration (Ry)	0.459 in

## **Effective Section Properties, Strong Axis**

0.116 in <sup>2</sup>
0.187 in <sup>4</sup>
0.143 in <sup>3</sup>
2824 in-lbs
3072 in-lbs
990 lb
414 lb

### **Torsional Properties**

Unbraced Length (Lu)

St. Venant torsion constant (J x 1000)	0.0738 in <sup>4</sup>
Warping constant (Cw)	0.053 in <sup>6</sup>
Distance from shear center to neutral axis (Xo)	-0.980 in
Radii of gyration (Ro)	1.480 in
Torsional flexural constant (Beta)	0.561
Stud/track end reaction (Rx)	31 lbs

#### Notes:

• Calculated properties are based on AISI S100-07 w/ S2-10 Supplement and AISI S100-12, North American Specification for Design of Cold-Formed Steel Structural Members.

29.9 in

- · Gross and torsional properties are based on full-unreduced cross section of the studs, away from punch-outs.
- The allowable moment based on local buckling (Mal) is based on the compression flange continuously braced.
- The distortional buckling moment (Mad) does not consider the beneficial effect of sheathing to rotational stiffness.
- · For deflection calculations, use the effective moment of inertia.
- Stud/Track End Reaction (Rx) is the maximum end reaction (web crippling) capacity based on a minimum bearing length of 1 inch.
- East Coast Punch Pattern: Center of knockouts are 12" from the leading edge then 48" o.c.
- West Coast Punch Pattern: Center of knockouts are 24" from the leading edge then 24" o.c.

#### Sustainability Credits:


For more details and LEED letters contact Technical Services at 888-437-3244 or visit www.clarkdietrich.com/LEED

LEED v4 MR Credit -- Building Product Disclosure and Optimization: EPD (1 point) - Sourcing of Raw Materials (1 point) - Material Ingredients (1 point) - Construction and Demolition Waste Management (up to 2 points) - Innovation Credit (up to 2 points).

LEED 2009 Credit MR 2 & MR 4 -- ClarkDietrich's steel products are 100% recyclable and have a national average recycled content of 34.2% (19.8% post-consumer and 14.4% pre-consumer). If seeking a higher number to meet Credit MR 5, please contact us at (info@clarkdietrich.com / 888-437-3244)

Project Information	Contractor Information	Architect Information
Name:	Name:	Name:
Address:	Contact:	Contact:
	Phone:	Phone:
	Fax:	Fax:

## 09.22.16 (Non-Structural Metal Framing)



#### **ASTM & Code Standards:**

- AISI-NASPEC 2007 w/S2-10
- Meets or exceeds ASTM C645
- ICC ESR-1464 Evaluation Report
- SDS & Product Certification Information available at www.clarkdietrich.com





## **Product Submittal Sheet**

Tech Support: 888-437-3244 Engineering Services: 877-832-3206 Sales: 800-543-7140 clarkdietrich.com

#### Product category: Product name:

(TLF) TRAKLOC Fixed Length Stud 250TLF125-33 33ksi G40 - Punched 2-1/2" TRAKLOC Stud 33 mils (20ga)

## 2-1/2" TRAKLOC Stud 33 mils (20ga) Drywall Stud - COMPOSITE Limiting Heights (AC86-2012)

#### (1 layer) 5/8" Type X Gypsum Board

Spacing		5 psf			7.5 psf			10 psf	
(inches)	L/120	L/240	L/360	L/120	L/240	L/360	L/120	L/240	L/360
12	20'-11"	16'-7"	14'-6"	18'-3"	14'-6"	12'-8"	16'-7"	13'-2"	11'-6"
16	19'-0"	15'-1"	13'-2"	16'-7"	13'-2"	11'-6"	15'-1"	12'-0"	10'-6"
24	16'-7"	13'-2"	11'-6"	14'-6"	11'-6"	10'-1"	13'-2"	10'-6"	9'-0"

Composite Table Notes:

• Allowable composite limiting heights were determined in accordance with ICC-ES AC86-2012.

• Additional composite wall testing and analysis requirements of the SFIA Code Compliance Certification Program were observed.

• In accordance with current building codes and AISI design standards, the 1/3 Stress Increase for strength was not used.

• The composite limiting heights provided in the tables are based on a single layer of 5/8" Type X Gypsum Board complying with ASTM C1396 and from the following manufacturers: American Gypsum, CertainTeed, Georgia Pacific, Continental, National Gypsum or USG.

• The gypsum board must be applied full height in the vertical orientation to each stud flange and installed in accordance with ASTM C754 using minimum No. 6 Type S fine thread Drywall bugle head screws spaced as listed below:

- Screws spaced a maximum of 16 inch on-center to framing members spaced at 12 inch on-center.

- Screws spaced a maximum of 12 inch on-center to framing members spaced at 16inch or 24 inch on-center.
- Screws spaced 16 inch on-center to the top and bottom track.
- No fasteners are required for attaching the stud to the track except as detailed in ASTM C754.
- Stud end bearing must be a minimum of 1 inch.
- f: Adjacent to the height value indicates that flexural stress controls the allowable wall height.
- s: Adjacent to the height value indicates that shear/end reaction controls the allowable wall height.

### 2-1/2" TRAKLOC Stud 33 mils (20ga) Drywall Stud - NON-COMPOSITE Limiting Heights (FULLY BRACED)

Spacing		5 psf			7.5 psf			10 psf	
(inches)	L/120	L/240	L/360	L/120	L/240	L/360	L/120	L/240	L/360
12	17'-0"	13'-6"	11'-9"	15'-10"	13'-3"	11'-7"	13'-9"	12'-1"	10'-6"
16	15'-5"	12'-3"	10'-8"	13'-9"	12'-1"	10'-6"	11'-11"	10'-11"	9'-7"
24	13'-6"	10'-8"	9'-4"	11'-2"	10'-6"	9'-2"	9'-8"	9'-7"	8'-4"

Non-Composite Table Notes:

• Heights are based on AISI S100-07 w/S2-10 Supplement, and AISI S100-12 Specification using steel properties alone.

· Compression flange must be continuously braced.

- End bearing must be 1 inch.
- e: Web stiffeners are required at the stud/track connection.

Project	Information
Name:	
Address:	

**Contractor Information** 

Name: Contact: Phone: Fax: Architect Information Name: Contact: Phone: Fax: