

 Product iQ will be unavailable on Saturday, April 13th from 8:00am to 1:00pm CST due to site maintenance. We apologize for any inconvenience.

UL Product iQ®



## Caulking and Sealants

[See General Information for Caulking and Sealants](#)

### DEWALT INDUSTRIAL TOOL CO

701 E Joppa Rd

Towson, MD 21286 USA

**Foamed plastic caulking and sealant.**

R16754

#### PowerFoam Residential Grade Applied to Inorganic Reinforced Cement Board+

Flame spread	10
Smoke developed	30

+Tested as applied in three 3/4 in. diameter beads, 5 in. OC covering 12.5 percent of the exposed test sample area.

#### TriggerFoam Pro Standard Applied to Inorganic Reinforced Cement Board+

Flame spread	5
Smoke developed	10

+Tested as applied in three 3/4 in. diameter beads, 5 in. OC covering 12.5 percent of the exposed test sample area.

#### TriggerFoam Pro Window and Door Applied to Inorganic Reinforced Cement Board+

Flame spread	0
Smoke developed	10

+Tested as applied in three 3/4 in. diameter beads, 5 in. OC covering 12.5 percent of the exposed test sample area.

#### TriggerFoam Pro All Season Applied to Inorganic Reinforced Cement Board+

Flame spread	0
Smoke developed	10

+Tested as applied in three 3/4 in. diameter beads, 5 in. OC covering 12.5 percent of the exposed test sample area.

**Trigger Foam Pro Fire Block  
Applied to Inorganic  
Reinforced Cement Board+**

Flame spread	0
Smoke developed	10

+Tested as applied in three 3/4 in. diameter beads, 5 in. OC covering 12.5 percent of the exposed test sample area.

**Trigger Foam Pro Window & Door  
Applied to Inorganic  
Reinforced Cement Board+**

Flame spread	0
Smoke developed	10

+Tested as applied in three 3/4 in. diameter beads, 5 in. OC covering 12.5 percent of the exposed test sample area.

**Trigger Foam Pro All Season  
Applied to Inorganic  
Reinforced Cement Board+**

Flame spread	0
Smoke developed	10

+Tested as applied in three 3/4 in. diameter beads, 5 in. OC covering 12.5 percent of the exposed test sample area.

**DEWALT POWER FOAM Applied to Inorganic  
Reinforced Cement Board+**

Flame spread	10
Smoke developed	50

+ Tested as applied in two 3/4 in. (19 mm) diameter beads, 8 in. (203mm) OC covering 8.3 percent of the exposed test sample area.

**DEWALT POWER RESIDENT Applied to Inorganic  
Reinforced Cement Board+**

Flame spread	10
Smoke developed	50

+ Tested as applied in two 3/4 in. (19 mm) diameter beads, 8 in. (203mm) OC covering 8.3 percent of the exposed test sample area.

**DEWALT TRIGGER FOAM PRO FIRE BLOCK FORMULA  
Applied to Inorganic Reinforced Cement Board+**

Flame spread	10
Smoke developed	5

+ Tested as applied in two 3/4 in. (19 mm) diameter beads, 8 in. (203mm) OC covering 8.3 percent of the exposed test sample area.

**DEWALT TRIGGER FOAM PRO STANDARD FORMULA**  
**Applied to Inorganic Reinforced Cement Board+**

Flame spread	10
Smoke developed	5

+ Tested as applied in two 3/4 in. (19 mm) diameter beads, 8 in. (203mm) OC covering 8.3 percent of the exposed test sample area.

Last Updated on 2020-06-01

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2024 UL LLC."