

ICC-ES Evaluation Report



ESR-3026

Reissued April 2021 This report is subject to renewal April 2022.

www.icc-es.org | (800) 423-6587 | (562) 699-0543

A Subsidiary of the International Code Council®

DIVISION: 07 00 00—THERMAL AND MOISTURE

PROTECTION

Section: 07 53 23—Ethylene-Propylene-Diene-Monomer

Roofing

REPORT HOLDER:

FIRESTONE BUILDING PRODUCTS COMPANY, LLC

EVALUATION SUBJECT:

FIRESTONE RUBBERGARD EPDM SINGLE-PLY **ROOFING MEMBRANES**

ADDITIONAL LISTEE:

GENFLEX ROOFING SYSTEMS, LLC

1.0 EVALUATION SCOPE

Compliance with the following codes:

- 2018, 2015, 2012 and 2009 International Building Code® (IBC)
- 2013 Abu Dhabi International Building Code (ADIBC)[†]

[†]The ADIBC is based on the 2009 IBC. 2009 IBC code sections referenced in this report are the same sections in the ADIBC.

Properties evaluated:

- Weather resistance
- Fire classification
- Wind uplift resistance
- Impact resistance

2.0 USES

Firestone RubberGard EPDM single-ply roofing membranes are used as roof coverings in ballasted, adhered and mechanically fastened membrane roofing systems.

3.0 DESCRIPTION

3.1 General:

The RubberGard EPDM Membrane Roofing Systems described in this report consist of single-ply roofing membranes, insulation (where used), barrier board or slip sheet (where used), flashing, mechanical fasteners and adhesives that are installed on a combustible or noncombustible deck.

3.2 EPDM Membranes:

3.2.1 Fire Retardant RubberGard: Fire Retardant RubberGard is a nonreinforced fire-resistant EPDM

single-ply roofing membrane complying with ASTM D4637, available in nominally 45-mil (1.1 mm) or 60-mil (1.5 mm) thicknesses. The 45-mil-thick membrane weighs approximately 0.31 lb/ft2 (1.5 kg/m2) and is available in 100-foot-long by 7.5-foot- or 9-foot-wide (30.5 m by 2.3 or 2.7 m) rolls. The 60-mil-thick membrane weighs approximately 0.43 lb/ft2 (2.1 kg/m2) and is available in 100-foot-long by 7.5-foot- or 9-foot-wide (30.5 m by 2.3 or 2.7 m) rolls.

- 3.2.2 RubberGard LS-FR: Standard RubberGard LS-FR is a nonreinforced fire-resistant EPDM single-ply roofing membrane complying with ASTM D4637, available in nominally 45-mil (1.1 mm) or 60-mil (1.5 mm) thicknesses. 45-mil-thick membrane weighs approximately 0.31 lb/ft2 (1.5 kg/m2) and is available in rolls of various widths, 100 feet long (30.5 m). The 60-mil-thick membrane weighs approximately 0.43 lb/ft2 (2.1 kg/m2) and is available in rolls of various widths, 100 feet long (30.5 m).
- 3.2.3 RubberGard LS-FR PT: Standard RubberGard LS-FR PT is a nominally 60-mil (1.5 mm) thick, nonreinforced fire-resistant EPDM single-ply roofing membrane complying with ASTM D4637, with a pre-applied 3-inch or 6-inch-wide (76 or 152 mm), 0.035-inch-thick (0.9 Quick mm) Seam tape laminated along the length of the membrane. The membrane weighs approximately 0.31 lb/ft2 (1.5 kg/m2) and is available in rolls of various widths, 100 feet long (30.5 m).
- 3.2.4 RubberGard MAX: RubberGard MAX is an internally-reinforced EPDM single-ply roofing membrane complying with ASTM D4637, available in nominally 45-mil (1.1 mm), 60-mil (1.5 mm) or 75-mil (1.9 mm) The 45-mil-thick membrane weighs thicknesses. approximately 0.32 lb/ft² (1.5 kg/m²) and is available in 100foot-long by 7.5-foot- or 10-foot-wide (30.5 m by 2.3 or 3 m) rolls. The 60-mil-thick membrane weighs approximately 0.42 lb/ft² (2.0 kg/m²) and is available in 100foot-long by 7.5-foot- or 10-foot-wide (30.5 m by 2.3 or 3 m) rolls. The 75-mil-thick membrane weighs approximately 0.52 lb/ft2 (2.4 kg/m2) and is available in 100-foot-long by 7.5-foot- or 10-foot-wide (30.5 m by 2.3 or 3 m) rolls.
- 3.2.5 RubberGard MAX PT: RubberGard MAX PT is an internally-reinforced EPDM single-ply roofing membrane complying with ASTM D4637, available in nominally 45-mil (1.1 mm), 60-mil (1.5 mm) or 75-mil (1.9 mm) thicknesses, with a pre-applied 3-inch or 6-inch-wide (76 or 152 mm), 0.035-inch-thick (0.9 mm) Quick Seam tape laminated along the length of the membrane. The 45-mil-thick membrane weighs approximately 0.33 lb/ft2





- **3.2.6 RubberGard MAX FR:** RubberGard Max FR is an internally-reinforced, fire-resistant, EPDM single-ply roofing membrane complying with ASTM D4637, available in nominally 45-mil (1.1 mm), 60-mil (1.5 mm) or 75-mil (1.9 mm) thicknesses. The 45-mil-thick membrane weighs approximately 0.32 lb/ft² (1.5 kg/m²) and is available in 100-foot-long by 7.5-foot- or 10-foot-wide (30.5 m by 2.3 or 3 m) rolls. The 60-mil-thick membrane weighs approximately 0.42 lb/ft² (2.0 kg/m²) and is available in 100-foot-long by 7.5-foot- or 10-foot-wide (30.5 m by 2.3 or 3 m) rolls. The 75-mil-thick membrane weighs approximately 0.52 lb/ft² (2.5 kg/m²) and is available in 100-foot-long by 7.5-foot- or 10-foot-wide (30.5 m by 2.3 or 3 m) rolls.
- **3.2.7 RubberGard Platinum:** RubberGard Platinum is a nominally 90-mil (2.2 mm) thick, nonreinforced, EPDM single-ply roofing membrane complying with ASTM D4637. The membrane weighs approximately 0.56 lb/ft² (2.7 kg/m²) and is available in 50-foot- or 100-foot-long by 10-foot-wide (15.2 or 30.5 m by 3 m) rolls.
- **3.2.8 RubberGard EcoWhite:** RubberGard EcoWhite is a nominally 60-mil (1.5 mm) thick, nonreinforced, bi-laminate, white-on-black, cured single ply roofing membrane complying with ASTM D4637. The membrane weighs approximately 0.43 lb/ft² (2.1 kg/m²) and is available in rolls of various widths, 100 feet long (30.5 m).
- **3.2.9 RubberGard EcoWhite Platinum:** RubberGard EcoWhite Platinum is a nominally 90-mil (2.3 mm) thick, nonreinforced, bi-laminate, white-on-black, cured single ply roofing membrane complying with ASTM D4637. The membrane weighs approximately 0.61 lb/ft² (3.0 kg/m²) and is available in 100-foot-long by 10-foot-wide (30.5 m by 3 m) rolls
- **3.2.10 RubberGard EPDM SA:** RubberGard EPDM SA membrane is a nominally 60-mil (1.5 mm) thick, non-reinforced, self-adhered single-ply EPDM roofing membrane complying with ASTM D4637. The membrane weighs approximately 0.47 lb/ft² (2.1 kg/m²) and is available in rolls of various widths in 100-foot-long (30.5 m) lengths.

3.3 Insulation:

See Tables 1 through 5 for insulations used with specific roofing systems. Foam plastic insulation, where used, must have a flame-spread index of not more than 75 when tested at the maximum thickness intended for use in accordance with ASTM E84. Polyisocyanurate and polystyrene foam plastic insulation must comply with ASTM C1289 and ASTM C578, respectively, and with Chapter 26 of the IBC.

3.4 Barrier board or Coverboard:

Barrier board or coverboard, when used, may be any of the following:

- Minimum ¹/₄-inch-thick (6.4 mm) G-P Gypsum Corporation DensDeck or DensDeck Prime.
- Minimum ¹/₂-inch-thick (12.7 mm) gypsum board, complying with ASTM C1396.
- One-half-inch-thick (12.7 mm) Firestone ISOGARD HD or Firestone RESISTA.
- One-half-inch-thick (12.7 mm) USG Corporation SECUROCK Gypsum Fiber Roof Board.

3.5 Fasteners:

Fasteners and stress plates used to attach barrier or cover boards, insulation boards and roofing membranes must be corrosion-resistant. Fasteners may be any of the Firestone insulation and membrane fasteners, plates and strips summarized in this section or noted in Table 5.

- **3.5.1 Firestone All-Purpose Fasteners:** An epoxycoated steel screw used in combination with the Firestone Insulation Fastening Plate to attach roofing insulation and base sheets to steel and wood substrates. Fastener length must be sufficient to penetrate through the steel deck a minimum of ³/₄ inch (19.1 mm), and into the wood deck a minimum of 1 inch (25.4 mm).
- **3.5.2** Firestone Heavy-Duty Fastener: An epoxy-coated steel screw used in combination with the Firestone Insulation Fastening Plates, Firestone Batten Strips, Seam Plates or Termination Bars to attach roofing insulation and base sheets to steel, wood and concrete decks. Fastener length must be sufficient to penetrate through the steel deck a minimum of ³/₄ inch (19.1 mm), and into the wood or concrete deck a minimum of 1 inch (25.4 mm).
- **3.5.3 Firestone Concrete Drive Fastener:** A nonthreaded hammer-in fastener, epoxy-coated, used with Firestone Insulation Plates to attach roofing insulation, base sheets and other accessories to structural concrete substrates. Fastener length must be sufficient to penetrate into the concrete deck a minimum of 11/4 inch (32 mm).
- **3.5.4** Firestone Insulation Fastening Plate: A 3-inch-diameter (76 mm) galvalume plate used in combination with Firestone fasteners to secure insulation and base sheets to the roof deck.
- **3.5.5 Firestone Seam Plate:** A 2-inch-diameter (50 mm), galvalume plate used in combination with Firestone All-Purpose, Heavy-Duty and Concrete Drive fasteners.
- **3.5.6 Firestone V-Plate:** A 2.25-inch-diameter (57 mm), galvalume plate used in combination with Firestone All-Purpose, Heavy-Duty and Concrete Drive fasteners to secure Firestone RubberGard MAX and Firestone QuickSeam Strips.
- **3.5.7 Firestone Batten Strip:** A corrosion-resistant, 10-foot-long by 1-inch-wide (3 m by 25.4 mm), galvalume metal batten strip with holes spaced 6 inches (152 mm) o.c.
- **3.5.8 Firestone Polymer Batten Strip:** A corrosion-resistant polymer batten strip, with holes spaced 3 inches (76 mm) o.c., available in 250-feet-long by ¾-inch-wide (76.2 m by 19.1 mm) rolls.
- **3.5.9 QuickSeam R.M.A. Strip:** A 10-inch-wide (254 mm) RubberGard Max membrane with two 3-inch-wide (76 mm) strips of laminated tape on both sides along the length of the strip used to anchor membranes to the substrate.

3.6 Adhesives:

3.6.1 Firestone Water Based Bonding Adhesive (P) [WBBA (P)]: A contact adhesive designed for bonding RubberGard EPDM products to specific substrates as specified in the report holder's or additional listee's installation instructions. The adhesive is applied to both the substrate and the underside of the membrane with a coverage of approximately 100 to 120 ft² (9.3 to 11.62 m²) per gallon (3.78 L), total, for both the substrate and the membrane. See Table 2 and Tables 4A through 4F for the adhesive application rate for each specific system. Water Based Bonding Adhesive (P) is an alternative to Firestone solvent based bonding adhesives. The adhesive has a shelf life of one year when stored in unopened containers at temperatures between 60° F (16° C) and 80° F (27° C).

- **3.6.3** Single-Ply LVOC Bonding Adhesive: Solvent based, contact adhesives designed for bonding Firestone RubberGard EPDM membranes and flashings to wood, metal, masonry and other substrates as specified in the report holder's or additional listee's installation instructions. Either adhesive is applied to both the substrate and the underside of the membrane with a coverage of approximately 45 to 60 ft² (4.18 to 5.58 m²) per gallon (3.78 L), total, for both the substrate and the membrane. Each adhesive has a shelf life of one year when stored in unopened containers at temperatures between 60°F (16°C) and 80°F (27°C).
- **3.6.4 Single-Ply LVOC Bonding Adhesive 1168:** Solvent based, contact adhesives designed for bonding Firestone RubberGard EPDM membranes and flashings to wood, metal, masonry and other substrates as specified in the report holder's or additional listee's installation instructions. Either adhesive is applied to both the substrate and the underside of the membrane with a coverage of approximately 45 to 60 ft² (4.18 to 5.58 m²) per gallon (3.78 L), total, for both the substrate and the membrane. Each adhesive has a shelf life of one year when stored in unopened containers at temperatures between 60°F (16°C) and 80°F (27°C)
- **3.6.5** Firestone EPDM Solvent Free Bonding Adhesive: A polymer based bonding adhesive for adhering non-reinforced RubberGard EPDM membranes to substrates on vertical and horizontal applications as specified in the report holder's or additional listee's installation instructions. The adhesive is applied to the substrate only with a coverage of approximately 150 ft² (11.62 m²) per gallon (3.78 L). The adhesive has a shelf life of 12 months when stored in unopened containers at temperature between 60° F (16° C) and 80° F (27° C).
- **3.6.6 Firestone I.S.O. Twin-Pack Insulation Adhesive:** A two-component, low-rise, polyurethane insulation adhesive designed for bonding roof insulations to deck substrate types as specified in the report holder's or additional listee's installation instructions. The components have a shelf life of one year when stored in unopened containers at temperatures between 60°F (16°C) and 80°F (27°C).
- **3.6.7 Firestone I.S.O. FIX II:** A single-component, polyurethane adhesive designed for bonding of Firestone ISO 95+ GL, Fibertop, and DensDeck to substrates as specified in the report holder's or additional listee's installation instructions. The adhesive has a shelf life of 15 months when stored in unopened containers at temperatures between 50°F (10°C) and 75°F (24°C).
- **3.6.8 Firestone I.S.O. STICK:** A two-component, low-rise polyurethane insulation adhesive designed for bonding insulations to specific deck substrate types as specified in the report holder's or additional listee's installation instructions. The components have a shelf life of 18 months when stored in unopened containers at temperatures between 60°F (16°C) and 80°F (27°C).

3.7 Surface Coating:

Firestone AcryliTop PC-100 is an acrylic coating that may be spray-applied in one coat or roller-applied using two coats. When spray-applied in one coat, the AcryliTop PC-100 has a coverage rate of approximately 100 ft² (9.3 m²) per gallon (3.78 L). For roller application, the Firestone AcryliTop PC-100 Base Coat is applied in one coat at a coverage rate of 200 ft² (18.6 m²) per gallon (3.78 L). The second coat of AcryliTop PC-100 is applied at a 100 ft² (9.3 m²) per gallon (3.78 L). The AcryliTop PC-100 has a shelf life of one year when stored in unopened containers at temperatures between 60°F (16°C) and 80°F (27°C).

3.8 Impact Resistance:

The Firestone RubberGard EPDM roofing membranes described in this report comply with the impact resistance requirements of IBC Section 1504.7 based testing in accordance with Section 4.6 of FM 4470.

4.0 INSTALLATION

4.1 General:

Installation of the EPDM roofing membranes described in this report must comply with the applicable code, the report holder's or additional listee's published installation instructions and this report. The report holder's or additional listee's published installation instructions must be available on the jobsite at all times during installation.

The substrate to which the membrane is to be applied must be clean, dry, and free of frost, loose fasteners, and other protrusions or contaminates that will interfere with the adhesion or attachment of the membrane or that will puncture the membrane. All materials must be protected against contact with incompatible materials. Where gypsum board is used as barrier board in the roofing assembly, weather protection must be provided to prevent damage to the gypsum board prior to application of the roofing membrane.

The slope of the roof on which the single-ply membrane systems are installed must be a minimum of ¹/₄:12 (2 percent slope) and must not be more than the maximum slope indicated for the particular assembly as listed in Tables 1 through 3.

Penetrations and terminations of the roof covering must be flashed and made weathertight in accordance with the requirements of the membrane manufacturer and Section 1503.2 of the IBC. Where flashing is of metal, the metal must be corrosion-resistant, minimum No. 26 gage [0.019 (0.483 mm)] galvanized steel.

4.2 Fire Classification:

- **4.2.1 New Construction:** Roof covering systems described in Tables 1 through 3, when installed in accordance with this report, are classified as Class A or B roof covering systems in accordance with ASTM E108 or UL 790.
- **4.2.2 Reroofing:** The existing deck must be inspected to verify that the structure to be reroofed is structurally sound and adequate to support and secure the roofing membrane.

Class A, B, or C roof covering systems may be installed over existing classified roof covering systems under the following conditions provided the resulting classification is the lower of the new and existing roofing classification:

- New uninsulated systems installed only over existing uninsulated assemblies.
- New insulated systems installed over existing uninsulated systems only.

4.3 Wind Uplift Resistance:

4.3.1 New Construction: The allowable wind uplift pressures for the Firestone membrane roof covering systems described in the report are noted in Tables 4 and 5. Metal edge securement for all roofing systems must be listed in accordance with 2011 edition (2018 and 2015 IBC) or 2003 edition (2012 and 2009 IBC) of ANSI/SPRI ES-1 and designed and installed for wind loads in accordance with IBC Section 1504.5 and IBC Chapter 16.

The ballasted membrane roof covering system in Table 1 must comply with ANSI/SPRI RP-4.

4.3.2 Reroofing: Roof covering systems employing mechanical fasteners must be qualified to the satisfaction of the code official as to the adequacy of fasteners penetrating through existing roof coverings into structural substrates. Since the composition and/or condition of any particular underlying existing roofing material may vary widely, reroofing with adhered systems is outside the scope of this report.

5.0 CONDITIONS OF USE

The Firestone RubberGard EPDM single-ply roofing membranes described in this report comply with, or are suitable alternatives to what is specified in the IBC, subject to the following conditions:

- 5.1 Installation of the roofing systems must comply with the IBC, the report holder's or additional listee's published installation instructions and this report. If there are any conflicts between the report holder's or additional listee's published installation instructions and this report, this report governs.
- 5.2 The roof covering systems must be installed only by applicators approved by Firestone Building Products Company, LLC or Genflex Roofing Systems, LLC.
- 5.3 Foam plastic insulation must be separated from the interior of the building by an approved thermal barrier in accordance with IBC Section 2603.4.1.5.
- 5.4 Foam plastic insulation, where used, must bear the label of an approved agency indicating that the foam plastic has a flame-spread index of not more than 75 when tested at the maximum thickness intended for use in accordance with ASTM E84 or UL 723, subject to the approval of the code official.
- **5.5** Above-deck thermal insulation board must comply with the applicable standards listed in IBC Table 1508.2.
- 5.6 Design wind-uplift pressure on any roof area, including edge and corner zones, must not exceed the allowable

- wind pressure for the system installed in that particular area. Refer to the allowable wind uplift pressure for roof coverings as listed in Tables 4 and 5.
- 5.7 The allowable wind uplift pressures listed in Tables 4 and 5 are for the roof covering only. The deck and framing to which the roof covering is attached must be designed for the applicable components and cladding wind loads in accordance with the IBC.
- 5.8 Calculations demonstrating that the required wind resistance is less than the allowable wind resistance must be submitted to the code official.
- 5.9 When application is over existing roofs, documentation of the wind uplift resistance of the composite roof construction must be submitted to the code official for approval at the time of permit application.
- 5.10 The membranes are manufactured in Prescott, Arkansas under a quality-control program with inspections by ICC-ES.

6.0 EVIDENCE SUBMITTED

Data in accordance with the ICC-ES Acceptance Criteria for Membrane Roof covering Systems (AC75), dated July 2010 (editorially revised March 2018).

7.0 IDENTIFICATION

- 7.1 Each roll of roofing membrane described in this report is identified with a label indicating the report holder's name (Firestone Building Products Company, LLC) or the name of the additional listee (Genflex Roofing Systems, LLC), the product name, and the evaluation report number (ESR-3026).
- **7.2** The report holder's contact information is the following:

FIRESTONE BUILDING PRODUCTS COMPANY, LLC 200 4TH AVENUE SOUTH NASHVILLE, TENNESSEE 37201 (800) 428-4442 www.firestonebpco.com

7.3 The Additional Listee's contact information is the following:

GENFLEX ROOFING SYSTEMS, LLC 200 4TH AVENUE SOUTH NASHVILLE, TENNESSEE 37201 (800) 443-4272 www.genflex.com

TABLE 1—FIRE CLASSIFICATION ASSEMBLIES - BALLASTED ROOFING SYSTEMS

| SYSTEM NO. | ROOF CLASS | SUBSTRATE | MAX. ROOF SLOPE | INSULATION ^{2,3} | MEMBRANE ¹ | SURFACING |
|---------------|---------------|-------------------------------|--------------------|-------------------------------------------------------|-----------------------|------------------------------------------------------------------------------------------|
| 1 | А | Combustible or noncombustible | 2:12 | (Optional) Any UL- classified foam plastic insulation | RubberGard | River-bottom stones at min. 1000 lbs/100 ft² or concrete pavers at min. 10 lbs/ft² |

For SI: 1 inch = 25.4 mm

¹Membranes must be UL-classified for roofing systems.

²All foam plastic insulation must be UL-classified foam plastic for roofing systems, and must be limited to the maximum thickness noted in Section 5.4 of this report.

³Polyisocyanurate insulation must comply with ASTM C1289. Polystyrene insulation must comply with ASTM C578.

TABLE 2—FIRE CLASSIFICATION ASSEMBLIES - ADHERED ROOFING SYSTEMS

| SYSTEM | ROOF | | MAX. | | BARRIER OR | MEMBRAN | E ⁴ | |
|--------|-------|------------------------|-----------------------------------|-------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------|-------------------|
| NO. | CLASS | SUBSTRATE ² | ROOF SLOPE | INSULATION ^{1,3} | COVER BD.4 | TYPE | ADHESIVE4 | SURFACING⁴ |
| 1 | А | Combustible | 11/2:12 | | Min. ¹ / ₄ -inch-thick DensDeck or DensDeck Prime, mechanically fastened to deck | RubberGard EcoWhite | BA-2004 (T), EPDM Solvent Free Bonding Adhesive, Single-Ply LVOC Bonding Adhesive or WBBA (P) | |
| 2 | А | Noncombustible | ¹ / ₄ :12 | Min. 1-inch- thick, any UL- classified polyisocyanurate insulation, mechanically fastened to steel deck or adhered to concrete deck | | RubberGard MAX, MAX PT or RubberGard EPDM SA (when an adhesive is not used) | BA-2004 (T) or Single-Ply LVOC Bonding Adhesive | |
| 3 | А | Concrete | ¹ / ₄ :12 | Min. 1-inch- thick, any UL- classified polyisocyanurate insulation, adhered to deck | Min. ¹ / ₄ -inch-thick DensDeck or DensDeck Prime, adhered to insulation | RubberGard EPDM SA (when adhesive is not used) | - | |
| 4 | A | Concrete | 2:12 | Same as System 3 | Same as System 3 | RubberGard Platinum | BA-2004 (T), EPDM Solvent Free Bonding Adhesive or Single-Ply LVOC Bonding Adhesive | |
| 5 | А | Concrete | 4 ¹ / ₂ :12 | Same as System 3 | Same as System 3 | RubberGard Platinum | BA-2004 (T), EPDM Solvent Free Bonding Adhesive or Single-Ply LVOC Bonding Adhesive | PC-100 Coating |
| 6 | А | Concrete | 4:12 | Same as System 3 | Same as System 3 | RubberGard MAX FR | BA-2004 (T), EPDM Solvent Free Bonding Adhesive or Single-Ply LVOC Bonding Adhesive | |
| 7 | А | Noncombustible | 11/2:12 | Same as System 2 | | RubberGard Platinum | BA-2004 (T), EPDM Solvent Free Bonding Adhesive or Single-Ply LVOC Bonding Adhesive | PC-100 Coating |
| 8 | А | Noncombustible | ¹/ ₂ :12 | Same as System 2 | | RubberGard LS-FR, LS-FR PT, Platinum or EcoWhite | BA-2004 (T), EPDM Solvent Free Bonding Adhesive or Single-Ply | |

TABLE 2—FIRE CLASSIFICATION ASSEMBLIES - ADHERED ROOFING SYSTEMS

| SYSTEM | ROOF | CUBCTDATE? | MAX. | INCLU ATION ¹³ | BARRIER OR | MEMBRAN | E ⁴ | CUDEACING4 |
|--------|-------|------------------------|---------------------------------|---------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------|---------------------------------|
| NO. | CLASS | SUBSTRATE ² | ROOF SLOPE | INSULATION ^{1,3} | COVER BD.⁴ | TYPE | ADHESIVE4 | SURFACING⁴ |
| | | | | | | | LVOC Bonding Adhesive | |
| 9 | А | Concrete | ¹ / ₂ :12 | Same as System 3 | Same as System 3 | RubberGard MAX or MAX PT | BA-2004 (T), EPDM Solvent Free Bonding AdhesiceNT Single-Ply LVOC Bonding Adhesive | NUED) |
| 10 | А | Noncombustible | ³/ _{4:} :12 | Max. 4-inch- thick Firestone "ISO 95+GL", adhered or mechanically fastened to deck | | RubberGard EcoWhite or EcoWhite Platinum | WBBA (P) | |
| 11 | А | Noncombustible | 11/2:12 | | Min. ¹ / ₄ -inch-thick DensDeck or DensDeck Prime, mechanically fastened to deck | RubberGard EcoWhite or EcoWhite Platinum | BA-2004 (T), EPDM Solvent Free Bonding Adhesive, Single-Ply LVOC Bonding Adhesive or WBBA (P) | |
| 12 | А | Noncombustible | ¹/ ₂ :12 | (Optional) Any UL- classified polyisocyanurate insulation | Min. ¹ / ₂ -inch-thick Firestone "ISOGARD HD" | RubberGard LS-FR, MAX, Platinum or RubberGard SA (when an adhesive is not used) | BA-2004 (T), EPDM Solvent Free Bonding Adhesive, Single-Ply LVOC Bonding Adhesive or WBBA (P) | (Optional) PC-100 Coating |
| 13 | А | Noncombustible | 1:12 | (Optional) Any UL- classified polyisocyanurate insulation | Same as System 12 | Fire Retardant RubberGard or EcoWhite | BA-2004 (T), EPDM Solvent Free Bonding Adhesive, Single-Ply LVOC Bonding Adhesive or WBBA (P) | (Optional) PC-100 Coating |
| 14 | А | Noncombustible | 21/2:12 | (Optional) Any UL- classified polyisocyanurate insulation | Same as System 12 | RubberGard MAX FR | BA-2004 (T), EPDM Solvent Free Bonding Adhesive, Single-Ply LVOC Bonding Adhesive or WBBA (P) | (Optional) PC-100 Coating |

TABLE 2—FIRE CLASSIFICATION ASSEMBLIES - ADHERED ROOFING SYSTEMS (CONTINUED)

| SYSTEM | ROOF | | MAX. | | BARRIER OR | МЕМ | BRANE ⁴ | |
|--------|-------|------------------------|-----------------------------------|-------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------|-----------------------------------------------------------------------|------------------------------|
| NO. | CLASS | SUBSTRATE ² | ROOF SLOPE | INSULATION ^{1,3} | COVER BD.4 | TYPE | ADHESIVE4 | SURFACING⁴ |
| 15 | А | Noncombustible | 2:12 | (Optional) Any UL- classified polyisocyanurate insulation | Same as System 12 | RubberGard Platinum | BA-2004 (T), Single-Ply LVOC Bonding Adhesive or WBBA (P) | PC-100 Coating |
| 16 | А | Combustible | ¹/ ₂ :12 | (Optional) Max. 4-inch-thick Firestone "ISO 95+GL" | Min. 1-inch-thick Firestone "ISOGARD HD" or "RESISTA", adhered or mechanically fastened to deck | RubberGard LS-FR, MAX, MAX FR, Platinum or EcoWhite | BA-2004 (T), Single-Ply LVOC Bonding Adhesive or WBBA (P) | (Optional) PC-100 Coating |
| 17 | А | Combustible | ¹/ ₂ :12 | 2-inch-thick, any UL- classified polyisocyanurate insulation, mechanically fastened to deck | | RubberGard EcoWhite | BA-2004 (T), Single-Ply LVOC Bonding Adhesive or WBBA (P) | |
| 18 | В | Combustible | ¹/ ₂ :12 | (Optional) Max. 4-inch-thick Firestone "ISO 95+GL" | Min. 1/2-inch-thick Firestone "ISOGARD HD" or "RESISTA", adhered or mechanically fastened to deck | RubberGard LS-FR, MAX, MAX FR, Platinum or EcoWhite | BA-2004 (T), Single-Ply LVOC Bonding Adhesive or WBBA (P) | (Optional) PC-100 Coating |
| 19 | В | Noncombustible | ¹/ ₂ :12 | Min. 1-inch-thick Firestone "ISO 95+ GL" (optional if a barrier board or coverboard is used) | -Min. ¹ / ₂ -inch-thick RESISTA adhered or mechanically fastened to deck (optional if insulation is used) | RubberGard EPDM SA | Self-Adhered | - |
| 20 | А | Combustible | 3:12 | + | Min. ¹ / ₄ -inch-thick DensDeck or DensDeck Prime, mechanically fastened to deck | RubberGard Platinum | BA-2004 (T) or Single-Ply LVOC Bonding Adhesive | (Optional) PC-100 Coating |
| 21 | А | Noncombustible | 1:12 | | Min. ⁷ / ₁₆ -inch-thick OSB, mechanically fastened to deck | RubberGard EcoWhite or EcoWhite Platinum | BA-2004 (T) or Single-Ply LVOC Bonding Adhesive | |
| 22 | А | Noncombustible | Unlimited | (Optional) Any UL- classified polyisocyanurate insulation | Min. ¹ / ₄ -inch-thick DensDeck or DensDeck Prime, ¹ / ₄ -inch-thick plywood or ⁷ / ₁₆ -inch-thick OSB, mechanically fastened to deck | RubberGard MAX FR | BA-2004 (T) or Single-Ply LVOC Bonding Adhesive | |
| 23 | А | Noncombustible | 3:12 | (Optional) Any UL- classified polyisocyanurate insulation | Same as System 22 | RubberGard MAX FR | WBBA (P) | |
| 24 | А | Noncombustible | 3:12 | (Optional) Any UL- classified polyisocyanurate insulation, adhered or mechanically fastened to deck | | RubberGard MAX FR | BA-2004 (T) or Single-Ply LVOC Bonding Adhesive | |
| 25 | Α | Noncombustible | 2 ¹ / ₂ :12 | Same as System 24 | | RubberGard MAX FR | WBBA (P) | |

For **SI**: 1 inch = 25.4 mm.

¹All foam plastic insulation must be UL-classified foam plastic for roofing systems, and must be limited to the maximum thickness noted in Section 5.4 of this report.

 $^{^2}$ Wood deck must be minimum $^{15}/_{32}$ -inch-thick (11.9 mm) plywood. Steel deck must be minimum No. 22 gage galvanized steel [0.030 inch (0.76 mm)]. Concrete must have a minimum compressive strength (f_c) of 2500 psi. [minimum of 24MPa is required under ADIBC Appendix L, Section 5.1.1].

³Polyisocyanurate insulation must comply with ASTM C1289.

⁴Barrier or cover boards, adhesives, membranes and surface coatings must be UL-classified for roofing systems. See Section 3.6 for adhesive application rates.

TABLE 3—FIRE CLASSIFICATION ASSEMBLIES - MECHANICALLY FASTENED ROOFING SYSTEMS

| SYSTEM NO. | ROOF CLASS | SUBSTRATE ² | MAX. ROOF SLOPE | INSULATION1,3 | BARRIER OR COVER BD. ⁴ | MEMBRANE ⁴ | SURFACING ⁴ |
|---------------|---------------|------------------------|-----------------------------------|-----------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------|------------------------------|
| 1 | А | Noncombustible | ¹/ ₂ :12 | (Optional) Any UL- classified polyisocyanurate insulation | Min. ¹ / ₂ -inch-thick Firestone "ISOGARD HD" or "RESISTA" | RubberGard MAX | (Optional) PC-100 Coating |
| 2 | Α | Noncombustible | ¹/ ₂ :12 | (Optional) Max. 4-inch-thick Firestone "ISO 95+GL" | 1 | RubberGard LS- FR, RubberGard LS-FR PT or Platinum | 1 |
| 3 | Α | Noncombustible | 2 ¹ / ₂ :12 | (Optional) Max. 4-inch-thick Firestone "ISO 95+GL" | 1 | RubberGard MAX FR | - |
| 4 | А | Noncombustible | 4:12 | (Optional) Any UL- classified polyisocyanurate insulation | Min. ¹ / ₄ -inch-thick DensDeck or DensDeck Prime, ¹ / ₄ -inch-thick plywood or ⁷ / ₁₆ -inch- thick OSB | RubberGard MAX FR | 1 |
| 5 | В | Combustible | ¹/ ₂ :12 | (Optional) Max. 4-inch-thick Firestone "ISO 95+GL" | Min. ¹ / ₂ -inch-thick Firestone "ISOGARD HD" or "RESISTA" | RubberGard LS- FR, MAX, MAX FR, Platinum | (Optional) PC-100 Coating |
| 6 | Α | Combustible | 2:12 | 1 ¹ / ₂ -inch-thick Firestone "ISO 95+GL" | Min. ¹ / ₄ -inch-thick DensDeck or DensDeck Prime | RubberGard MAX FR | |
| 7 | Α | Combustible | ¹/ ₂ :12 | 1.3-inch-thick Firestone "ISO 95+GL" | | RubberGard MAX FR | |

For **SI:** 1 inch = 25.4 mm.

¹All foam plastic insulation must be UL-classified foam plastic for roofing systems, and must be limited to the maximum thickness noted in Section 5.4 of this report.

²Wood deck must be minimum ¹⁵/₃₂-inch-thick (11.9 mm) plywood. Steel deck must be minimum No. 22 gage galvanized steel [0.030 inch (0.76 mm)]. Concrete must have a minimum compressive strength (f_c) of 2500 psi. [minimum of 24MPa is required under ADIBC Appendix L, Section 5.1.1]. ³Polyisocyanurate insulation must comply with ASTM C1289.

⁴Barrier or cover boards, membranes and surface coatings must be UL-classified for roofing systems.

TABLE 4A—WIND RESISTANCE - ADHERED ROOFING SYSTEMS - WOOD DECKS

| | | INSUL | ATION | COVER I | BOARD | MEN | /BRANE | ALLOWABLE |
|---------------|----------------------------------------------------------|-----------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------|-------------------------------------|
| SYSTEM NO. | DECK ³ | TYPE ^{1,2} | ATTACHMENT ¹ | TYPE ¹ | ATTACHMENT ¹ | TYPE | ATTACHMENT ¹ | WIND UPLIFT PRESSURE (psf) |
| W-1 | ¹⁹ / ₃₂ -inch- thick plywood | 1 | - 1 | ¹ / ₂ -inch-thick DensDeck Prime or SECUROCK Gypsum Fiber Roof Board | All-Purpose Fastener with Fastening Plate at 1 fastener per 1.6 ft ² | RubberGard EcoWhite or EcoWhite Platinum | BA-2004 (T) Bonding Adhesive or Single-Ply LVOC Bonding Adhesive 1168 at 60 ft² per gallon to substrate and underside of membrane | 45 |
| W-2 | ¹⁹ / ₃₂ -inch- thick plywood | 2-inch-thick Firestone "ISO 95+GL" | Heavy-Duty Fastener with Insulation Fastening Plate at 1 fastener per 1.78 ft² | | | RubberGard EcoWhite or EcoWhite Platinum | BA-2004 (T) Bonding Adhesive or Single-Ply LVOC Bonding Adhesive 1168 at 60 ft² per gallon to substrate and underside of membrane | 45 |
| W-3 | ¹⁵ / ₃₂ -inch thick plywood | Optional ¹ / ₄ -inch thick DensDeck Prime | I.S.O. STICK Adhesive in continuous ³ / ₄ - to 1-inch wide ribbons at 12 inches o.c. | Min. 1-inch thick "RESISTA" or "ISO 95+ GL" | I.S.O. STICK Adhesive in continuous ³ / ₄ - to 1-inch wide ribbons at 12 inches o.c. | RubberGard LS-FR, Fire Retardant RubberGard, RubberGard EcoWhite, RubberGard MAX, RubberGard MAX FR or RubberGard EPDM SA (when an adhesive is not used) | WBBA (P) or | 45 |

¹Insulation, barrier boards, cover boards, vapor barriers, adhesives and fasteners must be FM-approved.

²All foam plastic insulation must be limited to the maximum thickness in accordance with Section 5.4 of this report or the maximum thickness in accordance with this table, whichever is less. 3 Wood deck must be minimum $^{15}/_{32}$ -inch-thick (11.9 mm) plywood. See Section 5.7 of this report.

TABLE 4B—WIND RESISTANCE - ADHERED ROOFING SYSTEMS - STEEL DECKS

| OVOTEM | | INSU | LATION | cov | ER BOARD | МЕМІ | BRANE | ALLOWABLE |
|---------------|-------------------|-----------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------|
| SYSTEM NO. | DECK ³ | TYPE ^{1,2} | ATTACHMENT ¹ | TYPE ¹ | ATTACHMENT ¹ | TYPE | ATTACHMENT ¹ | WIND UPLIFT PRESSURE (psf) |
| S-1 | Steel | Min. 1.5-inch- thick to max. 4-inch-thick Firestone "ISO 95+GL" | Heavy-Duty or All- Purpose Fastener with Insulation Fastening Plate at 1 fastener per 2 ft ² | ¹ / ₂ -inch-thick "ISOGARD HD" or "RESISTA" | I.S.O. Twin-Pack Insulation Adhesive in continuous ¹ / ₂ - to ³ / ₄ -inch-wide beads at 12 inches o.c. | Any RubberGard membrane or RubberGard EPDM SA (when an adhesive is not used) | BA-2004 (T) Bonding Adhesive, Single- Ply LVOC Bonding Adhesive or Single-Ply LVOC Bonding Adhesive 1168 at 60 ft² per gallon to substrate and underside of membrane | 45 |
| S-2 | Steel | Min. 1.5-inch- thick to max. 4-inch-thick Firestone "ISO 95+GL" | Mechanically fastened per FM preliminary fastening requirements | ¹ / ₂ -inch-thick "ISOGARD HD" or "RESISTA" | Heavy-Duty or All- Purpose Fastener with Insulation Fastening Plate at 1 fastener per 2.7 ft ² | Any RubberGard membrane or RubberGard EPDM SA (when an adhesive is not used) | BA-2004 (T) Bonding Adhesive, Single- Ply LVOC Bonding Adhesive or Single-Ply LVOC Bonding Adhesive 1168 at 60 ft² per gallon to substrate and underside of membrane | 45 |
| S-3 | Steel | Min. 1.5-inch- thick to max. 4-inch-thick Firestone "ISO 95+GL" | All-Purpose Fastener with Insulation Fastening Plate at 1 fastener per 2 ft ² | - | - | RubberGard LS-FR, LS-FR PT, FR, MAX, MAX FR, MAX PT, or Platinum or RubberGard EPDM SA (when an adhesive is not used) | BA-2004 (T) Bonding Adhesive, Single- Ply LVOC Bonding Adhesive or Single-Ply LVOC Bonding Adhesive 1168 at 60 ft² per gallon to substrate and underside of membrane or EPDM Solvent Free Bonding Adhesive at 150 ft² per gallon to the substrate only | 45 |
| S-4 | Steel | Min. 1.5-inch- thick to max. 4-inch-thick Firestone "ISO 95+GL" | Heavy-Duty or All- Purpose Fastener with Insulation Fastening Plate at 1 fastener per 2.7 ft ² | Min. 1.5-inch- thick to max. 4-inch-thick Firestone "ISO 95+GL" | I.S.O. Twin-Pack Insulation Adhesive in continuous ¹ / ₂ - to ³ / ₄ -inch-wide ribbons at 12 inches o.c. | Any RubberGard membrane or RubberGard EPDM SA (when an adhesive is not used) | BA-2004 (T) Bonding Adhesive, Single- Ply LVOC Bonding Adhesive or Single-Ply LVOC Bonding Adhesive 1168 at 60 ft² per gallon to substrate and underside of membrane or EPDM Solvent Free Bonding Adhesive at 150 ft² per gallon to substrate only | 30 |
| S-5 | Steel | Min. 2-inch- thick to max. 4-inch-thick Firestone "ISO 95+GL" | Heavy-Duty or All- Purpose Fastener with Insulation Fastening Plate at 1 fastener per 4 ft ² | Min. 1.5-inch- thick to max. 4-inch-thick Firestone "ISO 95+GL" | I.S.O. Twin-Pack Insulation Adhesive in ¹ / ₂ - to ³ / ₄ -inch- wide ribbons at 12 inches o.c. | Any RubberGard membrane or RubberGard SA (when an adhesive is not used) | BA-2004 (T) Bonding Adhesive, Single- Ply LVOC Bonding Adhesive or Single-Ply LVOC Bonding Adhesive 1168 at 60 ft² per gallon to substrate and underside of membrane or EPDM Solvent Free Bonding Adhesive at 150 | 38 |

TABLE 4B—WIND RESISTANCE - ADHERED ROOFING SYSTEMS - STEEL DECKS

| 0)/07514 | | INSU | LATION | cov | ER BOARD | МЕМІ | BRANE (CONTIN | U ÆL OWABLE |
|---------------|-------------------|-----------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------|
| SYSTEM NO. | DECK ³ | TYPE ^{1,2} | ATTACHMENT ¹ | TYPE ¹ | ATTACHMENT ¹ | TYPE | ATTACHMENT ¹ | WIND UPLIFT PRESSURE (psf) |
| | | | | | | | ft ² per gallon to substrate only | |
| S-6 | Steel | Min. 1.5-inch- thick to max. 4-inch-thick Firestone "ISO 95+GL" | All-Purpose Fastener with Insulation Fastening Plate at 1 fastener per 2 ft ² | Min. ¹ / ₄ -inch- thick DensDeck or DensDeck Prime | I.S.O. Twin-Pack Insulation Adhesive in continuous ¹ / ₂ - to ³ / ₄ -inch-wide beads at 12 inches o.c. | RubberGard LS-FR, LS-FR PT, FR, MAX, MAX FR, MAX PT, Platinum, EcoWhite or EcoWhite Platinum or RubberGard EPDM SA (when no adhesive is used) | BA-2004 (T) Bonding Adhesive, Single- Ply LVOC Bonding Adhesive or Single-Ply LVOC Bonding Adhesive 1168 (DensDeck Prime only) at 60 ft² per gallon to substrate and underside of membrane or EPDM Solvent Free Bonding Adhesive at 150 ft² per gallon to the substrate only | 45 |
| S-7 | Steel | Min. 1.5-inch- thick to max. 4-inch-thick Firestone "ISO 95+GL" | All-Purpose Fastener with Insulation Fastening Plate at 1 fastener per 1.6 ft ² | Min. 1.5-inch- thick to max. 4-inch-thick Firestone "ISO 95+GL" | I.S.O. Twin-Pack Insulation Adhesive in continuous ¹ / ₂ - to ³ / ₄ -inch-wide beads at 12 inches o.c. | RubberGard LS- FR, LS-FR PT, FR, MAX, MAX FR, MAX PT, Platinum, EcoWhite or EcoWhite Platinum or RubberGard EPDM SA (when an adhesive is not used) | BA-2004 (T) Bonding Adhesive, Single- Ply LVOC Bonding Adhesive or Single-Ply LVOC Bonding Adhesive 1168 at 60 ft² per gallon to substrate and underside of membrane | 75 |
| S-8 | Steel | Min. 2-inch- thick to max. 4-inch-thick Firestone "ISO 95+GL" | All-Purpose Fastener with Insulation Fastening Plate at 1 fastener per 1.6 ft ² | 1 | | RubberGard LS- FR, LS-FR PT, FR, MAX, MAX FR, MAX PT, Platinum, EcoWhite or EcoWhite Platinum | BA-2004 (T) Bonding Adhesive, Single- Ply LVOC Bonding Adhesive or Single-Ply LVOC Bonding Adhesive 1168 at 60 ft² per gallon to substrate and underside of membrane | 82 |
| S-9 | Steel | 1.5-inch-thick Firestone "ISO 95+GL" | Loose-laid | Min. ¹ / ₄ -inch- thick DensDeck Prime | All-Purpose Fastener with Insulation Fastening Plate at 1 fastener per 2.1 ft ² | RubberGard EcoWhite or EcoWhite Platinum | WBBA (PS) at 120 ft² per gallon to substrate and underside of membrane | 30 |
| S-10 | Steel | 1.5-inch-thick Firestone "ISO 95+GL" | Loose-laid | Min. ¹ / ₄ -inch- thick DensDeck Prime | All-Purpose Fastener with Insulation Fastening Plate at 1 fastener per 1.8 ft ² | RubberGard EcoWhite or EcoWhite Platinum | BA-2004 (T) Bonding Adhesive, Single- Ply LVOC Bonding Adhesive or Single Ply LVOC Bonding Adhesive 1168 at 60 ft² per gallon to substrate and underside of membrane or EPDM Solvent Free Bonding Adhesive at 150 ft² per gallon to the substrate only | 45 |

TABLE 4B—WIND RESISTANCE - ADHERED ROOFING SYSTEMS - STEEL DECKS (CONTINUED)

| 0)/0==- | | INSU | LATION | COV | ER BOARD | MEM | BRANE | ALLOWABLE |
|---------------|-------------------|----------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------|-------------------|-------------------------|---------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------|
| SYSTEM NO. | DECK ³ | TYPE ^{1,2} | ATTACHMENT ¹ | TYPE ¹ | ATTACHMENT ¹ | TYPE | ATTACHMENT ¹ | WIND UPLIFT PRESSURE (psf) |
| S-11 | Steel | 1.5-inch-thick Firestone "ISO 95+GL" | Heavy-Duty or All- Purpose Fastener with Insulation Fastening Plate at 2.67 fastener per ft ² | - | - | Any RubberGard membrane or RubberGard EPDM SA (when an adhesive is not used) | BA-2004 (T) Bonding Adhesive at 45 ft² per gallon to substrate and underside of membrane or EPDM Solvent Free Bonding Adhesive at 150 ft² per gallon to the substrate only or Single-Ply LVOC Bonding Adhesive at 60 ft² per gallon to the substrate and underside of the membrane | 30 |
| S-12 | Steel | Min. 2-inch- thick to max. 4- inch-thick Firestone "ISO 95+GL" | Heavy-Duty or All- Purpose Fastener with Insulation Fastening Plate at 4 fastener per ft ² | - | - | Any RubberGard membrane or RubberGard EPDM SA (when an adhesive is not used) | BA-2004 (T) Bonding Adhesive at 60 ft² per gallon or WBBA (SP) at 120 ft² per gallon to substrate and underside of membrane or EPDM Solvent Free Bonding Adhesive at 150 ft² per gallon to the substrate only, or Single-Ply LVOC Bonding Adhesive 1168 or Single-Ply LVOC Bonding Adhesive at 60 ft² per gallon to substrate and underside of membrane | 45 |
| S-13 | Steel | Min. 2-inch- thick to max. 4- inch-thick Firestone "ISO 95+GL" | Heavy-Duty or All- Purpose Fastener with Insulation Fastening Plate at 1 fastener per ft ² | - | - | Any RubberGard membrane or RubberGard EPDM SA (when an adhesive is not used) | BA-2004 (T) Bonding Adhesive, Single- Ply LVOC Bonding Adhesive or Single-Ply Bonding Adhesive 1168 at 60 ft² per gallon to substrate and underside of membrane | 112 |

TABLE 4C—WIND RESISTANCE - ADHERED ROOFING SYSTEMS - STEEL DECKS WITH VAPOR BARRIER

| | | VAPO | R BARRIER | INS | ULATION | co | VERBOARD | MEM | BRANE | ALLOWABLE WIND |
|---------------|-------------------|-------------|-------------------------------------------------------------------------|---------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------|-------------------|-------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------|
| SYSTEM NO. | DECK ³ | TYPE | ATTACH- MENT | TYPE ^{1,2} | ATTACHMENT ¹ | TYPE ¹ | ATTACHMENT ¹ | TYPE | ATTACHMENT ¹ | UPLIFT PRESSURE (psf) |
| S-14 | Steel | V- Force | Self- adhered and fully bonded with 3" wide side laps | 1.5-inch thick Firestone "ISO 95+ GL" | I.S.O. Stick Adhesive in continuous ³ / ₄ to 1-inch wide ribbons at 12 inches o.c. | - | - | RubberGar d LS-FR, Fire Retardant RubberGar d EcoWhite, RubberGar d MAX, RubberGar d MAX FR or RubberGar d EPDM SA (when an adhesive is not used) | BA-2004 (T) Bonding Adhesive, Single-Ply LVOC Bonding Adhesive, Single-Ply LVOC Bonding Adhesive 1168 or WBBA (P) | 68 |
| S-15 | Steel | V- Force | Self- adhered and fully bonded with 3" wide side laps | 1.5-inch thick Firestone "ISO 95+ GL" | I.S.O. Twin Pack Insulation Adhesive in continuous ³ / ₄ to 1-inch wide ribbons at 12 inches o.c. | - | - | RubberGar d LS-FR, Fire Retardant RubberGar d EcoWhite, RubberGar d MAX, RubberGar d MAX FR or RubberGar d EPDM SA (when an adhesive is not used) | BA-2004 (T) Bonding Adhesive, Single-Ply LVOC Bonding Adhesive, Single-Ply LVOC Bonding Adhesive 1168 at 60 ft² per gallon to substrate and underside of membrane or WBBA (P) at 120 ft² per gallon to substrate and underside of membrane or WBBA (P) at | 83 |

¹Insulation, barrier boards, cover boards, vapor barriers, adhesives and fasteners must be FM-approved.

²All foam plastic insulation must be limited to the maximum thickness in accordance with Section 5.4 of this report or the maximum thickness in accordance with this table, whichever is less.

³Steel deck must be minimum No. 22 gage galvanized steel [0.030 inch (0.76 mm)]. See Section 5.7 of this report.

TABLE 4D—WIND RESISTANCE - ADHERED ROOFING SYSTEMS - STEEL DECKS WITH BARRIER BOARD

| | | BARRIE | ER BOARD | INS | ULATION | COVE | R BOARD | MEMI | BRANE | ALLOW- |
|----------------|-------|----------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------|
| SYSTE M NO. | DECK | TYPE | ATTACHMEN T | TYPE ^{1,2} | ATTACHMENT | TYPE ¹ | ATTACHMENT | TYPE | ATTACHMENT | ABLE WIND UPLIFT PRESSUR E (psf) |
| S-16 | Steel | Min. ¹ / ₄ - inch-thick DensDec k or DensDec k Prime | Heavy-Duty or All- Purpose Fastener with Insulation Fastening Plate at 1 fastener per 2 ft ² | Min. 1.5- inch- thick to max. 4-inch- thick Fireston e "ISO 95+GL" in 1 or 2 layers | I.S.O. Twin-Pack Insulation Adhesive in continuous 1/2- to 3/4- inch-wide ribbons at 12 inches o.c. or I.S.O. FIX II or I.S.O. STICK Adhesive in continuous 3/4- to 1- inch-wide ribbons at 12 inches o.c. | Min. 1/4- inch-thick DensDec k Prime | I.S.O. Twin-Pack Insulation Adhesive in continuous 1/2- to 3/4- inch-wide ribbons at 12 inches o.c. or I.S.O. FIX II or I.S.O. STICK Adhesive in continuous 3/4- to 1- inch-wide ribbons at 12 inches o.c. | Any RubberGar d membrane or RubberGar d EPDM SA (when an adhesive is not used) | BA-2004 (T) Bonding Adhesive, Single-Ply LVOC Bonding Adhesive or Single-Ply Bonding LVOC Bonding Adhesive 1168 at 60 ft² per gallon to substrate and underside of membrane or EPDM Solvent Free Bonding Adhesive at 150 ft² per gallon to the substrate only | 45 |

¹Insulation, barrier boards, cover boards, vapor barriers, adhesives and fasteners must be FM-approved.

²All foam plastic insulation must be limited to the maximum thickness in accordance with Section 5.4 of this report or the maximum thickness in accordance with this table, whichever is less.
³Steel deck must be minimum No. 22 gage galvanized steel [0.030 inch (0.76 mm)]. See Section 5.7 of this report.

TABLE 4E—WIND RESISTANCE - ADHERED ROOFING SYSTEMS - CONCRETE DECKS

| | | INSUL | ATION | COVE | R BOARD | МЕМ | BRANE | ALLOWABLE |
|---------------|-------------------|-------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------|
| SYSTEM NO. | DECK ³ | TYPE ^{1,2} | ATTACHMENT ¹ | TYPE ¹ | ATTACHMENT ¹ | TYPE | ATTACHMENT ¹ | WIND UPLIFT PRESSURE (psf) |
| C-1 | Concrete | Min. 1.5-inch-thick to max. 4-inch-thick Firestone "ISO 95+GL" | Full mopping of hot asphalt | Min. ¹ / ₄ -inch- thick DensDeck | Full mopping of hot asphalt | Any RubberGard membrane or RubberGard EPDM SA (when an adhesive is not used) | BA-2004 (T) Bonding Adhesive at 60 ft² per gallon to substrate and underside of membrane or EPDM Solvent Free Bonding Adhesive at 150 ft² per gallon to the substrate only | 165 |
| C-2 | Concrete | Min. 1.5-inch-thick to max. 4-inch-thick Firestone "ISO 95+GL" | Full mopping of hot asphalt | 1 | | Any RubberGard membrane or RubberGard EPDM SA (when an adhesive is not used) | BA-2004 (T) Bonding Adhesive or Single-Ply LVOC Bonding Adhesive 1168 at 60 ft² per gallon to substrate and underside of membrane or EPDM Solvent Free Bonding Adhesive at 150 ft² per gallon to the substrate only | 195 |
| C-3 | Concrete | Min. 1.5-inch-thick to max. 4-inch-thick Firestone "ISO 95+GL" | I.S.O. FIX II Adhesive in continuous ³ / ₄ - to 1- inch-wide ribbons at 12 inches o.c. | ¹ / ₂ -inch-thick "ISOGARD HD" or "RESISTA" | I.S.O. FIX II Adhesive in continuous ³ / ₄ - to 1-inch-wide ribbons at 12 inches o.c. | Any RubberGard membrane or RubberGard EPDM SA (when an adhesive is not used) | BA-2004 (T) Bonding Adhesive at 60 ft² per gallon or WBBA (P) at 120 ft² per gallon to substrate and underside of membrane or EPDM Solvent Free Bonding Adhesive at 150 ft²²°-3 per gallon to the substrate only or Single-Ply LVOC Bonding Adhesive 1168 at 60 ft² per gallon to substrate and underside of membrane | 278 |
| C-4 | Concrete | Min. 1.5-inch-thick to max. 4-inch-thick Firestone "ISO 95+GL" | I.S.O. Twin-Pack Adhesive in continuous ¹ / ₂ - to ³ / ₄ -inch-wide ribbons at 12 inches o.c. | ¹ / ₂ -inch-thick "ISOGARD HD" or "RESISTA" | I.S.O. FIX II Adhesive in continuous ¹/₂- to ³/₄-inch-wide ribbons at 12 inches o.c. | Any RubberGard membrane or RubberGard EPDM SA (when an adhesive is not used) | BA-2004 (T) Bonding Adhesive at 60 ft² per gallon, or WBBA (P) at 120 ft² per gallon to substrate and underside of membrane, or EPDM Solvent Free Bonding Adhesive at 150 ft² per gallon to the substrate only, or Single-Ply LVOC Bonding Adhesive 1168 at 60 ft² per gallon to substrate and underside of membrane | 248 |

TABLE 4E—WIND RESISTANCE - ADHERED ROOFING SYSTEMS (CONTINUED)

| SYSTEM NO. | DECK ³ | INSULATION | | COVER BOARD | | MEMBRANE | | ALLOWABLE |
|---------------|-------------------|---------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------|
| | | TYPE ^{1,2} | ATTACHMENT ¹ | TYPE ¹ | ATTACHMENT ¹ | TYPE | ATTACHMENT ¹ | WIND UPLIFT PRESSURE (psf) |
| C-5 | Concrete | Min. 1.5-inch- thick to max. 4- inch-thick Firestone "ISO 95+GL" | I.S.O. STICK Adhesive in continuous ³ / ₄ - to 1-inch-wide ribbons at 12 inches o.c. | Min. ¹ / ₄ -inch- thick DensDeck or DensDeck Prime | I.S.O. STICK Adhesive in continuous ³ / ₄ - to 1-inch-wide ribbons at 12 inches o.c. | Any RubberGard membrane or RubberGard EPDM SA (when an adhesive is not used) | BA-2004 (T) Bonding Adhesive or Single-Ply LVOC Bonding Adhesive 1168 at 60 ft² per gallon to substrate and underside of membrane or EPDM Solvent Free Bonding Adhesive at 150 ft² per gallon to the substrate only | 232 |
| C-6 | Concrete | Min. 1.5-inch- thick Firestone "ISO 95+GL" Followed by an optional layer of Min. 1.5-inch- thick Firestone "ISO 95+GL" | I.S.O. Twin-Pack Adhesive in continuous ¹ / ₂ - to ³ / ₄ -inch wide ribbons at 12 inches o.c. or I.S.O. STICK Adhesive or I.S.O. FIX II Adhesive applied to the substrate in continuous ³ / ₄ - to 1-inch wide ribbons at 12 inches o.c. | Min. ¹ / ₄ -inch- thick DensDeck Prime | I.S.O. Twin-Pack Adhesive in continuous ¹ / ₂ - to ³ / ₄ -inch wide ribbons at 12 inches o.c. or I.S.O. STICK Adhesive or I.S.O. FIX II Adhesive applied to the substrate in continuous ³ / ₄ - to 1-inch wide ribbons at 12 inches o.c. | RubberGard LS-FR, RubberGard LS-FR PT, Platinum, RubberGard MAX FR, RubberGard MAX, PT, Fire Retardant RubberGard, Rubbergard EcoWhite | Single-Ply LVOC Bonding Adhesive 1168 at 60 ft ² per gallon to substrate and underside of membrane | 262.5 |
| C-7 | Concrete | Min. 1.5-inch- thick to max. 4- inch-thick Firestone "ISO 95+GL" | I.S.O. STICK Adhesive in continuous ³ / ₄ - to 1-inch-wide ribbons at 12 inches o.c. | | | Any RubberGard membrane or RubberGard EPDM SA (when an adhesive is not used) | BA-2004 (T) Bonding Adhesive at 60 ft² per gallon to substrate and underside of membrane or EPDM Solvent Free Bonding Adhesive at 150 ft² per gallon to the substrate only | 270 |

TABLE 4E—WIND RESISTANCE - ADHERED ROOFING SYSTEMS (CONTINUED)

| SYSTEM NO. | DECK ³ | INSULATION | | COVER BOARD | | MEMBRANE | | ALLOWABLE |
|---------------|------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------|
| | | TYPE ^{1,2} | ATTACHMENT ¹ | TYPE ¹ | ATTACHMENT ¹ | TYPE | ATTACHMENT ¹ | WIND UPLIFT PRESSURE (psf) |
| C-8 | Concrete | Min. 1.5-inch- thick to max. 4- inch-thick Firestone "ISO 95+GL" | I.S.O. STICK Adhesive in continuous ³ / ₄ - to 1-inch-wide ribbons at 12 inches o.c. | ¹ / ₂ -inch-thick "ISOGARD HD" or "RESISTA" | I.S.O. STICK Adhesive in continuous ³ / ₄ - to 1-inch-wide ribbons at 12 inches o.c. | Any RubberGard membrane or RubberGard EPDM SA (when an adhesive is not used) | BA-2004 (T) Bonding Adhesive or Single-Ply LVOC Bonding Adhesive 1168 (RESISTA only) at 60 ft² per gallon to substrate and underside of membrane or EPDM Solvent Free Bonding Adhesive at 150 ft² per gallon to the substrate only | 322 |
| C-9 | Concrete | Min. 1-inch thick Firestone "RESISTA" followed by optional layer of min. 1-inch thick Firestone "RESISTA" | I.S.O. Twin-Pack Adhesive in continuous ¹ / ₂ - to ³ / ₄ -inch wide ribbons at 12 inches o.c. or I.S.O. STICK Adhesive or I.S.O. FIX II Adhesive applied to the substrate in continuous ³ / ₄ - inch to 1-inch wide ribbons at 12 inches o.c. | - | - | RubberGard LS-FR, RubberGard LS-FR PT, RubberGard Platinum, RubberGard MAX, RubberGard MAX FR, RubberGard MAX PT, RubberGard EcoWhite, Fire Retardant RubberGard | Single-Ply LVOC Bonding Adhesive 1168 at 60 ft² per gallon to substrate and underside of membrane | 450 |
| C-10 | Concrete | Min. 1.5-inch- thick to max. 4- inch-thick Firestone "ISO 95+GL" | I.S.O. Twin-Pack Adhesive in ¹ / ₂ - to ³ / ₄ -inch wide ribbons at 12 inches o.c. | - | - | Any RubberGard membrane or RubberGard EPDM SA (when an adhesive is not used) | BA-2004 (T) Bonding Adhesive at 60 ft² per gallon to substrate and underside of membrane or EPDM Solvent Free Bonding Adhesive at 150 ft² per gallon to substrate only | 390 |
| LC | Lightweight concrete, min. 160 psi | Min. 1.5-inch-thick to max. 4-inch-thick Firestone "ISO 95+GL", Hunter Panels "H-Shield" or Atlas Roofing Corp. "ACFoam-II" | Olympic Fasteners "OlyBond 500" in continuous ³ / ₄ - to 1-inch-wide ribbons at 12 inches o.c. | Min. ¹ / ₄ -inch- thick DensDeck or DensDeck Prime | Olympic Fasteners "OlyBond 500" in continuous ³ / ₄ - to 1-inch- wide ribbons at 12 inches o.c. | Any RubberGard membrane or RubberGard EPDM SA (when an adhesive is not used) | BA-2004 (T) Bonding Adhesive or Single-Ply LVOC Bonding Adhesive 1168 at 60 ft² per gallon to substrate and underside of membrane | 225 |

¹Insulation, barrier boards, cover boards, vapor barriers, adhesives and fasteners must be FM-approved.

²All foam plastic insulation must be limited to the maximum thickness in accordance with Section 5.4 of this report or the maximum thickness in accordance with this table, whichever is less.

 $^{^{3}}$ Concrete must have a minimum compressive strength (f_{c}) of 2500 psi [minimum of 24MPa is required under ADIBC Appendix L, Section 5.1.1], unless otherwise noted. See Section 5.7 of this report.

TABLE 4F—WIND RESISTANCE - ADHERED ROOFING SYSTEMS - CEMENTITIOUS WOOD FIBER DECKS

| SYSTEM NO. | DECK ³ | INSULATION | | COVERBOARD | | MEMBRANE | | ALLOWABLE WIND |
|---------------|------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------|
| | | TYPE ^{1,2} | ATTACHMENT ¹ | TYPE ¹ | ATTACHMENT ¹ | TYPE | ATTACHMENT ¹ | UPLIFT PRESSURE (psf) |
| CWF | "Tectum I" cementitious wood fiber | Min. 1.5-inch-thick to max. 4-inch-thick Firestone "ISO 95+GL", Hunter Panels "H-Shield" or Atlas Roofing Corp. "ACFoam-II" | Olympic Fasteners "OlyBond 500" in continuous ³ / ₄ - to 1-inch- wide ribbons at 12 inches o.c. | Min. ¹ / ₄ - inch-thick DensDeck or DensDeck Prime | Olympic Fasteners "OlyBond 500" in continuous ³ / ₄ - to 1-inch- wide ribbons at 12 inches o.c. | Any RubberGard membrane or RubberGard EPDM SA (when an adhesive is not used) | BA-2004 (T) Bonding Adhesive or Single-Ply LVOC Bonding Adhesive 1168 at 60 ft ² per gallon to substrate and underside of membrane | 45 |

For SI: 1 inch = 25.4 mm; 1 ft = 0.305 m; 1 psf = 47.88 Pa; 1 gal = 3.785 L.

TABLE 5—WIND RESISTANCE - MECHANICALLY FASTENED ROOFING SYSTEMS

| SYSTEM NO | | INSUL | ATION | ME | ALLOWABLE | |
|--------------|-------------------|------------------------------------------------------------------------------|-----------------------------------------------------------------------------|--------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------|
| | DECK ³ | TYPE ^{1,2} | ATTACHMENT ¹ | TYPE | ATTACHMENT ¹ | WIND UPLIFT PRESSURE (psf) |
| MW-1 | Wood | Min. 1.5-inch-thick, any UL- classified polyisocyanurate insulation | Mechanically fastened per FM preliminary fastening requirements | RubberGard MAX, MAX FR or MAX PT | QuickSeam R.M.A. Strip At 9 ft-6 inches o.c., with Polymer Batten Bar and All- Purpose Fasteners at 6 inches along the batten bar | 45 |
| MSC-1 | Steel or concrete | Min. 1.5-inch-thick, any UL- classified polyisocyanurate insulation | Mechanically fastened per FM preliminary fastening requirements | RubberGard MAX, MAX FR or MAX PT | Heavy-Duty Fastener or All- Purpose Fastener (on steel deck only) with V-Plate at 6 inches o.c. within the roof cover 7-inch laps, in rows 7 ft o.c. | 52 |
| MS-1 | Steel | Min. 1.5-inch-thick, any UL- classified polyisocyanurate insulation | Mechanically fastened per FM preliminary fastening requirements | RubberGard LS-FR, LS-FR PT, FR or Platinum | QuickSeam R.M.A. Strip At 7 ft o.c., with Coiled Metal Batten Bar and All-Purpose Fasteners at 6 inches along the batten bar | 30 |
| MS-2 | Steel | Min. 1.5-inch-thick, any UL- classified polyisocyanurate insulation | Mechanically fastened per FM preliminary fastening requirements | RubberGard MAX, MAX FR or MAX PT | Coiled Metal Batten Bar and Heavy-Duty Fastener at 6 inches o.c. within the roof cover 7-inch laps, in rows 7 ft o.c. | 38 |
| MS-3 | Steel | Min. 1.5-inch-thick, any UL- classified polyisocyanurate insulation | Mechanically fastened per FM preliminary fastening requirements | RubberGard LS-FR, LS-FR PT, FR or Platinum | QuickSeam R.M.A. Strip At 6 ft o.c., with Coiled Metal Batten Bar and Heavy-Duty Fasteners at 12 inches along the batten bar | 38 |
| MS-4 | Steel | Min. 1.5-inch-thick, any UL- classified polyisocyanurate insulation | Mechanically fastened per FM preliminary fastening requirements | RubberGard MAX, MAX FR or MAX PT | Coiled Metal or Polymer Batten Bar and Heavy-Duty or All-Purpose Fastener at 6 inches o.c. within the roof cover 6-inch wide side laps, and in rows 7 ft o.c. | 52 |

¹Insulation, barrier boards, cover boards, vapor barriers, adhesives and fasteners must be FM-approved.

²All foam plastic insulation must be limited to the maximum thickness in accordance with Section 5.4 of this report or the maximum thickness in accordance with this table, whichever is less.

 $^{^{3}}$ Concrete must have a minimum compressive strength (f_{c}) of 2500 psi [minimum of 24MPa is required under ADIBC Appendix L, Section 5.1.1], unless otherwise noted. See Section 5.7 of this report.

¹Insulation, adhesives and fasteners must be FM-approved.

²All foam plastic insulation must be limited to the maximum thickness in accordance with Section 5.4 of this report or the maximum thickness in accordance with this table, whichever is less.

³Wood deck must be minimum ¹⁵/₃₂-inch-thick (11.9 mm) plywood. Steel deck must be minimum No. 22 gage galvanized steel [0.030 inch (0.76 mm)]. Concrete must have a minimum compressive strength (f_c) of 2500 psi, unless otherwise noted. See Section 5.7 of this report.



ICC-ES Evaluation Report

ESR-3026 CBC Supplement

Issued April 2021

This report is subject to renewal April 2022.

www.icc-es.org | (800) 423-6587 | (562) 699-0543

A Subsidiary of the International Code Council®

DIVISION: 07 00 00—THERMAL AND MOISTURE PROTECTION Section: 07 53 23—Ethylene-Propylene-Diene-Monomer Roofing

REPORT HOLDER:

FIRESTONE BUILDING PRODUCTS COMPANY, LLC

EVALUATION SUBJECT:

FIRESTONE RUBBERGARD EPDM SINGLE-PLY ROOFING MEMBRANES

1.0 REPORT PURPOSE AND SCOPE

Purpose:

The purpose of this evaluation report supplement is to indicate that the Firestone RubberGard EPDM single-ply roofing membranes, described in ICC-ES evaluation report ESR-3026, have also been evaluated for compliance with the code noted below.

Applicable code edition:

2019 California Building Code (CBC)

For evaluation of applicable chapters adopted by the California Office of Statewide Health Planning and Development (OSHPD) and Division of State Architect (DSA), see Sections 2.1.1 and 2.1.2 below.

2.0 CONCLUSIONS

2.1 CBC:

The Firestone RubberGard EPDM single-ply roofing membranes, described in Sections 2.0 through 7.0 of the evaluation report ESR-3026, comply with CBC Chapter 15, provided the design and installation are in accordance with the 2018 *International Building Code*® (IBC) provisions noted in the evaluation report and the additional requirements of CBC Chapter 15, as applicable.

- **2.1.1 OSHPD:** The applicable OSHPD Sections of the CBC are beyond the scope of this supplement.
- 2.1.2 DSA: The applicable DSA Sections of the CBC are beyond the scope of this supplement.

This supplement expires concurrently with the evaluation report, reissued April 2021.

