



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION
NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599
www.miamidade.gov/economy

GAF
1 Campus Drive
Parsippany, NJ 07054

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami-Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (in Miami-Dade County) and/or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Drill-Tec™ Roofing Fastener Assemblies

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews and revises NOA No. 18-0308.04 and consists of pages 1 through 12.
The submitted documentation was reviewed by Jorge L. Acebo.



NOA No.: 23-0313.08
Expiration Date: 04/17/24
Approval Date: 04/06/23
Page 1 of 12

ROOFING COMPONENT APPROVAL

Category: Roofing
Sub-Category: Roofing Fastener
Material: Steel

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT

FASTENERS: *Manufactured at Location #1*

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
Drill-Tec™ #14 HD Fastener	#14 x 12" max. length	TAS 114 TAS 117	Carbon steel screw with #3 phillips drive, modified truss head for use in steel, wood or concrete decks. TruKote epoxy coating.
Drill-Tec™ #15 EHD Fastener	#15 x 24" max. length	TAS 114 TAS 117	Carbon steel screw with #3 phillips drive, modified truss head for use in steel, wood or concrete decks. TruKote epoxy coating.
Drill-Tec™ #12 DP Fastener	#12 x 8" max. length	TAS 114 TAS 117	Carbon steel screw with #3 phillips drive, modified truss head for use in steel or wood decks. TruKote epoxy coating.
Drill-Tec™ #12 Purlin Fastener	#12 x 8-3/4" max. length	TAS 114 TAS 117	Carbon steel screw with #3 square drive, modified truss head and long pilot-point for use in min. 18 ga. steel purlin. TruKote epoxy coating.
Drill-Tec™ LDE Fastener	0.250" thread dia. x 4 1/4" max. length. To be used in combination with Drill-Tec™ LDE Plate.	TAS 114 TAS 117	Carbon steel screw with #2 phillips drive, modified truss head for use in lightweight insulating concrete decks and various poured gypsum decks. TruKote epoxy coating.

FASTENERS: *Manufactured at Location #2*

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
Drill-Tec™ Base Sheet Fastener (1.2 in.)	2.7" head 1.2" long	TAS 114 TAS 117	Two piece factory assembled base ply fastener/plate unit with dual gripping shanks and integral rib reinforced Galvalume stress distribution plate, formed from 0.013" thick G-90 galvanized steel or cold rolled steel that is coated with a black urethane coating. For use in lightweight insulating concrete, NVS concrete and various poured gypsum decks.
Drill-Tec™ Base Sheet Fastener (1.7 in.)	2.7" head 1.7" long	TAS 114 TAS 117	Two piece factory assembled base ply fastener/plate unit with dual gripping shanks and integral rib reinforced Galvalume stress distribution plate, formed from 0.013" thick G-90 galvanized steel or cold rolled steel that is coated with black urethane coating. For use in lightweight insulating concrete decks and various poured gypsum decks.
Drill-Tec™ Locking Impact Nail	2.7" head 1.4" long, 1.8" long, 2.8" long, 3.8" long, 4.8" long	TAS 114 TAS 117	Three piece factory assembled fastener/plate unit. Tube formed from .030" thick AZ-55 Galvalume or G-90 galvanized steel. A 2.7" diameter disk formed from .018" AZ-55 Galvalume steel is factory assembled to each fastener. Locking staple formed from .080" stainless steel or coated steel is factory assembled into tube. For base sheet and insulation attachment to new or existing cementitious wood fiber, poured gypsum and lightweight insulating concrete decks.



PLATES: *Manufactured at Location #1*

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
Drill-Tec™ 3” Flat Steel Plate	3” Round with reinforcing ribs	TAS 114 TAS 117	Galvalume steel stress plate for use with Drill-Tec™ Fasteners.
Drill-Tec™ LDE Plate	3” Round with reinforcing ribs	TAS 114 TAS 117	Galvalume steel stress plate for use with Drill-Tec™ LDE Fasteners.
Drill-Tec™ PVC IW Plate	3” Round	TAS 114 TAS 117	Galvalume steel stress plate for use with Drill-Tec™ Fasteners and PVC membranes.
Drill-Tec™ TPO IW Plate	3” Round	TAS 114 TAS 117	Galvalume steel stress plate for use with Drill-Tec™ Fasteners and TPO membranes.
Drill-Tec™ 3” Recessed Steel Plate	3” Round with reinforcing ribs and recessed center hole.	TAS 114 TAS 117	Galvalume steel stress plate for use with Drill-Tec™ Fasteners.
Drill-Tec™ 2.4” Barbed Seam Plate	2.4” Round with reinforcing ribs and barbs	TAS 114	Galvalume steel stress plate for use with Drill-Tec™ Fasteners.
Drill-Tec™ Barbed Scoop Plate	2.4” Round with reinforcing ribs and barbs	TAS 114	Galvalume steel stress plate for use with Drill-Tec™ Fasteners.

PRE-ASSEMBLED SYSTEMS: *Manufactured at Location #1*

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
Drill-Tec™ 3” ASAP Flat	See components above	TAS 114 TAS 117	Preassembled Drill-Tec™ #12 DP Fastener with Drill-Tec™ 3” Flat Steel Plates.

MANUFACTURING LOCATIONS:

1. Bryan, OH.
2. Holland, MI.



EVIDENCE SUBMITTED:

<u>Test Agency/Identifier</u>	<u>Name</u>	<u>Report</u>	<u>Date</u>
Factory Mutual	Pull Out/Shear Data	1G1A6.AM	3/26/82
Research Corporation	Pull Out/Shear Data	1H2A0.AM	5/26/83
	Pull Out/Shear Data	0J9A1.AM	7/11/85
	Pull Out/Shear Data	0N0A7.AM	5/9/86
	Pull Out/Shear Data	0N0A8.AM	10/7/86
	Corrosion Resistance	0P0Q8.AM	3/9/89
	Pull Out/Shear Data	1Q2A2.AM	10/27/89
	Wind Uplift	0R0Q1.AM	03/22/91
	Wind Uplift	1V1A9.AM	07/12/91
	Standard 4470	0V8A3.AM	11/13/91
	Standard 4470	1V9A8.AM	02/25/92
	Wind Uplift	0W2A0.AM	03/19/92
	Pull Out/Shear Data	0V7A4.AM	6/10/92
	Wind Uplift	1W5A2.AM	10/05/92
	Wind Uplift	0W4A1.AM	01/04/93
	Corrosion Resistance	0W4A1.AM	01/07/93
	Testing of Loc-Nails		
	Pull Out/Shear Data	1W7A7.AM	3/17/93
	1994 FMRC APPROVAL GUIDE	18-134	1/94
	Standard 4470	3W3A5.AM	01/27/94
	Corrosion Resistance	3031797	05/19/08
	FM 4470	3040205	06/08/10
	FM 4470	PR449339	06/01/18
	FM 4470	3059661	09/21/18
	FM 4470	PR451160	03/12/20
Exterior Research & Design, LLC.	TAS 117(A), (B) & (C)	#4670.07.97-1	07/20/97
	TAS 117 (A), (B) & (C)	#4712.02.98-1	12/15/98
Trinity ERD	TAS 117(A) & (B)	#EO8950.04.08	04/17/08
	TAS 117 (A), (B) & (C)	2011.A35880.04.12-R1	04/03/12
	TAS 117 (A) & (B)	E41800.10.12	10/18/12
NEMO etc.	TAS 117 (A) & (B)	4-AB-18-001.05.18	05/08/18
	TAS 117 (A)	4S-AB-18-001.08.18	08/01/18
Trinity Engineering, Inc.	Dynamic Pull Through TAS 117(B)	#4670.10.95-1	10/01/95
PRI Construction Materials Technologies	TAS 114	ESP-001-02-01	01/23/12
			02/20/12



TYPICAL PROPERTIES:

Note: A 2 to 1 margin of safety has been applied to test results producing the design values noted herein.

Withdrawal Resistance Performance - TAS 117(A) - Static Load			
<u>Fastener</u>	<u>Deck Type</u>	<u>min. Penetration / Embedment</u>	<u>Static Withdrawal Resistance (lbf)</u>
Drill-Tec™ #12 DP Fastener	Min. 19/32" plywood	3/4"	278.0
	Min. 22 ga., 50ksi steel	3/4"	232.0
Drill-Tec™ #14 HD Fastener	Min. 19/32" plywood	3/4"	273.0
	Min. 22 ga., 50ksi steel	3/4"	261.0
	2,500 – 3,000 psi concrete	1"	297.0
Drill-Tec™ #15 EHD Fastener	Min. 19/32" plywood	3/4"	314.0
	Min. 22 ga., 50ksi steel	3/4"	353.0
	2,500 – 3,000 psi concrete	1"	417.0
Drill-Tec™ #12 Purlin Fastener	Structural Steel (1/8")	1"	987.0
	Structural Steel (1/4")	1"	1877.0

Withdrawal Resistance Performance - TAS 117(A) - Static Load			
<u>Fastener</u>	<u>Deck Type</u>	<u>Static Withdrawal Resistance (lbf)</u>	
Drill-Tec™ LDE Fastener	Min. 348 psi cellular Lightweight concrete	3 day cure 108.0	28 day cure 86.0
	Poured gypsum	71.5	
Drill-Tec™ Base Sheet Fastener E (1.2 in.)	Poured gypsum	30.0	
Drill-Tec™ Base Sheet Fastener E (1.7 in.)	Min. 200 psi cellular Lightweight concrete	3 day cure 32.1	28 day cure 53.5
	Min. 200 psi aggregate lightweight concrete	3 day cure 39.9	28 day cure 77.3
Drill-Tec™ Locking Impact Nail	Poured gypsum	131.4	
Drill-Tec™ Locking Impact Nail	Cementitious wood fiber	176.2	

Withdrawal Resistance Performance - TAS 117(A) - Pulsating Load			
<u>Fastener</u>	<u>Deck Type</u>	<u>min. Penetration / Embedment</u>	<u>Pulsating Load (lbf)</u>
Drill-Tec™ #12 DP Fastener	Min. 19/32" plywood	3/4"	220.0
	Min. 22 ga., 50ksi steel	3/4"	127.0
Drill-Tec™ #14 HD Fastener	Min. 19/32" plywood	3/4"	165.0
	Min. 22 ga., 50ksi steel	3/4"	156.0
	2,500 – 3,000 psi concrete	1"	263.0
Drill-Tec™ #15 EHD Fastener	Min. 19/32" plywood	3/4"	252.0
	Min. 22 ga., 50ksi steel	3/4"	239.0
	2,500 – 3,000 psi concrete	1"	325.0
Drill-Tec™ #12 Purling Fastener	Structural Steel (1/8")	1"	969.0
	Structural Steel (1/4")	1"	1750.0



Withdrawal Resistance Performance - TAS 117(A) - Pulsating Load		
<u>Fastener</u>	<u>Deck Type</u>	<u>Pulsating Load (lbf)</u>
Drill-Tec™ LDE Fastener	Min. 348 psi cellular Lightweight concrete	28 day cure – 88.5
	Poured gypsum	28 day cure – 74.0
Drill-Tec™ Base Sheet Fastener E (1.2 in.)	Poured gypsum	25.8
Drill-Tec™ Base Sheet Fastener E (1.7 in.)	Min. 200 psi cellular lightweight concrete	28 day cure – 42.9
	Min. 200 psi aggregate lightweight concrete	28 day cure – 66.3
Drill-Tec™ Locking Impact Nail	Poured gypsum	<u>98.0</u>
Drill-Tec™ Locking Impact Nail	Cementitious wood fiber	105.0

Base Sheet Rupture Performance - TAS 117(B) Drill-Tec™ LDE Plate		
<u>Manufacturer</u>	<u>Base Sheet</u>	<u>Typical Results (lbf)</u>
GAF	GAFGLAS #75	73.5
Soprema	SOPRAFIX BASE 613 (Straight Pull)	164.5
	SOPRAFIX BASE 613 (Within 5” wide, torched-lap)	213.5
Tremco	POWERply Heavy Duty Base Sheet (Straight Pull)	233.5
	POWERply Heavy Duty Base Sheet (Within 5” wide, PEBA sealed lap)	287.0

Base Sheet Rupture Performance - TAS 117(B) Drill-Tec™ 2.4” Barbed Seam Plate, Drill-Tec™ 2.4” Barbed Scoop Plate		
<u>Manufacturer</u>	<u>Base Sheet</u>	<u>Typical Results (lbf)</u>
CertainTeed	Flintlastic Poly SMS Base Sheet	197.0
Johns Manville	DynaLastic 180 S	326.0
Soprema	Soprafix [S]	358.0



Base Sheet Rupture Performance - TAS 117(B)
Drill-Tec™ 3” Flat Steel Plate & Drill-Tec™ 3” Recessed Steel Plate

<u>Manufacturer</u>	<u>Base Sheet</u>	<u>Typical Results (lbf)</u>
Generic	ASTM D 226, Type II	112.0
CertainTeed	Glasbase Base Sheet	77.5
	Flexiglas Base Sheet	126.5
	All Weather/ Empire Base Sheet	107.5
	Flintlastic 20 Base	151.5
	Flintlastic Poly SMS Base	186.0
	Yosemite Venting Base Sheet	124.0
	Flintlastic SA Nailbase	139.0
Firestone	MB Base M	101.0
	Venting Base	113.5
	SBS Base	135.0
GAF	GAFGLAS #75 Base Sheet	92.0
	GAFGLAS #80 Ultima Base Sheet	76.0
	GAFGLAS Stratavent Eliminator (nailable)	77.5
	FlexPly 6	104.5
	Liberty MA Mechanically Attached Base	150.0
Garland	HPR Glasbase	102.0
	HPR Premium Glasbase	112.0
	HPR Tri-Base Plus	231.5
Johns Manville	PermaPly 28	92.5
	Ventsulation	129.0
	GlasPly Premier	108.0
	DynaBase	133.0
	JM APP Base	104.0
Derbigum	PRS Glass Base	114.0
	PRS Modified Base Sheet	115.0
	PRS Vented Base	101.0
	Derbibase	120.5
	Derbibase Ultra	116.0
Siplast	Parabase	125.5
	Parabase Plus	127.0
Soprema	Sopra-G	103.5
	Modified Sopra-G	108.0
	Soprabase	190.0
Tamko	Glass-Base	92.5
	Vapor-Chan	121.0
US Ply	USP Base	115.0
	USP NVB	101.0
	DuraFlex 30 SBS Base	100.0
	DuraFlex 60 SBS Base	165.0
	DuraFlex SBS Polybase	184.0



Base Sheet Rupture Performance, TAS 117(B):					
Drill-Tec™ Locking Impact Nail					
Manuf.	Base Sheet	Rupture Value (lbs.)	Manuf.	Base Sheet	Rupture Value (lbs.)
Honeywell	Black Armor base Sheet	109.0	Johns Manville	Dynabase	151.0
Bitec	Beta Base	120.0		Vestulation	114.0
CertainTeed	Glasbase	90.0		Perma Ply-28	138.0
	Flex-I-Glas Base	120.0	Siplast	Parabase	109.0
	Flex-I-Glas All Weather Empire Base	125.0		Parabase Plus	140.0
Firestone	MB Base	128.0	Soprema	Sopra-G	123.0
GAF	GAFGLAS Stratavent	119.0		Modified Sopra-G	103.0
	GAFGLAS Stratavent perforated	97.0	Tamko	Glass-Base	117.0
	GAFGLAS #75	117.0		Vapor-Chan	158.0
WP Hickman	Multiply glass	133.0		Base-N-Ply	103.0
	Multiply glass CL	191.0	N/A	N/A	

Base Sheet Rupture Performance, TAS 117(B):					
Drill-Tec™ Base Sheet Fastener E (1.2 in.) or Drill-Tec™ Base Sheet Fastener E (1.7 in.)					
Manuf.	Base Sheet	Rupture Value (lbf)	Manuf.	Base Sheet	Rupture Value (lbf)
Honeywell	Glass Fiber Base Sheet	84.0	Johns Manville	Glasbase	103.0
	Vented Base Sheet	85.0		Dynabase	104.0
Celotex	Channel Vent GB	95.0		Ventsulation	109.0
	Vaporbar GB	92.0	Siplast	Parabase	101.0
	Hydrostop	102.0		Parabase Plus	100.0
Firestone	MB Base	88.0	Soprema	Sopra-G	103.0
GAF	GAFGLAS #75	103.0		Elastophene 180	107.0
	Stratavent	89.0		Sopralene 180	115.0
CertainTeed	Flex-I-Glas Base	106.0	Tamko	Nail Fast	99.0
	PolySMS	111.0		Versa Base	106.0
Koppers	Glass Fiber Base	108.0	Tremco	BURmastic Glass Ply	114.0
	Organic Base	94.0		BURmastic Composite Ply	114.0
Malarkey	#501	110.0	U.S. Intec	Ultra Base	95.0.0
	#602	107.0		Flex Base	111.0
	#603	114.0		Modified Base	111.0
	#605	109.0		Permavent	117.0
Nord	NBS G-2 Base	102.0	W.P Hickman	Multi Ply	112.0
	Nordstar Base	110.0		Performance Ply	113.0
	N/A	N/A		Pika Ply SS-2	116.0

Notes:

1. The physical properties listed above are presented at typical average values as determined by accepted ASTM test methods and Miami-Dade Protocols and are subject to normal manufacturing variation.
2. A 2 to 1 margin of safety has been applied to test results providing the above noted design values.



APPROVED APPLICATIONS:

Tradename:	Drill-Tec™ #12 DP Fastener
Compatible Plate(s):	Drill-Tec™ 3” Flat Steel Plate and proprietary seam and fastening assembly plates listed in the specific Roof Assembly, Notice of Acceptance.
Generic Insulation Types:	Polyisocyanurate, Fiber Glass, Perlite, Rockwool, High Density Wood Fiber, Polystyrene, Urethane/Perlite Composite, Gypsum Cover Boards.
Application:	Mechanical attachment of roof insulation. See specific Roof Assembly Notice of Acceptance for fastener density and approved attachment patterns.
Deck:	18-22 ga. steel, wood, min. 19/32" plywood or wood plank.
Tradename:	Drill-Tec™ #14 HD Fastener, & Drill-Tec™ #15 EHD Fastener
Compatible Plate(s):	Drill-Tec™ 3” Flat Steel Plates and proprietary seam and fastening assembly plates listed in the specific Roof Assembly, Notice of Acceptance.
Generic Insulation Types:	Polyisocyanurate, Fiber Glass, Perlite, Rockwool, High Density Wood Fiber, Polystyrene, Urethane/Perlite Composite, Gypsum Cover Boards.
Application:	Mechanical attachment of roof insulation and/or roof cover. See specific Roof Assembly Notice of Acceptance for fastener density and approved attachment patterns.
Deck:	18-22 ga. steel, wood, min. 19/32" plywood or wood plank and min. 2,500 psi concrete.
Tradename:	Drill-Tec™ #14 HD Fasteners & Drill-Tec™ #15 EHD Fasteners
Compatible Plate(s):	Drill-Tec™ PVC IW Plates, Drill-Tec™ TPO IW Plates, and proprietary seam and fastening assembly plates listed in the specific Roof Assembly, Notice of Acceptance.
Generic Insulation Types:	Polyisocyanurate.
Application:	Mechanical attachment of roof insulation. See specific Roof Assembly Notice of Acceptance for fastener density and approved attachment patterns.
Deck:	18-22 ga. steel, and min. 2,500 psi concrete.
Tradename:	Drill-Tec™ 3” ASAP Flat
Compatible Plate(s):	Drill-Tec™ 3” Flat Steel Plates, and Drill-Tec™ #12 DP Fasteners pre-assembled, and proprietary seam and fastening assembly plates listed in the specific Roof Assembly, Notice of Acceptance.
Generic Insulation Types:	Polyisocyanurate, Fiber Glass, Perlite, Rockwool, High Density Wood Fiber, Polystyrene, Urethane/Perlite Composite, Gypsum Cover Boards.
Application:	Mechanical attachment of roof insulation and/or roof cover. See specific Roof Assembly Notice of Acceptance for fastener density and approved attachment patterns.
Deck:	18-22 ga. steel, wood, min. 19/32" plywood or wood plank and min 2,500 psi concrete.
Tradename:	Drill-Tec™ #12 Purlin Fastener
Compatible Plate(s):	Proprietary seam and insulation fastening assembly plates listed in the specific Roof Assembly, Notice of Acceptance.
Generic Insulation Types:	Polyisocyanurate, Fiber Glass, Perlite, Rockwool, High Density Wood Fiber, Polystyrene, Urethane/Perlite Composite, Gypsum Cover Boards
Application:	Mechanical attachment of roof insulation and/or roof cover. See specific Roof Assembly Notice of Acceptance for fastener density and approved attachment patterns.
Deck:	Min. 1/8” structural steel.

Tradename: **Drill-Tec™ #12 Purlin Fastener**
Compatible Plate(s): Trufast PVC IW Plates, Trufast TPO IW Plates, and proprietary seam and fastening assembly plates listed in the specific Roof Assembly, Notice of Acceptance.
Generic Insulation Types: Polyisocyanurate.
Application: Mechanical attachment of roof insulation. See specific Roof Assembly Notice of Acceptance for fastener density and approved attachment patterns.
Deck: Min. 16 ga. steel.

Trade Name: **Drill-Tec™ LDE Fastener**
Deck: New or sound existing Lightweight Concrete and Poured Gypsum.

Compatible Plate(s): **Drill-Tec™ LDE Plate**
Application: See specific Roof Assembly Product Control Notice of Acceptance for fastener density and approved attachment patterns.

Trade Name: **Drill-Tec™ Base Sheet Fastener E (1.2 in.)**
Deck: Approved NVS lightweight concrete, various poured gypsums, existing gypsum. See lightweight concrete deck Notice of Acceptance for Approved deck systems.
Application: See specific Roof Assembly Product Control Notice of Acceptance for fastener density and approved attachment patterns.

Trade Name: **Drill-Tec™ Base Sheet Fastener E (1.7 in.)**
Deck: Approved minimum 200-psi aggregate or cellular lightweight concrete. See lightweight concrete deck Notice of Acceptance for Approved deck systems.
Application: See specific Roof Assembly Product Control Notice of Acceptance for fastener density and approved attachment patterns.

Trade Name: **Drill-Tec™ Locking Impact Nail**
Deck: New or sound existing Cementitious Wood Fiber, Poured Gypsum, Lightweight Concrete.
Application: See specific Roof Assembly Product Control Notice of Acceptance for fastener density and approved attachment patterns.



GENERAL LIMITATIONS:

1. Refer to Roof Assembly Notice of Acceptance for use, density and attachment patterns.
2. Fasteners shall be installed in accordance with manufacturer's published installation instructions.
3. Care shall be taken not to puncture or tear the base sheet or insulation facer during fastener installation. Application recommendations are noted in Roofing Application Standard TAS 117.
4. GAF fasteners are a component part of Miami-Dade Approved Roof Assembly. These products are approved for use only with those roof assemblies approved for use with the components listed herein.
5. Any modifications to this Notice of Acceptance shall void such approval.
6. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.
7. All approved products listed herein shall be labeled and shall bear the imprint or identifiable marking of the manufacturer's name or logo and following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



END OF THIS ACCEPTANCE



NOA No.: 23-0313.08
Expiration Date: 04/17/24
Approval Date: 04/06/23
Page 12 of 12