



**NOTE:**

1. A FIELD WELD CANNOT PASS WITHIN 9" (227 mm) OF THE CLAMPING, OR WITHIN THE DRAIN SUMP ITSELF.
2. MEMBRANE MUST EXTEND MINIMUM 1" (25.4 mm) BEYOND THE BOLT HOLES. THE CLAMPING RING BOLTS MUST PENETRATE THE MEMBRANE.
3. TAPERED INSULATION TO CREATE A ROOF SUMP MINIMUM 36" (0.914 m) x 36" (0.914 m) IN SIZE. (IF APPLICABLE)
4. USE ONE FULL TUBE OF FLEXSEAL™ CAULK GRADE SEALANT OR EVERGUARD WATER BLOCK PER DRAIN.
5. ASPHALT OR STONE PAVER MUST STOP AT DRAIN TAPER.



**EverGuard**  
SINGLE-PLY ROOFING SYSTEMS  
ROOF PENETRATION  
SERIES

DRAWING #  
**513**

**DRAIN -STANDARD ROOF DRAIN  
FLASHING DETAIL**

THIS DETAIL APPLIES TO:

**ALL SYSTEMS**

www.gaf.com  
1 Campus Drive  
Parsippany, NJ 07054

SCALE  
N.T.S.

REVISION DATE  
6-21-16