



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786)315-2590 F (786) 315-2599
www.miamidade.gov/economy

GAF

**1 Campus Drive
Parsippany, NJ 07054**

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: LeakBuster™ and Matrix™ Roofing Cements and Coatings

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA No. 13-0603.16 and consists of pages 1 through 5.
The submitted documentation was reviewed by Jorge L. Acebo.



NOA No.: 15-0128.14
Expiration Date: 08/23/16
Approval Date: 04/09/15
Page 1 of 5

ROOFING COMPONENT APPROVAL

Category: Roofing
Sub-Category: Cement-Adhesive-Coatings
Material: Asphalt

SCOPE:

This approves "LeakBuster™ and Matrix™ Roofing Cements and Coatings" as described in this Notice of Acceptance. These products have been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone of the Florida Building Code.

MANUFACTURING LOCATION:

1. Hallandale, FL.

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name / Report</u>	<u>Date</u>
PRI Construction Materials Technologies, LLC	TRA-089-02-01	ASTM D4586	05/16/06
	TRA-090-02-01	ASTM D4586	05/16/06
	TRA-091-02-01	ASTM D4586	05/16/06
	TRA-092-02-01	ASTM D2824	05/16/06
	TRA-093-02-01	ASTM D2824	05/16/06
	TRA-094-02-01	ASTM D3019	05/16/06
	TRA-095-02-01	ASTM D41	05/16/06
	TRA-096-02-01	ASTM D4479	05/16/06
	TRA-097-02-01	ASTM D3019	05/16/06
	TRA-098-02-01	ASTM D4586	05/16/06
	TRA-079-02-01	ASTM D4586	10/19/05
	TRA-080-02-01	ASTM D4586	10/19/05
	TRA-082-02-01	TAS 139	10/19/05
	TRA-083-02-01	ASTM D4479	10/21/05
	TRA-085-02-02	ASTM D41	12/30/05
	TRA-078-02-01	ASTM D 6083	11/22/05
	DL Laboratories	DL-9951-R	ASTM D962, Type II

PHYSICAL PROPERTIES OF COMPONENTS:

Trade name: Matrix™ 204 Wet/Dry Roof Cement or LeakBuster™ Matrix™ 204 Wet/Dry Roof Cement

Application Rate: This material is applied by trowel or knife at a minimum rate of 1/8" thick, approximately 1 gal/12 sq. ft. For systems approvals, refer to specific Roof Assembly, Product Control Notice of Acceptance.

Specifications: ASTM D4586 Type I, ASTM D3409

Description: An all weather flashing cement that adheres to all surfaces, wet or dry. Blended with select asphalts, cellulose fibers, surfactants, mineral stabilizers, and pure hydrocarbon solvents. Used for protecting, waterproofing, patching and sealing old and new roofs.

Container Size: 1, 5, 55 gallons. Note all cautions on container label.



NOA No.: 15-0128.14
Expiration Date: 08/23/16
Approval Date: 04/09/15
Page 2 of 5

Trade name: Matrix™ 203 Plastic Roof Cement or LeakBuster™ Matrix™ 203 Plastic Roof Cement

Application Rate: Applied with a trowel or knife at a minimum rate of 1/8" thick, approximately 1 gal/12 sq. ft. For systems approvals, refer to specific Roof Assembly, Product Control Notice of Acceptance.

Specifications: ASTM D4586, ASTM D3409

Description: An asbestos free asphaltic base, multipurpose plastic roof cement for repairing leaks, cracks, and holes in concrete, steel, or metal roofs. For use on all flashing around skylights, gutters, and in all crevices. It can also be applied as a heavy-duty foundation coating.

Container Size 1, 5, 55 gallons. Note all cautions on container label.

Trade name: Matrix™ 202 SBS Flashing Cement or LeakBuster™ Matrix™ 202 SBS Flashing Cement

Application Rate: Applied with a trowel at a minimum rate of 1/8" thick, approximately 1 gal/12 sq. ft. For systems approvals, refer to specific Roof Assembly, Product Control Notice of Acceptance.

Specifications: ASTM D4586, ASTM D3409

Description: Asbestos free flashing compound manufactured with high-grade oxidized base asphalts. Fortified with SBS rubber. Special surfactants make this product applicable in any climate or weather. Manufactured to adhere to all solid surfaces, wet or dry. For use in repairing, sealing, or adhering to all types of roofing. A trowel grade modified adhesive as well as flashing cement. Uses include fixing leaks around vent pipes, skylights, valleys, chimneys, joints, starting shingles as well as patching small holes. May be used to repair modified asphalt sheets as well as conventional roofing. Not for use on coal tar roofs.

Container Size: 1, 3, 55 gallons and 10.5 ounce caulking tubes.

Trade name: Matrix™ 303 Premium Fibered Aluminum Roof Coating or LeakBuster™ Matrix™ 303 Premium Fibered Aluminum Roof Coating

Application Rate: For systems approvals, refer to specific Roof Assembly, Product Control Notice of Acceptance.

Specifications: ASTM D2824 Type III

Description: Asbestos free, heavy duty, fibered aluminum asphalt coating that provides reflectivity while ensuring protection against moisture and corrosion. Do not work coating excessively during application. Attempt to brush or roll on in one direction. Can be used on all types of roofs, well suited for modified bitumen.

Container Size: 1, 5, 55 gallons. Note all cautions on container label.



Trade name: Matrix™ 304 Non-Fibered Aluminum Roof Coating or LeakBuster™ Matrix™ 304 Non-Fibered Aluminum Roof Coating

Application Rate: For systems approvals, refer to specific Roof Assembly, Product Control Notice of Acceptance.

Specifications: ASTM D2824 Type I

Description: A brilliant, durable paint designed to withstand extreme weather conditions. This product uses paint grade aluminum paste and a leafing finish. For use on roofs of all types, storage tanks, masonry surfaces, and structural steel. It also is a rust and corrosion resistant coating for all types of metal surfaces. Application of this product may be done with a mop, brush or spray equipment.

Container Size 1, 5, 55 gallons. Note all cautions on container label.

Trade name: Matrix™ 307 Premium Asphalt Primer or LeakBuster™ Matrix™ 307 Premium Asphalt Primer

Application Rate: Apply by brush or spray at a minimum rate of 1gal. /100ft² for systems approvals, refer to specific Roof Assembly, Product Control Notice of Acceptance.

Specifications: ASTM D-41

Description: A general purpose asphalt based primer used as a bonding coat for preparation of roof surfaces prior to the application of subsequent roofing materials.

Container Size: 1, 5, 55 gallons. Note all cautions on container label.



LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. LeakBuster™ or Matrix™ Roofing Cements and Coatings shall not be applied in inclement weather conditions.
3. The product listed herein are components of roof assemblies and are approved for use with roof assemblies that list any of the products listed herein as part of their roof assemblies Notice of Acceptance. If a product is not listed as part of roof assemblies Notice of Acceptance, a request may be made to the local building official or the Miami Dade Building Code Compliance Office for approval provided that appropriate documentation is provided.
4. All products listed herein shall have an unannounced follow-up quality control program from an approved listing agency, and shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code. Follow up test results shall be made available to Miami-Dade County Product Control upon request.
5. Change in materials, use, or manufacture of any of the products listed herein shall be cause for termination of this Notice of Acceptance.
6. This maintenance coating systems shall not be applied over, prepared roofing; i.e., fiber-cement shingles, quarry slate, cement or clay roof tile, metal shingles, wood shingles or shakes.
7. LeakBuster™ or Matrix™ Roofing Cements and Coatings shall be applied in accordance with manufacturer's published application instructions.
8. All approved products listed herein shall be labeled in compliance with TAS 121 and shall bear the imprint or identifiable marking of the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below

MIAMI-DADE COUNTY
APPROVED

END OF THIS ACCEPTANCE

MIAMI-DADE COUNTY
APPROVED

NOA No.: 15-0128.14
Expiration Date: 08/23/16
Approval Date: 04/09/15
Page 5 of 5

