

## **GENERAL CERTIFICATE OF CONFORMANCE**

### **GRABBER CONSTRUCTION PRODUCTS**

5255 West 11000 North  
Suite 100  
Highland, UT 84003-8955

GrabberGard EFC, IFC & EFS

### **THESE PRODUCTS ARE TESTED TO THE FOLLOWING TEST STANDARDS**

In the USA:

ASTM E-814      Standard Test Method for Fire Tests of Through Penetrations Fire Stops  
ASTM E-1399      Cyclic Movement and Measuring the Minimum and Maximum Joint Widths of  
Architectural Joint Systems

UL 1479      Fire Tests of Through-Penetration Firestops  
UL 2079      Tests for Fire Resistance of Building Joint Systems

In Canada:

ULC S115      Standard Method of Fire Tests of Firestop Systems

### **TESTED BY THIRD PARTY AGENCIES**

Underwriters Laboratories, Inc. (UL)  
Intertek Testing Services Inc. – Warnock Hersey (WHI)

**No Asbestos or PCBs are used or contained in this product.**

Conformance

January 2019