



modifiedPLUS® NP180gM4 Cap & Cap Flashing
modifiedPLUS® Base Sheet Flashing
modifiedPLUS® Base Sheet
 HENRY Re-Cover Board (If Required)
 Primary Insulation (Tapered Insulation Optional)
 Air/Vapor Barrier or Vapor Retarder (Optional)
 Gypsum Board Concrete Sheathing (Optional)
 Deck

Consult your HENRY representative or HENRY Technical Service for specific Code or design professional compliance issues.

SPEC NOTE: HENRY General Specifications apply in addition to the following recommendations.

PART 2: PRODUCTS

2.01	.1	Membrane adhesive:	HENRY #902 PBA Adhesive or #903 Modified Membrane Adhesive
2.02	.1	Membrane Flashing Cement:	HENRY #906 Flashmaster Elastomeric Flashing Cement
2.03	.1	Cold Process Insulation Adhesive	HENRY #111 Insulbond Cold Insulation Adhesive
2.04	.1	Membrane base sheet:	<i>modifiedPLUS®</i> G100s/s
2.05	.1	Base sheet flashing:	<i>modifiedPLUS®</i> G100s/s OR NP180s/s
2.06	.1	Cap and cap sheet flashing:	<i>modifiedPLUS®</i> NP180gM4

PART 3: EXECUTION

SPEC NOTE: Insulation must be installed as per manufacturers instructions. Polyisocyanurate and polystyrene insulation require a minimum 7/16" fiberboard, perlite or 1/8" HENRY Re-Cover Board overlay.

SPEC NOTE: Base and cap sheet must be mechanically fastened on slopes exceeding 1:12 (1" in 12")

- | | | |
|------|----|---|
| 3.01 | .1 | Apply base sheet in HENRY #902 or #903 by spray, or notched squeegee, applied at a rate of 2 gallons/100 ft ² . Sufficient adhesive should be applied at laps to result in a visible bead of adhesive completed lap edge. Adhere strictly to the latest HENRY data sheet instructions. |
| | .2 | Start all roofing applications at the lowest point to ensure water runs over the laps of the membrane. |
| | .3 | Carry base sheet to top of cant. Lap base sheet 3" on sides and 6" on ends. |
| | .4 | Reinforce around all projections and drains as per HENRY specifications and details. |
| 3.02 | .1 | Apply base sheet flashing in HENRY #902 or #903 by spray, or notched squeegee, applied at a rate of 2 gallons/100 ft ² . |
| | .2 | Begin application 4" from toe of cant and extend vertically as indicated. Mechanically fasten base sheet flashing using 1" round top nails on 8" centers. |
| 3.03 | .1 | Apply cap sheet in HENRY #902 or #903 by spray, or notched squeegee, applied at a rate of 2 gallons/100 ft ² . Sufficient adhesive should be applied at laps to result in a visible bead of adhesive at completed lap edge. Carry to the top of the cant and lap cap sheet 3" on sides and 6" on ends. |
| | .2 | Offset laps from those of the base sheet a minimum of 12" for side and 18" for end laps. |
| | .3 | At all end or head laps of cap sheets where T joint occurs, cut corner of membrane to be overlapped on a 45° angle. |
| 3.04 | .1 | Apply cap sheet flashing in HENRY #906 by trowel applied in an unbroken 1/8" film thickness. Adhere strictly to the latest HENRY data sheet instructions. |
| | .2 | Begin application 6" from toe of cant and extend vertically as indicated. Mechanically fasten cap sheet flashing using 1" round top nails on 8" centers. Refer to manufacturers standard details.<> |