

ICC-ES Evaluation Report

ESR-1027

Reissued October 2025

Revised June 2026


- City of LA Supplement

- CA Supplement

This report remains under an active [continuous compliance program](#) through the end of October 2026

ICC-ES Evaluation Reports are not to be construed as representing aesthetics or any other attributes not specifically addressed, nor are they to be construed as an endorsement of the subject of the report or a recommendation for its use. There is no warranty by ICC Evaluation Service, LLC, express or implied, as to any finding or other matter in this report, or as to any product covered by the report.

Copyright © 2026 ICC Evaluation Service, LLC. All rights reserved.

<p>DIVISION: 07 00 00 - THERMAL AND MOISTURE PROTECTION</p> <p>Section: 07 25 00—Water-Resistive Barriers/Weather Barriers</p> <p>07 27 00—Air Barriers</p>	<p>REPORT HOLDER:</p> <p>HENRY A CARLISLE COMPANY</p>	<p>EVALUATION SUBJECT:</p> <p>JUMBO TEX® , SUPER JUMBO TEX 60 MINUTE®, WEATHERSMART®, TWO-PLY HYDRO TEX D® WATER-RESISTIVE BARRIERS, TWO-PLY JUMBO TEX®, TWO-PLY SUPER JUMBO TEX 60 MINUTE® AND TWO-PLY JUMBO TEX HD 60/20 MINUTE</p>	
--	---	---	---

1.0 EVALUATION SCOPE

1.1 Compliance with the following codes:

- 2024, 2021, 2018 and 2015 [International Building Code® \(IBC\)](#)
- 2024, 2021, 2018 and 2015 [International Residential Code® \(IRC\)](#)
- 2024, 2021, 2018 and 2015 [International Energy Conservation Code® \(IECC\)](#)

Properties evaluated:

- Physical properties
- Air barrier
- Surface-burning characteristics
- Drainage efficiency (Two-Ply Hydro Tex D)
- Fire-resistance-rated walls (Jumbo Tex and Super Jumbo Tex 60 Minute)

1.2 Evaluation to the following green code(s) and/or standards:

- 2025 and 2022 [California Green Building Standards Code \(CALGreen\)](#), Title 24, Part 11
- 2024, 2021, 2018, 2015 and 2012 [International Green Construction Code® \(IgCC\)](#)
- 2023, 2020, 2017, 2014 and 2011 [ANSI/ASHRAE/USGBC/IES Standard 189.1](#)—Standard for the Design of High-Performance Green Buildings, Except Low-Rise Residential Buildings
- 2020, 2015, 2012 and 2008 ICC 700 [National Green Building Standard™](#) (ICC 700-2020, ICC 700-2015, ICC 700-2012, and ICC 700-2008)

Attributes verified:

- See Section 2.0

2.0 USES

Jumbo Tex, Super Jumbo Tex 60 Minute, WeatherSmart, Two-Ply Hydro Tex D, Two-Ply Jumbo Tex, Two-Ply Super Jumbo Tex 60 Minute and Two-Ply Jumbo Tex HD 60/20 Minute are used as water-resistive barriers on the exterior side of exterior walls of buildings of Type V construction under the IBC and construction permitted under the IRC. The water-resistive barriers comply with ASTM E2556 Type II in accordance with IBC Section 2510.6 and 2024 and 2021 IRC Section R703.7.3 and are equivalent to Grade D paper with a 60-minute water resistance rating as described in the exception to 2018 and 2015 IRC Section R703.7.3.

WeatherSmart may be used as an air barrier material in accordance with 2024 IRC Section N1102.5.1 (2021, 2018 and 2015 IRC Section N1102.4.1), or 2024 IECC Sections C402.6 and R402.5 (2021, 2018 and 2015 IECC Sections C402.5 and R402.4).

The attributes of the water-resistive barriers have been verified as conforming to the provisions of (i) CALGreen Section 5.407.1 for water-resistive barriers; (ii) ICC 700-2020 Sections 602.1.8, 11.602.1.8, 1202.6 and 13.104.1.4; and (iii) ICC 700-2015 Section 602.1.8, 11.602.1.8 and 12.6.602.1.8; (iv) ICC 700-2012 Sections 602.1.8, 11.602.1.8 and 12.5.602.1.8; and (v) ICC 700-2008 Section 602.9 for water-resistive barriers.

The attributes of WeatherSmart have been verified as conforming to the provisions of (i) 2024 and 2021 IgCC Section 701.3.1.2, 2018 IgCC Section 701.3.1.1 and 2015 and 2012 IgCC Section 605.1.2.1 for air barriers; and (ii) 2023 and 2020 ASHRAE 189.1 Section 7.3.1.2, 2017 and 2014 ASHRAE 189.1 Section 7.3.1.1 and 2011 ASHRAE 189.1 Section 7.4.2.9 for air barriers. Note that decisions on compliance for those areas rest with the user of this report. The user is advised of the project-specific provisions that may be contingent upon meeting specific conditions, and the verification of those conditions is outside the scope of this report. These codes or standards often provide supplemental information as guidance.

3.0 DESCRIPTION

3.1 Jumbo Tex:

Jumbo Tex is a Grade D asphalt-saturated kraft building paper. Jumbo Tex weighs 3.6 pounds per 100 square feet (0.18 kg/m²) and is manufactured in rolls of varying sizes.

3.2 Super Jumbo Tex 60 Minute:

Super Jumbo Tex 60 Minute is a Grade D asphalt-saturated kraft building paper with a 60-minute water-resistance rating. Jumbo Tex weighs 6 pounds per 100 square feet (0.29 kg/m²) and is manufactured in rolls of varying sizes.

3.3 WeatherSmart:

WeatherSmart is a Grade D, nonwoven, polypropylene fabric with a monolithic polymer coating on one side, and has a 60-minute water-resistance rating. WeatherSmart weighs 1.9 pounds per 100 square feet (0.09 kg/m²) and is manufactured in rolls of varying sizes. When used as an air barrier material, the product has an air permeance not exceeding 0.02 L/(s m²) @ 75 Pa [0.004 cfm.ft² at 0.3 w.g. (1.57 psf)].

3.4 Two-Ply Hydro Tex D:

Two-Ply Hydro Tex D is a two-layer water-resistive barrier comprised of one layer of Super Jumbo Tex 60 Minute, as described in Section 3.2, and one layer of WeatherSmart[®] D Drainable ([ESR-5320](#)). Two-Ply Hydro Tex D weighs 7.4 pounds per 100 square feet (0.36 kg/m²) and is manufactured in rolls of varying sizes.

3.5 Two-Ply Jumbo Tex: Two-Ply Jumbo Tex is a two-layer water-resistive barrier comprised of two layers of Jumbo Tex, as described in Section 3.1. Two-Ply Jumbo Tex weighs 7.2 pounds per 100 square feet (0.35 kg/m²) and is manufactured in rolls of varying sizes.

3.6 Two-Ply SuperJumbo Tex 60 Minute: Two-Ply Super Jumbo Tex 60 Minute is a two-layer water-resistive barrier comprised two layers of Super Jumbo Tex 60 Minute, as described in Section 3.2. Two-Ply Super Jumbo Tex weighs 12 pounds per 100 square feet (0.59 kg/m²) and is manufactured in rolls of varying sizes.

3.7 Two-Ply Jumbo Tex HD 60/20 Minute: Two-Ply Jumbo Tex HD 60/20 Minute is a two-layer water-resistive barrier comprised of one layer of Jumbo Tex, as described in Section 3.1 and one layer of Super Jumbo Tex 60 Minute, as described in Section 3.2. Two-Ply Jumbo Tex HD 60/20 Minute weighs 12 pounds per 100 square feet (0.59 kg/m²) and is manufactured in rolls of varying sizes.

3.8 Surface Burning Characteristics:

The water-resistive barriers have a flame spread index of less than 100 and a smoke-developed index of less than 450, when tested in accordance with ASTM E84.

3.9 Drainage Efficiency:

When installed in accordance with Section 4.4, Two-Ply Hydro Tex D has a drainage efficiency rating of 90 percent or more as determined in accordance with ASTM E2273.

4.0 INSTALLATION

4.1 General:

The water-resistive barriers must be installed in accordance with 2024, 2021 and 2018 IBC Section 1403.2 and (2015 IBC Section 1404.2) or IRC Section R703.2, as applicable, on the exterior side of exterior wall framing, sheathing or insulation, with the printed side installed facing outward.

The water-resistive barriers described in this report are installed after wall framing is completed and before or after windows and doors are installed. The roll is placed approximately 6 inches (152 mm) from the starting corner, except where the manufacturer's installation instructions specify a greater dimension, and is fastened with corrosion-resistant staples, corrosion-resistant nails, or corrosion nails or staples having plastic washer heads. The water-resistive barrier is then unrolled horizontally around the building and fastened in accordance with the manufacturer's published installation instructions. A minimum of 6 inches (152 mm) of overlap is to be provided for vertical seams and 2 inches (51 mm) for horizontal seams, except where the manufacturer's published installation instructions specify a greater overlap.

When the water-resistive barriers are installed over wood-based sheathing in exterior plaster applications, the water-resistive barriers must be applied in two layers over the sheathing, in accordance with 2018 and 2015 IBC Section 2510.6 and 2018 or 2015 IRC Section R703.7.3, as applicable. As an alternative, the water-resistive barriers may be installed in a single layer in accordance with the exception to 2018 and 2015 IBC Section 2510.6 and 2018 and 2015 IRC Section R703.7.3.

When Jumbo Tex, Super Jumbo Tex 60 Minute, WeatherSmart, Two-Ply Jumbo Tex, Two-Ply Super Jumbo Tex 60 Minute or Two-Ply Jumbo Tex HD 60/20 Minute are used over wood based sheathing in exterior plaster applications in accordance with 2024 and 2021 IBC Section 2510.6 and 2024 and 2021 IRC Section R703.7.3 installations must be as follows:

- For dry climate zones (B) in accordance with 2024 and 2021 IBC Section 2510.6.1 or 2024 and 2021 IRC Section R703.7.3.1, the products must be applied in accordance with 2024 and 2021 IBC Section 2510.6.1 Item 1 or 2 and 2021 IRC Section R703.7.3.1 Item 1 or 2, as applicable.
- For moist climate zones (A) or marine climate zones (C) in accordance with 2024 and 2021 IBC Section 2510.6.2 or 2024 and 2021 IRC Section R703.7.3.2, the product must be applied in accordance the dry climate zone (B) provisions noted above and with the additional requirements noted in 2024 and 2021 IBC Section 2510.6.2 Item 1 or 2024 and 2021 IRC Section R703.7.3.2 Item 1, as applicable.

When Two-Ply Hydro Tex D is used over wood based sheathing in exterior plaster applications in accordance with 2024 and 2021 IBC Section 2510.6 and 2024 and 2021 IRC Section R703.7.3 for installations must be as follows:

- For dry climate zones (B) in accordance with 2024 and 2021 IBC Section 2510.6.1 or 2024 and 2021 IRC Section R703.7.3.1, the products must be applied in accordance with 2024 and 2021 IBC Section 2510.6.1 Item 1 or 2 and 2024 and 2021 IRC Section R703.7.3.1 Item 1 or 2, as applicable.
- For moist climate zones (A) or marine climate zones (C) in accordance with 2024 and 2021 IBC Section 2510.6.2 or 2024 and 2021 IRC Section R703.7.3.2, the products must be applied in accordance the dry climate zone (B) provisions noted above and with the additional requirements noted in 2024 and 2021 IBC Section 2510.6.2 Item 1 or 2 or 2024 and 2021 IRC Section R703.7.3.2 Item 1 or 2, as applicable.

For cementitious coatings or exterior insulation and finish systems, application is to be in accordance with the ICC-ES evaluation report on the exterior coating system.

4.2 Fire-resistance-rated Construction Assemblies:

In Type V-A construction, the Jumbo Tex and Super Jumbo Tex 60 Minute water-resistive barriers may be used in exterior fire-resistance-rated assemblies described in IBC Table 721.1(2), or described in a current ICC-ES evaluation report that specifies use of building paper, without changing the assigned hourly rating of the assembly.

4.3 Air Barrier:

WeatherSmart, when used as an air barrier material, must be installed in accordance with the manufacturer's published installation instructions and this report.

4.4 Wall Covering Assembly with Drainage

4.4.1 Two-Ply Hydro Tex D:

Two-Ply Hydro Tex D has drainage efficiency rating of 90 percent or more as determined in accordance with ASTM E2773 when installed in an exterior wall assembly that consists of $1\frac{5}{32}$ -inch (12 mm) thick Exposure 1 oriented strand board (OSB) sheathing applied to wood studs spaced a maximum of 16 inches (406 mm) on center and fastened in accordance with the requirements of IBC Chapter 23 or IRC Chapter 6. Vertical board edges must butt over studs. Two-Ply Hydro D must be applied as described in Section 4.1. Minimum 1-inch-thick (25.4 mm) flat faced Type 1 expanded polystyrene (EPS) foam plastic insulation boards, described in a current ICC-ES evaluation report as complying with ASTM C578, must be positioned over the Two-Ply Hydro Tex D wrap and fastened to the sheathing along the edges of the EPS insulation boards and midway between the horizontal edges of the EPS insulation boards using Wind-Lock #7 x $1\frac{5}{8}$ -inch (41 mm) long (41 mm) dual threaded screws with Wind-Lock 2-inch (51 mm) diameter plastic washer (Part # GWLMT-1). The Wind-Lock fasteners must be spaced a maximum of 9 inches (229 mm) on center vertically starting 3 inches (76 mm) up from the bottom of the wall assembly and 16 inches (406 mm) on center horizontally starting 5 inches (127 mm) from one side of the wall assembly. The exterior wall covering must be applied over the EPS foam plastic insulation boards as specified in the applicable code or current ICC-ES evaluation report for the exterior wall covering.

5.0 CONDITIONS OF USE:

The water-resistive barriers described in this report comply with, or are suitable alternatives to what is specified in, those codes listed in Section 1.0 of this report, subject to the following conditions:

- 5.1 Installation must comply with this report, the manufacturer's published installation instructions and the applicable code. In the event of conflict between the manufacturer's published installation instructions and this report, this report governs.
- 5.2 The water-resistive barriers must be covered with an approved exterior wall covering.
- 5.3 The air permeance noted in Section 3.4 is for WeatherSmart used as an air barrier material only. The design and evaluation of an air barrier assembly, with WeatherSmart as a component, is outside the scope of this report.
- 5.4 The products are manufactured under a quality control program with inspections by ICC-ES.

6.0 EVIDENCE SUBMITTED

- 6.1 Data in accordance with the [ICC-ES Acceptance Criteria for Water-resistive Barriers \(AC38\)](#), dated August 2016 (editorially revised June 2024).
- 6.2 Reports of testing in accordance with ASTM E84.
- 6.3 Reports of testing in accordance with ASTM E2178.
- 6.4 Report of testing for Two-Ply Hydro Tex D in accordance with ASTM E2273.

7.0 IDENTIFICATION

- 7.1 The ICC-ES mark of conformity, electronic labeling, or the evaluation report number (ICC-ES ESR-1027) along with the name, registered trademark, or registered logo of the report holder must be included in the product label.
- 7.2 In addition, the water-resistive barriers described in this report are identified on one side, at regular intervals, with the product name, the Henry a Carlisle Company name and website address, and the evaluation report number (ESR-1027).
- 7.3 The report holder's contact information is the following:

HENRY A CARLISLE COMPANY
336 COLD STREAM ROAD
KIMBERTON, PENNSYLVANIA 19442
(888) 229-2199 www.henry.com
henry-techservice@carlisle.com

DIVISION: 07 00 00—THERMAL AND MOISTURE PROTECTION
Section: 07 25 00—Water-Resistive Barriers/Weather Barriers
Section: 07 27 00—Air Barriers

REPORT HOLDER:

HENRY A CARLISLE COMPANY

EVALUATION SUBJECT:

JUMBO TEX®, SUPER JUMBO TEX 60 MINUTE®, WEATHERSMART®, TWO-PLY HYDRO TEX D® WATER-RESISTIVE BARRIERS, TWO-PLY JUMBO TEX®, TWO-PLY SUPER JUMBO TEX 60 MINUTE® AND TWO-PLY JUMBO TEX HD 60/20 MINUTE

1.0 REPORT PURPOSE AND SCOPE

Purpose:

The purpose of this evaluation report supplement is to indicate that Jumbo Tex, Super Jumbo Tex 60 Minute, WeatherSmart, Two-Ply Hydro Tex D, Two-Ply Jumbo Tex, Two-Ply Super Jumbo Tex 60 Minute and Two-Ply Jumbo Tex HD 60/20 Minute, described in ICC-ES evaluation report [ESR-1027](#), has/have also been evaluated for compliance with the codes noted below as adopted by the Los Angeles Department of Building and Safety (LADBS).

Applicable code editions:

- 2026* *City of Los Angeles Building Code* ([LABC](#))
- 2026* *City of Los Angeles Residential Code* ([LARC](#))

*For evaluation for compliance with the anticipated requirements of the 2026 LABC and LARC

2.0 CONCLUSIONS

The Jumbo Tex, Super Jumbo Tex 60 Minute, WeatherSmart, Two-Ply Hydro Tex D, Two-Ply Jumbo Tex, Two-Ply Super Jumbo Tex 60 Minute and Two-Ply Jumbo Tex HD 60/20 Minute water-resistive barriers, described in Sections 2.0 through 7.0 of the evaluation report [ESR-1027](#), comply with the LABC Chapter 14, and the LARC Section R703, and are subject to the conditions of use described in this supplement.

3.0 CONDITIONS OF USE

The Jumbo Tex, Super Jumbo Tex 60 Minute, WeatherSmart, Two-Ply Hydro Tex D, Two-Ply Jumbo Tex, Two-Ply Super Jumbo Tex 60 Minute and Two-Ply Jumbo Tex HD 60/20 Minute water-resistive barriers described in this evaluation report supplement must comply with all of the following conditions:

- All applicable sections in the evaluation report [ESR-1027](#).
- The design, installation, conditions of use and identification of the Jumbo Tex, Super Jumbo Tex 60 Minute, WeatherSmart, Two-Ply Hydro Tex D, Two-Ply Jumbo Tex, Two-Ply Super Jumbo Tex 60 Minute and Two-Ply Jumbo Tex HD 60/20 Minute water-resistive barriers are in accordance with the 2024 *International Building Code*® (IBC) or 2024 *International Residential Code*® (IRC) provisions, as applicable, noted in the evaluation report [ESR-1027](#).
- The design, installation and inspection are in accordance with additional requirements of LABC Chapters 14 and 17 and LARC Section R703, as applicable.

This supplement expires concurrently with the evaluation report, issued October 2025, and revised June 2026.

DIVISION: 07 00 00—THERMAL AND MOISTURE PROTECTION
Section: 07 25 00—Water-Resistive Barriers/Weather Barriers
Section: 07 27 00—Air Barriers

REPORT HOLDER:**HENRY A CARLISLE COMPANY****EVALUATION SUBJECT:**

JUMBO TEX® , SUPER JUMBO TEX 60 MINUTE®, WEATHERSMART®, TWO-PLY HYDRO TEX D® WATER-RESISTIVE BARRIERS, TWO-PLY JUMBO TEX®, TWO-PLY SUPER JUMBO TEX 60 MINUTE® AND TWO-PLY JUMBO TEX HD 60/20 MINUTE

1.0 REPORT PURPOSE AND SCOPE**Purpose:**

The purpose of this evaluation report supplement is to indicate that Jumbo Tex, Super Jumbo Tex 60 Minute, WeatherSmart, Two-Ply Hydro Tex D, Two-Ply Jumbo Tex, Two-Ply Super Jumbo Tex 60 Minute and Two-Ply Jumbo Tex HD 60/20 Minute water-resistive barriers, described in ICC-ES evaluation report [ESR-1027](#), have also been evaluated for compliance with the codes noted below.

Applicable code editions:

- 2025 California Building Code (CBC)

For evaluation of applicable chapters adopted by the California Office of Statewide Health Planning and Development (OSHPD) AKA: California Department of Health Care Access and Information (HCAI) and the Division of State Architect (DSA), see Sections 2.1.1 and 2.1.2 below.

- 2025 California Residential Code (CRC)

- 2025 California Energy Code (CEC)

2.0 CONCLUSIONS**2.1 CBC:**

The Jumbo Tex, Super Jumbo Tex 60 Minute, WeatherSmart, Two-Ply Hydro Tex D, Two-Ply Jumbo Tex, Two-Ply Super Jumbo Tex 60 Minute and Two-Ply Jumbo Tex HD 60/20 Minute water-resistive barriers, described in Sections 2.0 through 7.0 of the evaluation report [ESR-1027](#), comply with CBC Chapter 14, provided the design and installation are in accordance with the 2024 *International Building Code*® (IBC) provisions noted in the evaluation report and the applicable provisions of the CBC Chapters 14 and 17. Use as an air barrier must be in accordance with the CEC.

2.1.1 OSHPD:

The applicable OSHPD Sections and Chapters of the CBC are beyond the scope of this supplement.

2.1.2 DSA:

The applicable DSA Sections and Chapters of the CBC are beyond the scope of this supplement.

2.2 CRC:

The Jumbo Tex, Super Jumbo Tex 60 Minute, WeatherSmart, Two-Ply Hydro Tex D, Two-Ply Jumbo Tex, Two-Ply Super Jumbo Tex 60 Minute and Two-Ply Jumbo Tex HD 60/20 Minute water-resistive barriers, described in Sections 2.0 through 7.0 of the evaluation report [ESR-1027](#), comply with CRC Chapter 7, provided the design and installation are in accordance with the 2024 *International Residential Code*® (IRC) provisions noted in the evaluation report and the applicable provisions of the CRC. Use as an air barrier must be in accordance with the CEC.

This supplement expires concurrently with the evaluation report, issued October 2026, revised June 2026.