



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	1451-1200:0121						
CATEGORY:	1451 - HEAD-OF-WALL/WALL-TO-WALL JOINT SYSTEMS						
LISTEE:	HILTI, INC. 5400 S 122nd East Ave., Tulsa, OK, 74146 Contact: Winston,Matthew (214) 803-5721 (918) 254-1679 Email: matthew.winston@hilti.com						
DESIGN:	Type CP606 Flexible Firestop Sealant for use in head-of-wall and wall-to-wall joint systems. Refer to listee's data sheet for detailed product description and operational considerations.						
RATING:	<table border="0"> <tr> <td><u>System No.</u></td> <td><u>Assembly Rating</u></td> </tr> <tr> <td>HW-D-0045</td> <td>2 Hr.</td> </tr> <tr> <td>WW-D-0032</td> <td>2 Hr.</td> </tr> </table>	<u>System No.</u>	<u>Assembly Rating</u>	HW-D-0045	2 Hr.	WW-D-0032	2 Hr.
<u>System No.</u>	<u>Assembly Rating</u>						
HW-D-0045	2 Hr.						
WW-D-0032	2 Hr.						
INSTALLATION:	In accordance with listee's printed installation instructions, UL Fire Resistance Directory, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.						
MARKING:	Listee's name, model number, rating, and UL label.						
APPROVAL:	Listed as firestop sealant for use in head-of-wall and wall-to-wall joint system when constructed and installed in accordance with UL Fire Resistance Directory. Approved for UL System Design Nos. HW-D-0045 and WW-D-0032.						
NOTES:							

*Rev. 06-20-2006



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 05/02/2026

Listing Expires: 06/30/2027

Authorized By: **Michael Huang**, Program Coordinator
Fire Engineering & Investigations Division