

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

Page 1 of 1

LISTING No. 4485-1200:0131

CATEGORY: 4485 -- OPENING PROTECTION (FIRESTOPPING)

LISTEE: HILTI, INC. 5400 S 122nd East Ave., Tulsa, OK 74146
Contact: Clay Hensley (918) 252-6216 Fax (918) 254-1679
Email: clay.hensley@hiliti.com

DESIGN: Type CP643N (may include a size designation between "643" and "N") Collar Firestop Devices for use in through penetration systems. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, UL Fire Resistance Directory, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, classification and UL label.

APPROVAL: Listed as collar firestop device for use in through penetration system when constructed and installed in accordance with UL Fire Resistance Directory. Approved systems: C-AJ-2109, W-L-2078, W-L-2084.



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2011**

Listing Expires **June 30, 2012**

Authorized By: **FRANCIS MATEO, Program Coordinator**
Fire Engineering Division