CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM





LISTING No. 2580-1701:0101 Page 1 of 1

CATEGORY: 2580 -- PLYWOOD

LISTEE: HOOVER TREATED WOOD PRODUCTS, INC.154 WIRE ROAD, THOMSON, GA 30824

Contact: Chris Athari (706) 755-5350 Fax (706) 595-6600

Email: cathari@frtw.com

DESIGN: Treated Plywood with EXTERIOR FIRE X. Products are pressure impregnated with

"EXTERIOR FIRE X" fire retardant chemical. EXTERIOR FIRE X covers the following types of plywood: Douglas Fir Plywood, Micro-Lam Douglas Fir laminated lumber plywood, Southern Yellow Pine Plywood, Gang-Lam Southern Yellow Pine laminated lumber plywood, Micro-Lam Southern Yellow Pine laminated lumber plywood, and Spruce Master Plank

laminated lumber plywood.

Refer to listee's printed installation instructions for additional detailed product description and

constructions.

RATING: Species Flame Spread Smoke Developed

(30 minutes) (30 minutes)

Douglas Fir 10 45

Micro-Lam Douglas Fir 10 25 Southern Yellow Pine 15 50

Gang-Lam Southern Yellow Pine 10 5 - 50 Micro-Lam Southern Yellow Pine 10 25

Spruce Master Plank 10 30

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, product identification, classification, and Underwriter's Laboratory label.

APPROVAL: Listed as exterior type fire retardant treated plywood. Also approved for use as ignition

resistant materials as specified in Chapter 7A of the *California Building Code. The plywood must be pressure treated with the fire retardant chemical at the factory under authorized

service inspection.

Corrected 9-25-12 il



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: July 01, 2021 Listing Expires June 30, 2022

Authorized By: **DAVID CASTILLO**, M.E., F.P.E.

Fire Engineering Division