



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	2580-1701:0102		
CATEGORY:	2580 - PLYWOOD		
LISTEE:	HOOVER TREATED WOOD PRODUCTS, INC. 154 WIRE ROAD, THOMSON, GA, 30824 Contact: Athari,Chris (706) 755-5350 (706) 595-6600 Email: cathari@frtw.com		
DESIGN:	<p>Treated Plywood with PYRO-GUARD. Products are pressure impregnated with "PYRO-GUARD" fire retardant chemical. PYRO-GUARD treated plywood covers the following species of plywood:</p> <p>Douglas Fir, Southern Yellow Pine, and Lauan.</p> <p>Refer to listee's printed installation instructions for additional detailed product description and constructions.</p>		
RATING:	Species	Flame Spread	Smoke Developed
	Douglas Fir	10	15
	Southern Yellow Pine	15	30
	Lauan	10	15
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.		
MARKING:	Listee's name, product identification, classification, and UL label.		
APPROVAL:	Listed as fire retardant treated plywood for interior use only. Listed as Class A products in accordance with ASTM E-84. In test of 30 minute duration, flame spread did not progress more than 10.5 feet beyond the centerline of the burners and no significant progressive combustion was present. The plywood must be pressure treated at the factory under authorized service inspection.		
NOTES:			

Corrected 11-03-11 jdd



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 03/20/2025

Listing Expires: 06/30/2026

Authorized By: **Michael Huang**, Program Coordinator
Fire Engineering & Investigations Division