

CITY OF LOS ANGELES

CALIFORNIA

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

VAN AMBATIELOS
PRESIDENT

JAVIER NUNEZ
VICE PRESIDENT

JOSELYN GEAGA-ROSENTHAL
GEORGE HOVAGUIMIAN
ELVIN W. MOON



ERIC GARCETTI
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

OSAMA YOUNAN, P.E.
GENERAL MANAGER
SUPERINTENDENT OF BUILDING

JOHN WEIGHT
EXECUTIVE OFFICER

Hoover Treated Wood Products, Inc.
154 Wire Road
Thomson, GA 30824

RESEARCH REPORT: RR 25150
(CSI 06070)

Attn: Christopher K. Athari
(706) 755-5350

REEVALUATION DUE

DATE: December 1, 2022

Issued Date: November 1, 2020

Code: 2020 LABC

GENERAL APPROVAL – Renewal - PYRO-GUARD® Fire-Retardant-Treated Wood.

DETAILS

PYRO-GUARD® Fire-Retardant-Treated (FRT) Wood is lumber and plywood that has been impregnated with the PYRO-GUARD® chemical by a pressure process to reduce combustibility. PYRO-GUARD® FRT Wood is kiln-dried after treatment to moisture contents of 19 percent for lumber and 15 percent for plywood, as required in Section 2303.2 of the 2020 LABC and Section R702.1.5.9 of 2020 LARC.

The products were evaluated for the following properties:

- Fire resistance
- Surface burning
- Structural Performance
- Hygroscopicity
- Thermal Barrier - Roof and Floor Applications
- Durability and Corrosion of Metals contacting Fire-Retardant-Treated (FRT) Lumber and Plywood

The following species of PYRO-GUARD® Fire-Retardant-Treated (FRT) treated lumber and plywood are covered under this report:

- Lumber: Alpine Fir, Balsam Fir, Black Spruce, Douglas Fir, Engelmann Spruce, Hem-Fir, Western Hemlock, Jack Pine, Lodgepole Pine, Ponderosa Pine, Red spruce, Southern Pine, Spruce-Pine-Fir (SPF), White Fir, White Spruce
- Plywood: Douglas Fir, Lauan, and Southern Pine

RR25150
Page 1 of 5

Hoover Treated Wood Products, Inc.
Re: PYRO-GUARD® Fire-Retardant – Treated Wood

The PYRO-GUARD® Fire-Retardant-Treated (FRT) lumber and plywood are approved for use subject to the following conditions:

1. Materials and methods of installation shall comply with this report and the manufacturer's published instructions. In the event of a conflict between the installation instructions and this report, this report governs.
2. Where required by the building official, engineering calculations and details shall be provided. The calculations shall verify that the anchorage complies with the building code for the type of framing and condition of the supporting construction.
3. All design capacities for plywood shall be reduced to 90% of the allowable values per code when fire treated with PYRO-GUARD®. The span rating shall be as noted per Table 1 of the evaluation report.
4. Use of PYRO-GUARD® Fire-Retardant-Treated (FRT) lumber and plywood in non-vented roofing assemblies is prohibited
5. Evaluations on the wood species intended for assemblies whose end-use includes exposure to continuous elevated temperatures are beyond the scope of this report.
6. The engineering calculations are subject to the adjustment factors in Table 2 used for lumber of those species noted herein.
7. PYRO-GUARD® Fire-Retardant-Treated (FFT) Wood must not be used in contact with the ground or any application in which it will be permanently exposed to precipitation, direct or indirect wetting, condensation, or in an unvented roofing or roofing support assembly.
8. PYRO-GUARD® Fire-Retardant-Treated (FFT) plywood may be field cut or ripped in any direction.
9. PYRO-GUARD® Fire-Retardant-Treated (FFT) lumber must not be milled or ripped in the field. However, bevels, end cuts, joints, laps, and scarfs may be fabricated.
10. All fire retardant treated lumber and plywood used on exterior walls shall be protected by a weather barrier in accordance with Section 1403 and 2508.2.1 of the 2020 Los Angeles City Building Code.
11. Fasteners used in PYRO-GUARD® Fire-Retardant-Treated (FFT) lumber must be galvanized steel, stainless steel, silicon bronze or copper, in accordance with Section 2304.10.5 of 2020 LABC and R317.3 or 2020 LARC. Refer to Table 1 and 2 for adjustment factors for design and minimum fastener size.

Hoover Treated Wood Products, Inc.
Re: PYRO-GUARD® Fire-Retardant – Treated Wood

12. PYRO-GUARD® Fire-Retardant-Treated (FFT) Wood is manufactured by Hoover treated Wood Products, Inc. under the UL LLC Listing/Classification and Follow-Up Service Program, which includes inspections in accordance with the quality elements of ICC-ES Acceptance Criteria for Quality Documentation, AC10. Hoover's manufacturing locations covered by this report are located in:
- Bakersfield, CA
 - Detroit, MI
 - Milford, VA
 - Oxford, PA
 - Winston, OR
 - Pine Bluff, AR
 - Thomson, GA
13. PYRO-GUARD® Fire-Retardant-Treated (FFT) Wood described in this evaluation report is identified by a marking bearing. See Attachment 2.
- The report holder 's name, Hoover treated Wood Products, Inc.
 - The plant identification
 - The UL Listing/Classification Mark
 - The evaluation report number UL ER7002-01

DISCUSSION

The report is in compliance with the 2020 Los Angeles City Building Code.

The approval is based on tests in accordance with the ICC-ES Acceptance Criteria for Fire-retardant-treated Wood (AC66), dated June 2015.

For Fire Resistance: PYRO-GUARD® Fire-Retardant-Treated (FRT) wood has been evaluated for fire resistance in accordance with Section 703.2 of the 2015 and 2012 IBC, Section R302.1 of the 2015 and 2012 IRC, and ANSI/UL 263 (ASTM E119-15) when used as a part of UL Fire Resistance Designs V314 and V332. Refer to section 8.4 of this report for the UL Certification of PYRO-GUARD® Fire-Retardant-Treated (FRT) Wood for fire resistance assembly designs.

For Surface Burning: PYRO-GUARD® Fire-Retardant-Treated (FRT) Wood covered under this report has a flame spread index of 25 or less and a smoke developed index of 450 or less, when tested in accordance with ANSI/UL 723 (ASTM E84) and did not show any evidence of significant progressive combustion when the test was continued for an additional 20-minute period. The flame front did not progress more than 10 ½ feet beyond the centerline of the burners at any time during the test. See Section 2303.2 of the 2015 IBC and the 2012 IBC, and Section R802.1.5 of the 2015 IBC and Section R802.1.3 of the 2012 IRC. Refer to Section 8.5 for the UL Certification of PYRO-GUARD® Fire-Retardant-Treated (FRT) Wood for surface burning characteristics

For Hygroscopicity: PYRO-GUARD® Fire-Retardant-Treated (FRT) Wood has a moisture content of less than 28 percent when tested in accordance with ASTM D3201 at 92 percent relative

RR25150

Page 3 of 5

Hoover Treated Wood Products, Inc.
Re: PYRO-GUARD® Fire-Retardant – Treated Wood

humidity, as specified in Section 2303.2.7 of the 2015 and 2012 IBC, Section R802.1.5.9 of the 2015 IRC, and Section R802.1.3.7 of the 2012 IRC.

For Thermal Barrier:

Roofing: PYRO-GUARD® Fire-Retardant-Treated (FRT) plywood for use in roofing assemblies has been evaluated in accordance with ANSI/UL 790 (ASTM E108) and by Section 1505.1 of the 2015 and 2012 IBC, Section Page 4 of 10 R902.1 of the 2015 and 2012 IRC. In addition, PYRO-GUARD® Fire-Retardant-Treated (FRT) plywood has been evaluated in accordance with ANSI/UL 1897 and Section 1504.3.1 of the 2015 and 2012 IBC. Refer to sections 8.6 and 8.7 of this report for the UL Certification of PYRO-GUARD® Fire-Retardant-Treated (FRT) Wood for roofing applications. Minimum 15/32 inch thick PYRO-GUARD® Fire-Retardant-Treated (FRT) plywood may be used as a thermal barrier to protect foam plastic insulation as described in Section 2603.4.1.5 of the 2015 and 2012 IBC, R316.5.2 of the 2015 and 2012 IRC.. Refer to Table 1 for load span limitations.

Flooring: Minimum 15/32 inch thick PYRO-GUARD® Fire-Retardant-Treated (FRT) plywood may be used as a thermal barrier to protect foam plastic insulation as described in Section 2603.4.1.14 of the 2015 and 2012 IBC, and Section R316.5.13 of the 2015 and 2012 IRC when the foam plastic insulation is exposed to the interior of the building. Refer to Table 1 for load span limitations.

For Durability and Corrosion of Metals contacting Fire-Retardant-Treated (FRT) Lumber and Plywood:

Corrosion rates for aluminum, carbon steel, copper, galvanized steel, and red brass components in contact with PYRO-GUARD® Fire-Retardant-Treated (FRT) Wood are not enhanced by the PYROGUARD® chemical treatment when used in assemblies when the manufacturer's instructions are followed.

This general approval will remain effective provided the Evaluation Report is maintained valid and unrevised with the issuing organization. Any revisions to the report must be submitted to this Department, with appropriate fee, for review in order to continue the approval of the revised report.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this approval have been met in the project in which it is to be used.

Hoover Treated Wood Products, Inc.
Re: PYRO-GUARD® Fire-Retardant – Treated Wood

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

QUAN NGHIEM, Chief
Engineering Research Section
201 N. Figueroa St, Room 880
Los Angeles, CA 90012
Phone – 213 -202-9812
Fax – 213-202-9943

EB
RR25150
R10/13/2020
TLB2000192
1403/2302.8/2304.10.5

Attachment 1: Table 1 and 2
Attachment 2: Identification