


NOTES:

1. DETAILS TO BE USED IN CONJUNCTION WITH GUIDE SPECIFICATIONS CONTAINING REQUIREMENTS FOR NAILERS, INSULATION, ETC.
2. IN NEW CONSTRUCTION, ACCEPTABLE SUBSTRATES INCLUDE EXTERIOR GRADE PLYWOOD, POURED OR PRECAST CONCRETE, CEMENT BLOCK OR MASONRY WALLS. CONTACT JM TECHNICAL SERVICES FOR OTHER SUBSTRATES.
3. ON REROOFING PROJECTS, AN ACCEPTABLE ASPHALT BARRIER MUST BE INSTALLED OVER THE EXISTING FLASHINGS TO FULLY DIVORCE THE JM PVC FLASHING MEMBRANE FROM ANY INCOMPATIBLE MATERIALS.
4. FOR WALL FLASHINGS OVER 3' - 0" (900 mm), INTERMEDIATE FASTENING IS REQUIRED AT 3' - 0" (900 mm) INTERVALS.

DRAWING NO. PW-31	ADHERED MEMBRANE WALL COVERING			 Johns Manville
	SCALE N.T.S.	ISSUE DATE 3-06	CAD PV31MEF	