



NOTES:

1. DETAILS TO BE USED IN CONJUNCTION WITH GUIDE SPECIFICATIONS CONTAINING REQUIREMENTS FOR NAILERS, INSULATION, ETC.
2. ON REROOF OR RECOVER PROJECTS, VENT PIPES MUST BE CLEANED OF LARGE DEPOSITS OF ASPHALT. JM ALUMINUM TAPE IS WRAPPED AROUND THE PIPE AS A SEPARATION LAYER. NEW ASPHALT COATED CAST IRON PIPES MUST BE WRAPPED WITH JM ALUMINUM TAPE.

DRAWING NO. PF-51	FIELD-FABRICATED VENT PIPE FLASHING			
	SCALE N.T.S.	ISSUE DATE 3-06	CAD PV51MEF	