


NOTES:

1. DETAILS TO BE USED IN CONJUNCTION WITH GUIDE SPECIFICATIONS CONTAINING REQUIREMENTS FOR NAILERS, INSULATION, ETC.
2. ACCORDING TO PROJECT CONDITIONS, THE SPECIFIER AND/OR APPLICATOR MUST DETERMINE THE REQUIRED VERTICAL FLASHING HEIGHT BASED ON REGIONAL CLIMATIC CONDITIONS. 12" (300 mm) MINIMUM.
3. JM PVC-COATED METAL FLASHING MUST EXTEND UNDER A MINIMUM OF TWO COURSES OF SHINGLES.
4. PVC MEMBRANE CANNOT BE IN CONTACT WITH ANY ASPHALTIC MATERIAL.

DRAWING NO. PT-82	TRANSITION TO SHINGLE ROOF			 Johns Manville
	SCALE N.T.S.	ISSUE DATE 3-06	CAD PV82MEF	