



## Evaluation Listing CCMC 13478-L

MASTERFORMAT: 07 21 19.02  
Issued: 2010-11-25  
Re-evaluation due: 2013-11-25

---

### ***JM Corbond III™***

#### ***1. Evaluation***

The product conforms to CAN/ULC-S705.1-01 (including Amendments 1 and 2), Type 1.

For retrofit construction the time period before occupancy is one (1) day.

#### ***2. Description***

A Type 1, spray-applied rigid polyurethane foam of medium density. The foam system consists of two components: "Huntsman" isocyanate and "JM Corbond-III" polymeric resin. The two components are mixed on site by a qualified installer with fixed-ratio positive displacement equipment.

The final cured product is grey.

The long-term thermal resistance (LTTR) for 50 mm is RSI 1.80

#### ***3. Standard and Regulatory Information***

CUFCA (Canadian Urethane Foam Contractors Association) has been identified by Corbond Corporation as the third-party organization that operates the field quality assurance program (FQAP) for the products in accordance with CAN/ULC-S705.2-05.

CUFCA can be contacted at: (866) 467-7729.

See the Preface and the standard for explanation.

Listing Holder: Corbond Corporation  
32404 Frontage Road  
Bozeman, MT 59715  
U.S.A.  
Tel: 406-586-4585

Plant(s): Belgrade, MT, U.S.A.

*This Listing is issued by the Canadian Construction Materials Centre, a program of the Institute for Research in Construction at the National Research Council of Canada. The Listing must be read in the context of the entire CCMC Registry of Product Evaluations.*

*Readers must confirm that the Listing is current and has not been withdrawn or superseded by a later issue. Please refer to <http://www.nrc-cnrc.gc.ca/eng/services/irc/ccmc.html>, or contact the Canadian Construction Materials Centre, Institute for Research in Construction, National Research Council of Canada, 1200 Montreal Road, Ottawa, Ontario, K1A 0R6. Telephone (613) 993-6189. Fax (613) 952-0268.*

***NRC has evaluated the material, product, system or service described herein only for those characteristics stated herein. The information and opinions in this Listing are directed to those who have the appropriate degree of experience to use and apply its contents. This Listing is provided without representation, warranty, or guarantee of any kind, expressed, or implied, and the National Research Council of Canada (NRC) provides no endorsement for any evaluated material, product, system or service described herein. NRC accepts no responsibility whatsoever arising in any way from any and all use and reliance on the information contained in this Listing. NRC is not undertaking to render professional or other services on behalf of any person or entity nor to perform any duty owed by any person or entity to another person or entity.***