



NOTES:

1. DETAILS TO BE USED IN CONJUNCTION WITH GUIDE SPECIFICATIONS CONTAINING REQUIREMENTS FOR NAILERS, INSULATION, ETC.
2. IN NEW CONSTRUCTION, ACCEPTABLE SUBSTRATES INCLUDE EXTERIOR GRADE PLYWOOD, POURED OR PRECAST CONCRETE, CEMENT BLOCK OR MASONRY WALLS. CONTACT JM TECHNICAL SERVICES FOR OTHER SUBSTRATES.
3. ON REROOFING PROJECTS, AN ACCEPTABLE ASPHALT BARRIER MUST BE INSTALLED OVER THE EXISTING FLASHING TO FULLY DIVORCE THE JM PVC REINFORCED FLASHING MEMBRANE FROM ANY INCOMPATIBLE MATERIALS.
4. APPROVED FASTENER MUST BE WITHIN 3" (80 mm) OF VERTICAL SUBSTRATE. MEMBRANE AREAS BETWEEN AND BEHIND THE PLATE MUST BE WELDED SOLID ALL THE WAY TO THE VERTICAL SUBSTRATE.
5. IF THE BACK EDGE OF THE INSEAM PLATE IS GREATER THAN 2" (50 mm) FROM THE VERTICAL SUBSTRATE, THE WALL FLASHING MUST BE ADHERED UTILIZING JM PVC MEMBRANE ADHESIVE.
6. REFER TO DETAIL PB-26 WHERE FASTENER CANNOT BE INSTALLED WITHIN 3" (80 mm) OF VERTICAL SUBSTRATE.

DRAWING NO. PB-25	BASE TIE-IN (FASTENER AND PLATE)			 Johns Manville
	SCALE N.T.S.	ISSUE DATE 3-06	CAD PV25MEF	