

NOTES:

- 1. DETAILS TO BE USED IN CONJUNCTION WITH GUIDE SPECIFICATIONS CONTAINING REQUIREMENTS FOR NAILERS, INSULATION, ETC.
- 2. ACCORDING TO PROJECT CONDITIONS, THE SPECIFIER AND/OR APPLICATOR MUST DETERMINE THE REQUIRED VERTICAL FLASHING HEIGHT BASED ON REGIONAL CLIMATIC CONDITIONS. 12" (300 mm) MINIMUM.
- 3. JM PVC-COATED METAL FLASHING MUST EXTEND UNDER A MINIMUM OF TWO COURSES OF SHINGLES.
- 4. PVC MEMBRANE CANNOT BE IN CONTACT WITH ANY ASPHALTIC MATERIAL.

| DRAWING NO. | TRANSITION TO SHINGLE ROOF | | | |
|-------------|----------------------------|------------|---------|----------------|
| PT-82 | SCALE | ISSUE DATE | CAD | |
| | N.T.S. | 3-06 | PV82MEF | Johns Manville |