


**NOTES:**

1. DETAILS TO BE USED IN CONJUNCTION WITH GUIDE SPECIFICATIONS CONTAINING REQUIREMENTS FOR NAILERS, INSULATION, ETC.
2. IN NEW CONSTRUCTION, ACCEPTABLE SUBSTRATES INCLUDE EXTERIOR GRADE PLYWOOD, POURED OR PRECAST CONCRETE, CEMENT BLOCK OR MASONRY WALLS. CONTACT JM TECHNICAL SERVICES FOR OTHER SUBSTRATES.
3. ON REROOFING PROJECTS, AN APPROVED ASPHALT BARRIER MUST BE INSTALLED OVER THE EXISTING FLASHINGS TO FULLY DIVORCE THE JM PVC FLASHING MEMBRANE FROM ANY INCOMPATIBLE MATERIALS TO AVOID MEMBRANE DISCOLORATION.

DRAWING NO. <b>PW-32A</b>	<b>PVC-COATED METAL STRIP                  INTERMEDIATE FLASHING ATTACHMENT</b>			
	SCALE N.T.S.	ISSUE DATE 3-06	CAD PV33MEF	