


NOTES:

1. DETAILS TO BE USED IN CONJUNCTION WITH GUIDE SPECIFICATIONS CONTAINING REQUIREMENTS FOR NAILERS, INSULATION, ETC.
2. JM TPO EDGE SEALANT IS USED TO SEAL THE MEMBRANE EDGES WHERE REINFORCING FABRIC IS CUT AND EXPOSED. EDGE SEALANT IS REQUIRED ON ALL END LAPS, T-JOINTS, AND FIELD CUT EDGES.
3. IN NEW CONSTRUCTION ACCEPTABLE SUBSTRATES INCLUDE EXTERIOR GRADE PLYWOOD, POURED OR PRECAST CONCRETE, CEMENT BLOCK OR MASONRY WALLS. CONTACT JM TECHNICAL SERVICES FOR OTHER SUBSTRATES.
4. ON REROOFING PROJECTS AN ACCEPTABLE ASPHALT BARRIER SHOULD BE INSTALLED OVER THE EXISTING FLASHINGS TO FULLY DIVORCE THE JM FLASHING MEMBRANE FROM ANY INCOMPATIBLE MATERIALS.
5. FOR WALL FLASHINGS OVER 3' (900 mm), INTERMEDIATE FASTENING IS REQUIRED AT 3' (900 mm) INTERVALS.
6. INSULATION MUST BE COMPATIBLE WITH JM TPO BONDING ADHESIVE.

| | | | | |
|-----------------------------|---------------------------------------|--------------------|-----------------|--|
| DRAWING NO. TW-31 | ADHERED MEMBRANE WALL COVERING | | |  Johns Manville |
| | SCALE N.T.S. | ISSUE DATE 3-06 | CAD TPO-4.02 | |