



- NOTES:**
1. DETAILS TO BE USED IN CONJUNCTION WITH GUIDE SPECIFICATIONS CONTAINING REQUIREMENTS FOR NAILERS, INSULATION, ETC.
 2. IN NEW CONSTRUCTION, ACCEPTABLE SUBSTRATES INCLUDE EXTERIOR GRADE PLYWOOD, POURED OR PRECAST CONCRETE, CEMENT BLOCK OR MASONRY WALLS. CONTACT JM TECHNICAL SERVICES FOR OTHER SUBSTRATES.
 3. ON REROOFING PROJECTS, AN ACCEPTABLE ASPHALT BARRIER SHOULD BE INSTALLED OVER THE EXISTING FLASHINGS TO FULLY DIVORCE THE JM TPO FLASHING MEMBRANE FROM ANY INCOMPATIBLE MATERIALS TO AVOID MEMBRANE DISCOLORATION.

DRAWING NO. TW-33	TPO-COATED METAL PARAPET DRIP EDGE			
	SCALE N.T.S.	ISSUE DATE 3-06	CAD TPO-506	