


**NOTES:**

1. DETAILS TO BE USED IN CONJUNCTION WITH GUIDE SPECIFICATIONS CONTAINING REQUIREMENTS FOR NAILERS, INSULATION, ETC.
2. JM TERMINATION BAR MUST BE FASTENED 1" (25 mm) MAXIMUM FROM THE END.
3. JM TERMINATION BAR MUST BE INSTALLED TO HARD, SMOOTH, NON-POROUS SUBSTRATES.
4. IN NEW CONSTRUCTION ACCEPTABLE SUBSTRATES INCLUDE EXTERIOR GRADE PLYWOOD, POURED OR PRECAST CONCRETE, CEMENT BLOCK OR MASONRY WALLS. CONTACT JM ROOFING SERVICES GROUP FOR OTHER SUBSTRATES.
5. ON REROOFING PROJECTS AN ACCEPTABLE ASPHALT BARRIER SHOULD BE INSTALLED OVER THE EXISTING FLASHING TO FULLY DIVORCE THE JM TPO FLASHING MEMBRANE FROM ANY INCOMPATIBLE MATERIALS.
6. DO NOT APPLY JM SINGLE PLY CAULK OVER ASPHALT OR OTHER MATERIALS THAT WILL PREVENT PROPER ADHESION.

DRAWING NO. <b>TC-44</b>	<b>TERMINATION BAR</b>			
	SCALE N.T.S.	ISSUE DATE 3-06	CAD TPO-5.05	