


- NOTES:
1. WITH MECHANICALLY FASTENED OR BALLASTED SPECIFICATIONS, MEMBRANE MUST BE MECHANICALLY ATTACHED WITH 2" (50 mm) JM EPDM ANCHOR DISC WITH ACCEPTABLE FASTENERS (MINIMUM OF 4 PER PIPE).
 2. DO NOT OVERLAP THE FLANGES FROM ADJACENT PIPE FLASHINGS. ANY SEAM UNDER BOOT FLANGE TO BE TREATED AS T-JOINT.
 3. BOTH SURFACES TO BE MATED MUST BE CLEANED WITH JM TAPE PRIMER/WASH. THE JM TAPE PRIMER/WASH MUST BE COMPLETELY DRY AND TACK FREE BEFORE LAP CEMENT APPLICATION.

DRAWING NO. EP-3	EPDM PIPE FLASHING FOR HOT PIPE			 Johns Manville
	SCALE N.T.S.	ISSUE DATE 3-06	CAD SP03VNT	