


- NOTES:
1. WITH MECHANICALLY FASTENED OR BALLASTED SPECIFICATIONS, MEMBRANE MUST BE MECHANICALLY ATTACHED WITH 2" (50 mm) ANCHOR DISC AND ACCEPTABLE FASTENERS (MINIMUM OF 4 PER PIPE).
 2. BASE PIECE SHOULD EXTEND A MINIMUM OF 3" (80 mm) BEYOND MEMBRANE COLLAR ON ALL SIDES.
 3. BOTH SURFACES TO BE MATED MUST BE CLEANED WITH JM TAPE PRIMER/WASH.
 4. THE JM TAPE PRIMER/WASH MUST BE COMPLETELY DRY AND TACK FREE BEFORE APPLYING JM EPDM LAP CEMENT.

DRAWING NO. EP-2	FIELD-FABRICATED PIPE FLASHING			 Johns Manville
	SCALE N.T.S.	ISSUE DATE 3-06	CAD SP02VNT	