


NOTES:

1. BASE PIECE SHOULD EXTEND A MINIMUM OF 3" (80 mm) BEYOND MEMBRANE COLLAR ON ALL SIDES.
2. WITH MECHANICALLY FASTENED OR BALLASTED SPECIFICATIONS, MEMBRANE MUST BE MECHANICALLY ATTACHED WITH 2" (50 mm) JM EPDM ANCHOR DISCS WITH ACCEPTABLE FASTENERS AROUND PROJECTION (MINIMUM OF 4 PER PIPE).
3. BOTH SURFACES TO BE MATED MUST BE CLEANED WITH JM TAPE PRIMER/WASH. THE JM TAPE PRIMER/WASH MUST BE COMPLETELY DRY AND TACK FREE BEFORE LAP CEMENT APPLICATION.

DRAWING NO. EP-4	FIELD-FABRICATED PIPE FLASHING FOR HOT PIPE			
	SCALE N.T.S.	ISSUE DATE 3-06	CAD SP04PIP	