


- NOTES:**
1. PLACE RTS MINIMUM OF 1/8" (6 mm) TO MAXIMUM OF 1" (25 mm) FROM WALL OR ADJACENT RTS.
 2. BOTH SURFACES TO BE MATED MUST BE CLEANED WITH JM TAPE PRIMER/WASH. THE JM TAPE PRIMER/WASH MUST BE COMPLETELY DRY AND TACK FREE BEFORE LAP CEMENT APPLICATION.
 3. USE T-JOINT PATCH OR 6" (150 mm) WIDTH JM PEEL & STICK SEALING STRIP OVER FIELD SEAM AT CHANGE OF ANGLE.
 4. KEEP RTS 6" (150 mm) TO 9" (225 mm) FROM INSIDE CORNERS.

DRAWING NO. EB-2	WALL OR CURB FLASHING WITH JM EPDM REINFORCED TERMINATION STRIP (RTS) FASTENED TO DECK - ADHESIVE			
	SCALE N.T.S.	ISSUE DATE 3-06	CAD SP02BFW	