

CITY OF LOS ANGELES  
CALIFORNIA

BOARD OF  
BUILDING AND SAFETY  
COMMISSIONERS

VAN AMBATIELOS  
PRESIDENT

E. FELICIA BRANNON  
VICE PRESIDENT

JOSELYN GEAGA-ROSENTHAL  
GEORGE HOVAGUIMIAN  
JAVIER NUNEZ



ERIC GARCETTI  
MAYOR

DEPARTMENT OF  
BUILDING AND SAFETY  
201 NORTH FIGUEROA STREET  
LOS ANGELES, CA 90012

FRANK M. BUSH  
GENERAL MANAGER  
SUPERINTENDENT OF BUILDING

OSAMA YOUNAN, P.E.  
EXECUTIVE OFFICER

Intermat  
2045 Placentia Avenue  
Costa Mesa, CA 92627

Attn: Carleton Elliott  
(714) 412-8647

RESEARCH REPORT: RR 25461  
(CSI #5160)

BASED UPON IAPMO EVALUATION  
SERVICES REPORT NO. 0126

Expires; April 01, 2020  
Issued: January 01, 2018  
Code: 2017 LABC

**GENERAL APPROVAL** – Reevaluation/Clerical Modification - Sure-Board® Series 200,  
200W and 200B Structural Panels Installed on Cold-Formed Steel or Wood Framed Shear Walls.

## DETAILS

The above assemblies and/or products are approved when in compliance with the use, description, design, installation, limitations and identification of Evaluation Report No. 0126, issued January 26, 2010, revised January 5, 2018, of the IAPMO Evaluation Services. The report, in its entirety, is attached and made part of this general approval subject to the following conditions.

The parts of Evaluation Report No. 0126 marked with an asterisk have been deleted or revised by the Los Angeles City Building Department from this approval.

### The approval is subject to the following conditions:

1. Building design calculations and details shall be prepared by an engineer or architect licensed in the state of California and approved by the structural plan check engineer.
2. Special inspection for seismic resistance shall be conducted in accordance with the Sections 1707.1 and 1707.2 of the 2017 Los Angeles City Building Code.
3. All shear walls shall be provided with holdowns.

RR 25461  
Page 1 of 3

## Intermat

### Sure-Board® Series 200, 200W and 200B Structural Panels Installed on Cold-Formed Steel or Wood Framed Shear Walls

4. When designing with Sure-Board® Series 200 and 200W the engineer of the record shall check:
  - All beams under the Sure-Board® Series 200 and 200W for uplift and overturning.
  - Foundation design for overturning, compression and tension.
  - The allowable vertical load on header.
  - The hold-down bolt capacity based on reduced edge and end distances detailed on plans.
  - The drag force at top plates from lateral force distribution in the same shear wall line.
  - Bearing pressure to the sill plate when there are additional vertical loads on top of the Sure-Board® Series 200 and 200W.
5. All nominal and allowable capacities provided in attached report, ER-0126 shall not be increased for short term (transient) loading.
6. Panels located in exterior walls shall be covered with an approved weather-resistant exterior wall envelope complying with Section 1403 of the 2017 City of Los Angeles Building code.
7. Panels must be installed with the published installation instructions by the manufacturer.
8. Fabrication of Sure-Board® Series 200, 200W and 200B shall be in a shop of a fabricator licensed by the City of Los Angeles Building Department, in accordance with the Manufacturing Standards submitted to the Department.

## DISCUSSION

The clerical modification is to update the report is to update the report to 2017 City of Los Angeles Building Code.

The report is in compliance with the 2017 City of Los Angeles Building Code.

The approval is based on test and analysis.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this approval have been met in the project in which it is to be used.

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

Intermat

Sure-Board® Series 200, 200W and 200B Structural Panels Installed on Cold-Formed Steel or Wood Framed Shear Walls

This general approval will remain effective provided the Evaluation Report is maintained valid and unrevised with the issuing organization. Any revisions to the report must be submitted to this Department, with appropriate fee, for review in order to continue the approval of the revised report.

---

Quan Nghiem, Chief  
Engineering Research Section  
201 N. Figueroa St., Room 880  
Los Angeles, CA 90012  
Phone- 213-202-9812  
Fax- 213-202-9943

BKR  
RR25461  
TLB1700434  
R12/28/17  
2315/2210

Attachments: IAPMO Report No. ER-0126 (9 Pages)  
California Supplement (1 Page)