
## Submittal Data - U Channel

## Member Designator 200U50-54

Coating CP60

## **Physical Properties**

Design Thickness 0.0566 in Mil 54 mil Gauge 16 Gauge Web Width 2.00 in Leg Length 0.50 in Yield Strength 33 ksi



## **Gross Properties**

Gross Properties										
Area	lx	Rx	ly	Ry						
(in <sup>2</sup> )	(in <sup>4</sup> )	(in)	(in <sup>4</sup> )	(in)						
0.157	0.079	0.709	0.003	0.136						

# **Effective Properties**

Effective Properties <sup>3</sup> (33ksi)										
lx <sup>2</sup>	Sx	Ma	Va							
(in⁴)	(in <sup>3</sup> )	(in-k)	(lb)							
0.079	0.079	1.87	1190							

## Allowable Ceiling Spans (L/240 & L/360)

		4 psf					6 psf				13 psf					15 psf					
		Channel Spacing (in) o.c.					Channel Spacing (in) o.c.				Channel Spacing (in) o.c.				Channel Spacing (in) o.c.						
Section	Spans	24	36	48	60	72	24	36	48	60	72	24	36	48	60	72	24	36	48	60	72
200U50-54	Single	5' 10"	5' 1"	4' 8"	4' 4"	4' 1"	5' 1"	4' 6"	4' 1"	3' 10"	3' 7"	4' 0"	3' 6"	3' 2"	3' 0"	2' 10"	3' 10"	3' 4"	3' 1"	2' 10"	2' 8"
	Multiple	7' 5"	6' 6"	5' 11"	5' 6"	5' 2"	6' 6"	5' 8"	5' 2"	4' 10"	4' 7"	5' 1"	4' 5"	4' 0"	3' 9"	3' 6"	4' 10"	4' 3"	3' 10"	3' 7"	3' 2"

#### **General Notes**

- 1. Physical properties and load tables have been calculated in conformance with the 2001 NASPEC for the Design of Cold-Formed Steel Structural Members, including the 2004 Supplement, and the IBC 2006, unless noted otherwise.
- $2. \quad \text{All structural framing members have a protective coating conforming to ASTM C 955}.$
- 3. Reference ASTM specification A 1003/A 1003 M table 1 for the universe of allowable coatings for light gauge steel framing.
- $4. \quad Stud/joists \, are \, manufactured \, to \, custom \, lengths. \, Stud/joists \, are \, manufactured \, with \, punched \, webs \, unless \, otherwise \, specified \, at \, time \, of \, order.$
- 5. Track is produced in standard lengths of 10 feet unless a custom track length is indicated. Track is manufactured with unpunched webs.
- 6. Structural framing members are marked with product information per the requirements of ASTM C 955 section 12.
- 7. All delivered material must be kept dry, preferably by being stored inside a building under a roof. If it is necessary to store material outside, it must be stacked off the ground, properly supported on a level platform, and fully protected from the weather. Reference ASTM C 754 section 8 and ASTM C 1007 section 4.

### **LEED Green Building Credits**

MR Credit 2: Construction Waste Management – MBA steel framing is 100% recyclable.

MR Credit 4: Recycled Content – MBA steel framing is formed from no less than 25.5% post-consumer and 6.8% pre-consumer recycled content.

MR Credit 5: Regional Materials – MBA has manufacturing facilities in multiple states.

