



Image II on 19/32" Plywood

Roof Fastener Spacing (feet)

Wind Speed (mph) Exposure Category	Roof Slope: 0.5:12 to 1.5:12	Roof Slope: 1.5:12 to 6:12	Roof Slope: 6:12 to 12:12
120C	Thickness Field Edge Corner 0.032" 2.00 1.00 0.50	Field Edge Corner -18.9 psf -33.1 psf -49.1 psf 2.00 1.00 0.50	Field Edge Corner -20.6 psf -24.2 psf -24.2 psf 2.00 1.50 1.50
	Thickness Field Edge Corner 0.032" 1.50 1.00 0.50	Field Edge Corner -22.2 psf -38.9 psf -57.6 psf 2.00 1.00 0.50	Field Edge Corner -24.3 psf -28.4 psf -28.4 psf 1.50 1.50 1.50
130C	Thickness Field Edge Corner 0.032" 1.50 0.50 0.50	Field Edge Corner -25.8 psf -45.1 psf -66.9 psf 1.50 0.50 0.50	Field Edge Corner -28.2 psf -33 psf -33 psf 1.50 1.00 1.00
	Thickness Field Edge Corner 0.032" 1.00 0.50 0.50	Field Edge Corner -29.6 psf -51.9 psf -76.9 psf 1.50 0.50 0.50	Field Edge Corner -32.4 psf -38 psf -38 psf 1.00 1.00 1.00
140C	Thickness Field Edge Corner 0.032" 1.00 0.50 0.50	Field Edge Corner -33.8 psf -59.1 psf -87.5 psf 1.00 0.50 0.50	Field Edge Corner -36.9 psf -43.3 psf -43.3 psf 1.00 1.00 1.00
	Thickness Field Edge Corner 0.032" 1.00 0.50 0.50*	Field Edge Corner -38.2 psf -66.7 psf -98.8 psf 1.00 0.50 0.50	Field Edge Corner -41.7 psf -48.9 psf -48.9 psf 1.00 0.50 0.50
150C	Thickness Field Edge Corner 0.032" 0.50 0.50 0.50*	Field Edge Corner -42.8 psf -74.8 psf -110.8 psf 1.00 0.50 0.50*	Field Edge Corner -46.8 psf -54.8 psf -54.8 psf 0.50 0.50 0.50
	Thickness Field Edge Corner 0.032" 0.50 0.50 0.50*	Field Edge Corner -47.8 psf -83.4 psf -123.5 psf 0.50 0.50 0.50*	Field Edge Corner -52.2 psf -61.1 psf -61.1 psf 0.50 0.50 0.50
160C			
170C			
180C			
190C			

Notes:

- Allowable spacing is based on a Design Pressures listed in the FBC 2017 Approval, FL11560.3 and determined by linear interpolation of those values. 1/3 increase is not included for wind. The fasteners and patterns are shown in the Approval.
- Allowable spacing is based on an applied load determined using ASCE 7-10 for the Wind Speeds, Wind Exposure Categories, * Roof Slopes, and Roof Zones shown, assuming 10 square feet of tributary area, Enclosed building, 3 or more span case, Topographic Factor of 1, and Mean Roof Height of 25 feet.
- Allowable spacing is determined for wind suction using the combination $0.6DL + 0.6W$. Also considered is the appropriate inward wind pressure, 20 psf live load and the weight of the panel.

* - Indicates that Support Straps must be installed per the Approval.

F FIELD
 E EDGE
 C CORNER
 A LENGTH OF ROOF VALLEY MUST BE AT LEAST 10 FEET. FASTENER SPACING MUST NOT BE LESS THAN 8 FEET.