To view the Sound Tests -SoundBreak XP Gypsum Board Acoustical Selector Guide click on the underlined Test No. **SOUNDBREAK® XP® GYPSUM BOARD PARTITIONS - STEEL FRAMING Fire Rating** Ref. Design No. Description Test No. 5/8" SoundBreak XP Gypsum Board vertically applied to one side of 3-5/8" steel studs 24" o.c. with 1" type S screws 8" o.c. at perimeter and 12" o.c. in the field. 5/8" Fire-Shield Gypsum Board vertically applied to opposite side with 1 hr. 54 UL 11465 RAL TL07-389 1" type S screws 8" o.c. at perimeter and 12" o.c. in the field. Joints staggered on opposite side. 3-1/2" glass fiber in stud cavity. UNBALANCED – 3-5/8" STUDS Base layer 5/8" SoundBreak XP Gypsum Board vertically applied to 3-5/8" steel 57 UL U465 RAL TL06-334 Studs spaced 24" o.c. with 1" type S screws 24" o.c. Face layer 5/8" Fire-Shield Gypsum Board vertically applied with 1-5/8" type S screws 12" o.c. Opposite side 5/8" Fire-Shield Gypsum Board vertically applied with 1" type S screws 12" o.c. Vertical joints staggered 24" each layer and opposite sides. 3-1/2" glass fiber in stud cavity. Base layer 5/8" SoundBreak XP Gypsum Board vertically applied to 3-5/8" steel studs spaced 24" o.c. with 1" type S screws 24" o.c. Face layer 5/8" Fire-Shield Gypsum Board vertically applied with 1-5/8" type S screws 12" o.c. Opposite 2 hr. V484 RAL TL07-168 60 UL side two layers 5/8" Fire-Shield Gypsum Board vertically applied. Base layer attached with 1" type S screws 24" o.c. Face layer attached with 1-5/8" type S screws 12" o.c. Vertical joints staggered 24" each layer and opposite sides. 3-1/2" glass fiber in stud cavity. Base layer 5/8" SoundBreak XP Gypsum Board vertically applied to 6" steel studs spaced 24" o.c. with 1" type S screws 24" o.c. Face layer 5/8" Fire-Shield Gypsum Board vertically applied with 1-5/8" type S screws 12" o.c. Opposite 2 hr. UL V484 NRCC B-3456.2 61 side two layers 5/8" Fire-Shield Gypsum Board vertically applied. Base layer attached with 1" type S screws 24" o.c. Face layer attached with 1-5/8" type S screws 12" o.c. Vertical joints staggered 24" each layer and opposite sides. 6 glass fiber in stud cavity. UNBALANCED DOUBLE ROW -Base layer 5/8" SoundBreak XP Gypsum Board vertically applied to double row of 2-1/2" steel studs 24" o.c. with 1" type S screws 8" o.c. at perimeter and 12" o.c. in the field. Face layer 5/8" Fire-Shield C Gypsum Board vertically applied with 1-5/8" Type S screws 12" o.c. 5/8" Fire-Shield C Gypsum Board applied vertically to opposite side with 1" type S screws 8" o.c. at perimeter applied vertically control to the field side with 1" type S screws 8" o.c. at perimeter V488 NGC 2008036 59 and 12" o.c. in the field. Joints staggered on opposite side. 3" glass fiber or mineral wool insulation in stud cavity. SOUNDBREAK® XP® GYPSUM BOARD PARTITIONS – WOOD FRAMING **Fire Rating** Ref. Design No. Description Test No. STC U309 5/8" SoundBreak XP Gypsum Board vertically applied to each side of 2x4 RAL TL07-145 53 1 hr. studs spaced 24" o.c. with 1-1/4" type W screws 12" o.c. 3-1/2" glass fiber in stud cavity. Base layer 5/8" Fire-Shield Gypsum Board vertically applied to staggered 2x4 studs spaced 16" o.c. on 2x6 plates with 1-1/4" type W screws 12" o.c. Face layer of 5/8" SoundBreak XP vertically applied with 2" type W screws 16" o.c. Opposite side 5/8" Fire-Shield Gypsum Board vertically applied with 1-1/4" type W screws 12" o.c. Vertical joints staggered 16" each layer and opposite sides. 2-1/2" glass fiber in stud cavity. 60 1 hr. Based on RAL TL07-170 WP3514 1 hr. Base layer 5/8" Fire-Shield Gypsum Board vertically applied to double row of 2x4 studs spaced 16" o.c. on separate plates with 1-1/4" type W screws 12" o.c. Face layer of 5/8" SoundBreak XP vertically applied with 2" type W screws 64 Based on RAL TL07-147 GΑ WP3514 16" o.c. Opposite side 5/8" Fire-Shield Gypsum Board vertically applied with 1-1/4" type W screws 12" o.c. Vertical joints staggered 16" each layer and opposite sides. 3-1/2" glass fiber in stud cavity.

SOUNDBREAK™ GYPSUM BOARD PARTITIONS – AREA SEPARATION WALL						
Fire Rating		Ref.	Design No.	Description	Test No.	STC
H-S1	TUD AREA SEPARATION WALL					
2 hr.	, <u>,</u>	UL	U347	Two layers of 1" Fire-Shield Shaftliner or Fire-Shield Shaftliner XP inserted in 2" H-studs spaced 24" o.c. Minimum 3/4" air space between shaftliner and adjacent construction.	NRCC B-3451.1	67
				5/8" SoundBreak XP Gypsum Board vertically applied to outside of 2x4 studs spaced 16" o.c. with 1-1/4" type W screws 12" o.c. 3-1/2" glass fiber in stud cavity.		