



The Public Health and Safety Organization

NSF Product and Service Listings

These NSF Official Listings are current as of **Wednesday, October 18, 2023** at 12:15 a.m. Eastern Time. Please contact NSF to confirm the status of any Listing, report errors, or make suggestions.

Alert: NSF is concerned about fraudulent downloading and manipulation of website text. Always confirm this information by clicking on the below link for the most accurate information:

<http://info.nsf.org/Certified/PwsComponents/Listings.asp?Company=41060&>

NSF/ANSI/CAN 61 Drinking Water System Components - Health Effects

NOTE: Unless otherwise indicated for Materials, Certification is only for the Water Contact Material shown in the Listing. Click here for a list of Abbreviations used in these Listings. Click here for the definitions of Water Contact Temperatures denoted in these Listings. Products certified to NSF/ANSI/CAN 61 comply with the health effects criteria in NSF/ANSI/CAN 600.

Simpson Strong-Tie Company

5956 West Las Positas Boulevard

Pleasanton, CA 94588

United States

800-999-5099

Facility : West Chicago, IL

Joining and Sealing Materials

Trade Designation	Size	Water Contact Temp	Water Contact Material
Adhesives			
AT-XP	[1]	CLD 23	ACR
AT-XP10	[1]	CLD 23	ACR
AT-XP13	[1]	CLD 23	ACR

AT-XP30	[1]	CLD 23	ACR
ET-3G	[2]	CLD 23	EPOXY
ET3G10	[2]	CLD 23	EPOXY
ET3G22	[2]	CLD 23	EPOXY
ET3G56	[2]	CLD 23	EPOXY
SET-3G	[2]	CLD 23	EPOXY
SET-XP	[2]	CLD 23	EPOXY
SET-XP22	[2]	CLD 23	EPOXY

[1] Certified for a maximum exposed surface area of 25 sq. in./1000 gal.

[2] Certified for a maximum exposed surface area of 216 sq. in./1000 gal.

Sealants

CI-LV	[3]	CLD 23	EPOXY
CILV32	[3]	CLD 23	EPOXY
CILV3KT	[3]	CLD 23	EPOXY
ET3G10	[2]	CLD 23	EPOXY
ET3G22	[2]	CLD 23	EPOXY
ET3G56	[2]	CLD 23	EPOXY
SET-3G	[2]	CLD 23	EPOXY
SET-XP	[2]	CLD 23	EPOXY
SET-XP22	[2]	CLD 23	EPOXY

[2] Certified for a maximum exposed surface area of 216 sq. in./1000 gal.

[3] Certified for a maximum surface area of 568 square inches per 1000 gallons. Mix ratio 2:1 (Resin:Cure).

Protective (Barrier) Materials

Trade Designation	Water Contact Size Restriction	Water Contact Temp	Water Contact Material
Coatings - Fittings [1]			
Simpson Strong-Tie Composite Strengthening System	>= 1"	CLD 23	EPOXY

[1] Product is applied in multiple layers with Layers 1,2, and 3 optional:

Protective (Barrier) Materials

Layer 1: CSS-ES Epoxy Primer and Saturant apply 10 wet mils maximum. Mix ratio of Part A to B is 2:1 by volume. Mix with a drill and mixing paddle until uniformly blended (5

[1] Product is applied in multiple layers with Layers 1,2, and 3 optional:

Protective (Barrier) Materials

Layer 1: CSS-ES Epoxy Primer and Saturant apply 10 wet mils maximum. Mix ratio of Part A to B is 2:1 by volume. Mix with a drill and mixing paddle until uniformly blended (5 minutes at 500 rpm). Apply 1 coat.

Layer 2: CSS-EP Paste Filler apply 40 wet mils maximum. Mix ratio of Part A to B is 2:1 by volume. Mix with a drill and mixing paddle until uniformly blended (5 minutes at 500 rpm). Apply 1 coat.

Layer 3: CSS-CUGF27 Fabric saturated with CSS-ES Epoxy Primer and Saturant (follow mixing instructions above). Apply with maximum thickness of 50 mils. It is permitted to place Layer 3 between layers of carbon fabric (Layers 4+).

Layer 4+: CSS-CUCF11, CSS-CUCF22, or CSS-CUCF44 Fabric saturated with CSS-ES Epoxy Primer and Saturant (follow mixing instructions above). Apply 1 - 10 layers with a maximum thickness of 20 mils per layer of CSS-CUCF11, 40 mils per layer of CSS-CUCF22, or 80 mils per layer of CSS-CUCF44.

Saturation rate for fabrics: 1 gallon per 75 square feet of CSS-CUCF11; 1 gallon per 50 square feet of CSS-CUCF22; 1 gallon per 50 square feet of CSS-CUGF27; and 1 gallon per 25 square feet of CSS-CUCF44.

Final cure time is 72 hours at 70°F after application of final layer. There is no cure between the application of layers.

Number of matching Manufacturers is 1

Number of matching Products is 23

Processing time was 0 seconds