

**SECTION 03 XX XX**

**Curing Agent, Water-Cure Equivalent Type**

**PART 1 – GENERAL**

**1.1 SECTION INCLUDES**

- A. Work includes labor, materials, appliances, tools, equipment, facilities, transportation, and services necessary for and incidental to performing operations in connection with furnishing, delivery, and installation of the work of this Section, complete as shown on the drawings and/or specified herein.
- B. Zero VOC Curing Agent, Water-Cure Equivalent Type, used to cure freshly placed interior or exterior concrete. This Non-reactive, inorganic concrete curing agent that shall replace water-cure, blankets, membrane forming cure, dissipating cure and plastic sheeting.
- C. Single application for suspended, on or below-grade concrete floor slabs that are not to receive moisture sensitive floor covering. (For moisture sensitive flooring see **Curing Agent, Moisture Emission Reducing** specification)

**1.2 RELATED SECTIONS**

- A. Division 03: Cast-in-Place Concrete
- B. Division 03: Curing Agent, Moisture Emission Reducing
- C. Division 03: Polished Concrete Systems
- D. Division 07: Vapor retarders
- E. Division 09: Sealer/Densifier/Dustproofer/Hardener

**1.3 REFERENCES**

- A. American Concrete Institute (ACI)
  - 1. 301 – Structural Concrete for Buildings
  - 2. 302.1R-15 Guide for Concrete Floor Slab Construction
- B. Health Product Declaration Collaborative (HPD)
  - 1. HPD v.2.2
- C. USGBC LEED 4
  - 1. EQ Credit 1.0, 4.1 and 4.3
  - 2. EQ Credit 10, 3.1
  - 3. MR Credit 5.1 and 5.2

## PROJECT HEADER

### D. ASTM International (ASTM)

1. ASTM C39 - Standard Test Method for Compressive Strength of Cylindrical Concrete Specimens
2. ASTM C156 - Standard Test Method for Water Loss [from a Mortar Specimen] Through Liquid Membrane-Forming Curing Compounds for Concrete
3. ASTM C309 - Liquid Membrane-Forming Compounds for Curing Concrete (Section 6)
4. ASTM C666 - Standard Test Method for Resistance of Concrete to Rapid Freezing and Thawing.
5. ASTM C672 - Standard Test Method for Scaling Resistance of Concrete Surfaces Exposed to Deicing Chemicals.
6. ASTM C882 - Standard Test Method for Bond Strength of Epoxy-Resin Systems Used With Concrete By Slant Shear.
7. ASTM C882 - Standard Test Method for Bond Strength of Epoxy-Resin Systems Used With Concrete By Slant Shear.
8. ASTM C944 - Standard Test Method for Abrasion Resistance of Concrete or Mortar Surfaces by the Rotating-Cutter Method.
9. ASTM C1202-93 – Standard Test Method for Electrical Indication of Concrete’s Ability to Resist Chloride Ion Penetration
10. ASTM E1155 Standard Test Method for Determining Floor Flatness and Levelness Using the F-Number System (inch-Pound Units)

### C. National Sanitation Foundation (NSF)

1. NSF/ANSI 61 Health Effects for Drinking Water System Components
2. NSF 327 lead content

### D. AASHTO

1. T 227-93

## 1.4 SYSTEM DESCRIPTION

### A. Concrete Curing Agent Water-Cure Equivalent Type:

1. Shall be equal to or exceed the performance of 28-day water-cured quality concrete per ASTM C-39, ASTM C-1202.
2. Shall reduce or eliminate cure-related cracking.
3. Shall not to leave a film or coating on the concrete surface. Will not interfere with the bonding or performance line markings or paints.
4. Shall be compatible with all bond-breakers, patching compounds, leveling products, and joint sealants.
5. Shall be GREENGUARD Gold Children and Schools Certified.
6. Shall be compatible with silicate hardeners, stains or dyes and polish systems.

### B. Fire / Safety / Habitability Criteria:

## PROJECT HEADER

1. Flammability: Provide water-based materials.
  2. Hazard Rating: Materials used shall comply with local and federal VOC criteria.
- D. Air Quality Compliance:
1. Product shall be GREENGUARD Gold Children & Schools indoor air quality certified.
  2. Shall be listed as Super-Compliant by the South Coast Air Quality Management District
  3. Shall exceed SCAQMD Rule 1113

### 1.5 SUBMITTALS

- A. Product Data:
1. Submit manufacturer's printed descriptions of materials, components and systems; performance criteria; use limitations; preparation instructions and recommendations; storage and handling requirements and recommendations; and installation methods.
  2. Submit all appropriate SDS sheets.
  3. Shall provide certified independent laboratory test reports verifying all claimed ASTM and related test results.
- B. Shop Drawings:
1. Submit shop drawings indicating flooring/finish schedule.
  2. (optional) Photo documentation of application.
- C. Quality Assurance Submittals: Submit the following:
1. Qualifications: Submit manufacturer and installer's qualifications specified herein.
  2. Manufacturer's Instructions: Manufacturer's installation procedure.

### 1.6 QUALITY ASSURANCE

- A. Single Source Control: Obtain concrete curing agents, finishing aids and hardeners from a single source.
- B. Manufacturer Qualifications: Manufacturer shall provide the following:
1. Manufacturer shall furnish written proof of operations as a formulator of specialty concrete treatments for at least 20 years.
  2. Product/Specification basis of design shall be manufactured by SINAK Corporation and distributed exclusively through authorized agents to ensure product quality and consistency.
  3. Manufacturer shall provide field service representation or real time video support inclusive with no additional expense to the client
  4. Manufacturer shall provide documentation of completed, successful projects performed during this period.
  5. EPA – US Environmental Protection Agency: Product as supplied must be certified contain no VOC's.

## PROJECT HEADER

6. Product manufacturer shall maintain product liability insurance of not less than 5 million dollars per occurrence.
- C. Contractor Licensing:
  1. Applicator shall provide upon request a valid contractor's license issued for either C-33 or C-8 in the State in which this work will be accomplished.
- E. General Contractor is to coordinate slab installation and finish to be compatible with the specified flooring products or finished in Division 9.

### 1.7 PRE-INSTALLATION MEETING

- A. A pre-installation meeting shall be held to verify project requirements, substrate conditions, manufacturer's installation instructions and subsequent flooring requirements are verified.

### 1.8 DELIVERY, STORAGE, AND HANDLING

- A. Ordering: Shall comply with manufacturer's ordering instructions and lead-time requirements to avoid construction delays.
- B. Delivery: Deliver materials in manufacturer's original, unopened, undamaged containers with identification labels attached.
- C. Storage and Protection: Store materials protected from exposure to harmful weather conditions and at temperature conditions recommended by manufacturer.
  1. Store materials in a dry, secure area.
  2. Maintain minimum temperature of 40° F and maximum temperature of 85° F.

### 1.9 WARRANTY

- A. Provide a copy of the manufacturers' warranty and conditions.

## PART 2 – PRODUCTS

### 2.1 CURING AGENT, WATER-CURE EQUIVALENT TYPE

- A. Contract documents are based on products manufactured by SINAK Corporation, San Diego, CA, (800-523-3147). Products by other manufacturers that meet or exceed the following requirements and are approved equivalent by the Architect and Structural Engineer, may be provided.

## PROJECT HEADER

1. Finishing Aid: Only SINAK Finishing Aid for use during placement and finishing operations is allowed. Addition of water on the surface for finishing is not allowed.
2. LithiumCure 2000: for interior surfaces with a hard trowel finish or surfaces to be sealed/densified or polished concrete systems.
3. LithiumCure 1000: for exterior textured or broom finished slabs or open surface profiled concrete. For use on Potable Water applications.

## 2.2 SOURCE QUALITY

- A. Source Quality: Obtain curing, finishing, sealing and hardening products from a single source manufacturer.
- B. Product performance requirements shall conform to requirements specified herein. Certified independent laboratory test certificates are required to verify test data.

## 2.3 MATERIALS

- A. **SINAK Finishing Aid**: Friction-reducing formula certified by the manufacturer to not interfere with curing agents, compounds, and floor finishes and to not affect water-to-cement ratio of the cement paste. Product to be UL GREENGUARD Gold certified and contain zero (0) VOCs.
- B. **SINAK LithiumCure 2000** is a curing agent, water cure equivalent type, clear, penetrating water-based curing agent, Type 1 Class A, material intended for use on interior hard troweled or burnished concrete. It is a non-toxic material containing zero VOC's providing properties and test results in full compliance with the following:
  1. ASTM C-39: results shall be equal to or exceeding 28-day continuous water soak cured concrete results.
  2. ASTM C1202 (Internal Permeability): shall be equal to a 28-day water cure.
  3. Initial Surface Absorption Tests BS 1881: Part 5 – Performance shall be equal to 28 day-water cured concrete samples.
  4. ASTM C-156: Less than .38 kg/m<sup>2</sup> in 72 hr.
- C. **SINAK LithiumCure 1000** is a penetrating curing agent, water cure equivalent type, material intended for use on exterior open surface concrete and in

## PROJECT HEADER

Potable Water applications. It is a non-toxic material containing zero VOC's providing properties and test results in full compliance with the following:

1. ASTM C-39: results shall be equal to or exceeding 28-day continuous water soak cured concrete results.
2. ASTM C1202 (Internal Permeability): shall be equal to a 28-day water cure.
3. Initial Surface Absorption Tests BS 1881: Part 5 – Performance shall be equal to 28 day-water cured concrete samples.
4. ASTM C-156: Less than .38 kg/m<sup>2</sup> in 72 hr.
5. ASTM C666: decrease of mass 13% with Total dilation of less than 1% after 300 cycles
6. ASTM C672: Visual scale 0.
7. Arkansas DOT/FHWA test: 19-40% less cracking than the 7-day water cure/C-309 treated surfaces in comparison
8. Availability in Type 1 or 2, Class A.
9. NSF/ANSI 61: Passed
10. NSF 327: Passed

## PART 3 – EXECUTION

### 3.1 PROJECT CONDITIONS

- A. The concrete shall be placed in accordance with normally accepted standards and guidelines by American Concrete Institute (ACI) 302. Water/cement ratio is recommended to be .45 but must be no greater than 0.50.
- B. Site verification of conditions: Verify concrete substrate conditions are acceptable for product installation in accordance with manufacturer's instructions.
  1. Prior to work in this section, carefully inspect the installed work of all other trades and verify that all such work is complete to the point where this installation may properly commence.
  2. Verify that work in this section may be installed in strict accordance with the original design, all pertinent codes and regulations and all pertinent portions of the referenced standards.
  3. Verify concrete finish is within material manufacturer's acceptable range.
  4. In the event of discrepancy, immediately notify the Architect. Do not proceed with application in area of discrepancy until all such discrepancies have been fully resolved.

### 3.2 EXAMINATION

- A. All finishing work must be complete and the surface firm enough to support foot traffic without leaving marks prior to the application of curing agent.

## PROJECT HEADER

- B. Early entry saw cutting or Soff-Cut operation and subsequent clean up shall be completed prior to the application of the product for optimal performance.
- C. In hot weather or windy conditions, installation of the curing agent shall be done as soon as possible, however, all saw cuts and slab edges shall be treated once cleaned and or forms are removed.

### 3.3 INSTALLATION

- A. Curing Agent application shall comply with manufacturer's written instructions and recommendations.
- B. Installation should be continuous. If rain should occur at any time during process; see "Interrupted Applications" at the end of the Product Information Sheet.
- C. (Interior Applications) **LithiumCure 2000** application should begin after the saw cutting operations and clean up is complete or when the concrete surface is firm enough to tolerate foot traffic without damaging the substrate.
- D. Apply **LithiumCure 2000** into the joints first then immediately apply to the surface of the concrete wetting the surface with an airless or low-pressure sprayer. DO NOT allow **LithiumCure 2000** to puddle.
  - a. Coverage Rates:
    - i. Single coat coverage rate for LithiumCure 2000 is 400-450 square feet per gallon for smooth-troweled concrete.
    - ii. Rates may vary due to substrate and environmental conditions.
- E. (Exterior Applications) **LithiumCure 1000** application should begin after the saw cutting operations and clean up is complete or when the concrete surface is firm enough to tolerate foot traffic without damaging the substrate.
- F. Apply **LithiumCure 1000** into the joints first then immediately apply to the surface of the concrete wetting the surface with an airless or low-pressure sprayer. DO NOT allow **LithiumCure 1000** to puddle.
- G.
  - a. Coverage Rates:
    - i. Two coat coverage rate for LithiumCure 1000 is 200-250 square feet per gallon on horizontal pavements
    - ii. Two coat coverage for LithiumCure 1000 is 150-200 square feet per gallon for vertical cast-in-place concrete
    - iii. Rates may vary due to substrate and environmental conditions.
- H. Clean all equipment by rinsing with water.

## PROJECT HEADER

### 3.4 PROTECTION

- A. Be responsible for protection of work area until owner's acceptance. Owner shall be responsible for reasonable care and maintenance of the installed treatment upon completion.
- B. Provide safe storage of product before and during application. Product that freezes shall be discarded.
- C. Be responsible to protect adjacent construction materials, glass, and metals which may be stained by overspray.

**END OF SECTION**