

## INSTALLATION INSTRUCTIONS

(Part Numbers: EZDR200, EZDR400)




EZ Path Retrofit Device

EZDR200 only: Rear Plate Adjustment




Optional Ground Attachment







Parts Included (Not to Scale)

## Sleeve Mounted Installation







Page 1 of 2 Warranty: www.stifirestop.com/legal/warranty Made in USA • Printed in USA ZIS1254 3579



**Specified Technologies Inc.** Somerville, NJ 08876 USA T: (800) 992-1180 F: (908) 526-9623 **www.stifirestop.com** 






## INSTALLATION INSTRUCTIONS



(Part Numbers: EZDR200, EZDR400)

Surface Mounted Installation



Note: Cables are deliberately not shown in any of the images to clarify device installation. However, a visual cable loading of 50 to 100% is required. For cable types and sizes, refer to applicable UL Certified Systems.

For fastener types, consult the latest UL® fire resistance directory for permissible types and sizes.

For more information on firestop installation, refer to ASTM E3157.

Page 2 of 2 Warranty: www.stifirestop.com/legal/warranty Made in USA • Printed in USA ZIS1254 3579



**Specified Technologies Inc.** Somerville, NJ 08876 USA T: (800) 992-1180 F: (908) 526-9623 **www.stifirestop.com** 



