

CERTIFICATION LETTER

We certify that ExoAir LEF has been tested in accordance with ASTM test methods and the following data are the results of the most recent testing:

ASTM E 90 (Tested in a 5/8" joint in combination with ExoAir Eco and ExoAir Duo Membrane)

STC rating 50

OITC rating 28

ASTM E 90 (Tested in a 5/8" joint in combination with ExoAir Duo Membrane on both sides)

STC rating 50

OITC rating 38

ASTM E 84

Flame Spread 5

Smoke Development 30