



Tremco Commercial Sealants & Waterproofing
3735 Green Road
Beachwood, OH 44122
US: 800.852.9068
Canada: 800.363.3213
www.tremcosealants.com

We certify that Vulkem® 445SSL has been tested to ASTM C 920, Standard Specification for Elastomeric Joint Sealants and does conform to the specification requirements and is classified as follows:

Type:	M	(Multiple Component)
Grade:	P	(Pourable)
Class:	35	(+/- 35% joint movement)
Use:	T	(Traffic)
	M	(Mortar)
	A	(Aluminum)
	O	(Other)
	I	(Immersion Service – Class 2).

We further certify that Vulkem 445SSL conforms to the requirements of Federal Specification TT-S00230C, Type I, Class A.

Vulkem 445SSL meets CAN/CGSB 2-19.13, MC-1-25 B-N.