

In Plant Testing

The Williams Brothers Corp. of America
Marcus Williams
1330 Progress Drive
Front Royal, VA 22630

Report Date: August 26, 2025
Author: Richard B. Luna
Report Number: ESP044689P.1

PRODUCT NAME: William Brothers Roof Hatch
PRODUCT TYPE: Roof Hatch
SERIES/MODEL: WB RH/WB RH-AL

Standard/Specifications	Summary
ASTM E283/E283M-19	0.62 L/(s•m²) (0.12 cfm/ft²)
ASTM E547-00 (2016)	DP30
ASTM E330/E330M-14 (2021)	DP+50/DP-50

Unless otherwise specified, measurement uncertainty will not be taken into account when making statements of conformity to a specification. The data herein represents only the item(s) tested. This report shall not be reproduced, except in full, without prior permission of Element Materials Technology.

EAR Controlled Data: This document contains technical data whose export and re-export/retransfer is subject to control by the U.S. Department of Commerce under the Export Administration Act and the Export Administration Regulations. The Department of Commerce's prior written approval may be required for the export or re-export/retransfer of such technical data to any foreign person, foreign entity or foreign organization whether in the United States or abroad.

This project shall be governed exclusively by the General Terms and Conditions of Sale and Performance of Testing Services by Element Materials Technology. In no event shall Element Materials Technology be liable for any consequential, special or indirect loss or any damages above the cost of the work.

This certificate shall not be reproduced, except in full, without the written approval of the laboratory.

EAR-CONTROLLED DATA

INTRODUCTION:

The following report presents the results of tests conducted on a WB-RH Roof Hatch 48 x 48" manufactured by The Williams Brothers Corp. of America. Testing was conducted on July 30, 2025 by Richard Luna of Element Des Moines. The tests were requested by Marcus Williams of The Williams Brothers Corp. of America and were performed at Element Des Moines.

The purpose of the testing was to determine the performance of the window for the air leakage resistance test in accordance with ASTM E283/E283M-19, water penetration resistance test in accordance with ASTM E547-00 (2016), uniform load deflection test and uniform load structural test in accordance with ASTM E330/E330M-14 (2021).

SUMMARY OF RESULTS:

<u>Test</u>	<u>Measured</u>
<u>Air Leakage Resistance Test</u>	
@ +300 Pa (6.24 psf)	0.62 L/(s•m ²) (0.12 cfm/ft ²)
<u>Water Penetration Resistance Test</u>	
@ 220 Pa (4.60 psf)	No Entry: Complies
<u>Uniform Load Deflection Test</u>	
@ 2400 Pa (50.13 psf) Positive/ 2400 Pa (50.13 psf) Negative Deflection	Complies 0.00 mm (0.000 in) Pos., 0.00 mm (0.000 in) Neg.

EAR-CONTROLLED DATA

TEST RESULTS:

AIR LEAKAGE RESISTANCE TEST

Parameter	Units	Measured	Allowable Requirement
Total Product Area	m ² (ft ²)	1.49 (16.00)	----
Total Sash Crack Length	m (ft.)	4.47 (14.67)	----
Test Pressure Difference - Infiltration	Pa (psf)	+300 (6.24)	300 (6.24)
Air Leakage	L/s (cfm)	0.92 (1.94)	----
Air Leakage Rate	L/(s•m ²) (cfm/ft ²)	0.62 (0.12)	Reporting Only

WATER PENETRATION RESISTANCE TEST

Parameter	Units	Measured	Allowed Requirement
Test Pressure Difference	Pa (psf)	220 (4.60)	N/A
Water Flow	L/(m ² •min) (GPH/ft ²)	3.4 (5)	3.4 (5)
Duration Static (15 min.)	Minutes	15	Report Only
Water Penetration Resistance	----	Complies	No Entry of water past water/test plane

UNIFORM LOAD DEFLECTION TEST

Parameter	Units	Measured	Allowed Requirement
Maximum Test Load - Positive	Pa (PSF)	2400 (50.13)	N/A
Duration	Seconds	10	10
Deflection Under Load Span of unsupported No Deflection = 0 mm (0.000 in)	mm (inches)	0.00 (0.000)	Report Only
Maximum Test Load - Negative	Pa (PSF)	2400 (50.13)	N/A
Duration	Seconds	10	10
Deflection Under Load Span of unsupported No Deflection = 0 mm (0.000 in)	mm (inches)	0.00 (0.000)	Report Only
OVERALL PERFORMANCE	----	Complies	No breakage of glass or damage to render unit inoperable

EAR-CONTROLLED DATA

TEST METHODS:

Air Leakage Resistance Test

ASTM E283/E283M-19, "Standard Test Method for Determining the Rate of Air Leakage Through Exterior Windows, Curtain Walls and Doors Under Specified Pressure Differences Across the Specimen".

Water Penetration Resistance Test

ASTM: E547-00 (2016), "Standard Test Method for Water Penetration of Exterior Windows, Skylights, Doors, and Curtain Walls by Cyclic Static Air Pressure Difference."

Uniform Load Deflection Test

E330/E330M-14 (2021) "Standard Test Method for Structural Performance of Exterior Windows, Curtain Walls, and Doors by Uniform Static Air Pressure Difference".

Uniform Load Structural Test

E330/E330M-14 (2021) "Standard Test Method for Structural Performance of Exterior Windows, Curtain Walls, and Doors by Uniform Static Air Pressure Difference".

TEST UNIT DESCRIPTION:

Product Name	: William Brothers Roof Hatch
Product Type	: Roof Hatch
Series/Model #	: WB RH/WB RH-AL
Rating Tested To	: Air Leakage: +300 Pa Water Resistance: DP30 Structural Tests: +DP50/ -DP50
Overall Frame Size	: 1219 x 1219 mm (48.000 x 48.000 inches)
Sash Size	: N/A
Finish	: Durable re-coatable gray primer finish
Reinforcement	: N/A
Curb Construction	: Curb shall be 14 ga. (G 90) galvanized steel with durable re-coatable gray primer finish standard. Curb shall be 12" (304mm) in height with a 4" (101mm) fiber board insulation, and mounting holes for roof attachment. Curb shall have integral cap flashing of the same material and thickness as the curb. Curb and cap flashing shall be fully welded at the corners for a watertight construction. Hinges are two-piece formed steel, with a non-removable heavy-duty pivot pin.
Cover Construction	: Cover shall be 14 ga. (G 90) galvanized steel, with radius corners for safety, and shall be fully welded at the corners for watertight construction. An extruded rubber gasket, mechanically fastened to the inside of the lid shall cause the hatch lid to seal.
Screen Construction	: N/A

EAR-CONTROLLED DATA

TEST UNIT DESCRIPTION:

Glazing System : N/A

Weather Strip : Weather resistant gasket

Weeps : N/A

Hardware : Hardware shall include interior handle, with a positive, one-point locking mechanism, exterior handle, and provisions for padlock, both inside and out. Pre-lubricated compression springs, encased in zinc-plated telescopic tubes, for smooth and controlled door operation at any position. An automatic, hold-open arm, with vinyl grip, shall be standard. All hardware shall be corrosion resistant, and all fasteners shall be of a self-locking type

Joint Sealant Application : N/A

General Installation Description : Screw Install

Installation Method : (4) screws on each side, (1) screw at the top and bottom in the center.

REMARKS:

The samples of the tested unit will be held in the laboratory for a period of one (1) month then disposed of.

C:\Users\RLuna\Desktop\ALL REPORTS.2\ESP044689P\ESP044689P.1 Final.Docx

Respectfully submitted,

Tested and Prepared By:



Richard B. Luna
Project Manager
P 515-309-4228

Reviewed By:



Brian S. Escherich
Operations Manager, Des Moines
Individual in Direct Charge
P 515-309-4220